

JINZHOU, China

WMO: 543370

Lat: 41.1402N

Lon: 121.1224E

Elev: 70

StdP: 100.49

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.9	-14.0	-29.6	0.2	-10.5	-27.3	0.3	-9.6	8.1	-4.3	7.2	-4.8	1.6	20	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	32.1	22.1	30.8	21.8	29.6	21.6	25.8	28.9	25.0	27.9	24.2	27.1	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.2	27.8	24.1	19.2	26.9	23.3	18.2	26.2	80.5	28.9	77.1	28.0	73.7	27.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.4	6.4	-17.5	34.9	2.6	1.9	-19.4	36.2	-21.0	37.4	-22.4	38.5	-24.3	39.9		
			-18.5	27.1	2.4	1.0	-20.2	27.8	-21.7	28.4	-23.0	29.0	-24.8	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-6.8	-2.9	3.6	11.6	18.3	22.4	25.4	24.8	20.0	12.3	2.7	-4.5
	DBStd	11.87	3.93	4.12	4.28	3.67	3.24	2.57	2.04	2.23	3.01	4.21	5.13	4.08
	HDD10.0	1803	519	360	201	25	0	0	0	0	0	26	223	448
	HDD18.3	3454	778	593	456	202	40	2	0	0	18	190	469	707
	CDD10.0	2042	0	0	4	74	258	372	477	457	298	97	4	0
	CDD18.3	652	0	0	0	1	40	124	218	199	67	3	0	0
	CDH23.3	4906	0	0	0	14	307	823	1776	1598	378	9	0	0
	CDH26.7	1366	0	0	0	3	65	245	539	456	58	1	0	0
Wind	WSAvg	2.8	2.1	2.7	3.2	3.5	3.3	3.0	2.9	2.5	2.5	2.6	2.5	2.2
Precipitation	PrecAvg	581	3	4	7	29	42	83	179	132	63	28	8	3
	PrecMax	1134	18	30	29	140	108	277	566	307	193	79	30	26
	PrecMin	348	0	0	0	4	13	10	28	24	2	0	0	0
	PrecStd	167	4	6	8	27	27	53	118	79	50	23	8	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.1	10.0	18.9	25.0	31.0	34.1	34.4	33.7	29.9	24.6	17.0	8.4
		MCWB	-0.4	2.9	9.1	12.0	16.2	20.0	23.7	23.9	20.1	16.1	10.3	4.8
	2%	DB	2.7	7.3	15.0	22.1	28.5	31.2	32.3	31.6	28.3	22.3	14.6	5.8
		MCWB	-1.6	1.6	6.7	11.1	15.6	19.4	23.5	22.8	19.2	15.0	9.5	1.9
	5%	DB	0.8	5.1	12.5	20.0	26.6	29.4	30.9	30.3	26.9	20.6	12.7	3.7
		MCWB	-2.5	0.6	5.3	10.3	14.9	18.9	23.0	22.7	18.3	14.1	8.1	0.1
	10%	DB	-0.8	3.2	10.2	18.1	24.9	27.7	29.6	29.2	25.6	19.0	10.6	1.9
		MCWB	-3.8	-0.6	3.9	9.3	14.2	18.5	22.8	22.6	18.0	13.1	6.2	-1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.9	4.1	9.7	14.7	19.4	22.8	27.1	27.0	24.0	19.5	13.2	6.5
		MCDB	3.3	7.7	16.4	20.2	27.1	27.9	31.4	30.4	26.9	22.0	14.8	7.1
	2%	WB	-1.0	2.4	7.8	13.2	17.9	22.0	26.0	25.9	22.2	17.8	10.6	2.6
		MCDB	1.9	5.8	13.7	18.9	25.2	27.1	29.4	28.7	25.3	20.4	13.4	4.9
	5%	WB	-2.3	1.1	6.1	11.9	16.9	21.3	25.2	25.1	21.1	16.1	8.7	0.4
		MCDB	0.8	4.5	11.2	17.2	23.1	25.6	28.3	27.9	24.3	18.8	11.8	3.3
	10%	WB	-3.8	-0.2	4.6	10.7	15.8	20.5	24.5	24.3	20.2	14.6	6.4	-1.4
		MCDB	-0.8	3.0	9.2	16.1	21.4	24.8	27.3	27.2	23.6	17.7	10.2	1.8
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.8	9.2	9.5	9.8	8.0	6.7	7.6	9.6	9.8	8.8	8.4
		MCDBR	10.8	11.2	12.2	12.9	12.9	11.6	9.2	9.3	11.0	11.3	11.2	10.4
		MCWBR	7.8	7.3	6.8	6.0	5.3	4.1	3.5	3.8	4.7	6.2	7.5	7.7
	5% WB	MCDBR	10.5	10.2	11.5	10.2	10.4	8.1	6.7	6.7	8.2	8.7	10.1	9.9
		MCWBR	7.9	7.3	6.8	5.7	5.2	3.6	3.3	3.9	5.2	6.4	8.1	8.2
Clear-Sky Solar Irradiance	taub	0.359	0.432	0.480	0.584	0.630	0.730	0.718	0.625	0.556	0.538	0.435	0.373	
	taud	2.098	1.918	1.857	1.691	1.646	1.525	1.591	1.752	1.832	1.791	1.971	2.089	
	Ebn at Noon	754	740	755	706	687	620	622	668	680	623	650	696	
	Edh at Noon	110	154	183	232	249	281	261	216	186	174	125	103	
All-Sky Solar Radiation	RadAvg	2.38	3.22	4.55	5.31	5.97	5.35	4.96	4.93	4.49	3.37	2.41	2.06	
	RadStd	0.20	0.23	0.28	0.33	0.48	0.49	0.47	0.35	0.26	0.21	0.23	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.84	N/A	N/A	N/A	N/A	N/A	N/A	+55
(47)	Regional (4 neighbors)	N/A	N/A	-1.09	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page