

LINJIANG, China

WMO: 543740

Lat: 41.8021N

Lon: 126.8945E

Elev: 1250

StdP: 14.04

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.5	(c) -10.2	(d) -20.6	(e) 1.9	(f) -11.7	(g) -17.1	(h) 2.3	(i) -8.3	(j) 12.0	(k) 20.8	(l) 9.8	(m) 16.4	(n) 2.0	(o) 0	(p) 0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.5	(c) 88.0	(d) 71.3	(e) 85.3	(f) 70.4	(g) 82.9	(h) 69.6	(i) 75.2	(j) 83.4	(k) 73.7	(l) 80.9	(m) 72.4	(n) 78.8	(o) 4.6	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.8	127.6	78.9	71.6	122.2	77.4	70.3	116.7	76.3	39.7	83.8	38.3	81.0	37.0	79.0	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	9.8	8.0	-18.5	92.7	4.0	2.8	-21.4	94.7	-23.7	96.3	-25.9	97.9	-28.8	100.0
			-18.9	77.4	3.9	2.1	-21.7	78.9	-24.0	80.1	-26.2	81.2	-29.0	82.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.1	6.1	15.3	30.4	46.2	58.2	67.6	73.9	71.9	60.8	46.3	28.1	10.7	
	DBStd	24.48	7.86	9.49	8.83	8.11	6.09	4.85	4.01	4.95	5.99	7.61	9.92	8.88	
	HDD50	5162	1362	972	609	167	9	0	0	0	3	164	657	1219	
	HDD65	8641	1827	1392	1074	566	222	30	1	8	150	581	1106	1684	
	CDD50	2635	0	0	0	52	262	527	740	678	328	48	0	0	
	CDD65	640	0	0	0	1	10	107	276	221	25	0	0	0	
	CDH74	4593	0	0	0	37	290	902	1875	1349	137	3	0	0	
	CDH80	1269	0	0	0	2	52	241	601	362	11	0	0	0	
Wind	WSAvg	2.9	2.0	2.5	3.4	4.0	3.8	3.1	2.7	2.5	2.7	2.9	2.6	2.2	
Precipitation	PrecAvg	33.0	0.4	0.4	0.7	2.0	3.0	4.7	8.0	7.7	3.0	1.4	1.2	0.6	
	PrecMax	48.7	1.1	1.3	1.6	5.2	6.6	8.9	12.5	16.4	6.0	3.2	2.6	1.1	
	PrecMin	25.4	0.1	0.0	0.2	0.3	1.6	1.5	3.0	3.5	0.7	0.2	0.2	0.2	
	PrecStd	5.3	0.3	0.3	0.4	1.1	1.2	1.8	2.8	3.3	1.5	0.8	0.6	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.3	44.1	60.1	79.0	85.4	89.6	93.1	90.8	81.5	72.7	57.5	36.6	
		MCWB	29.1	35.2	45.4	56.0	62.1	65.6	74.2	74.8	67.7	57.2	47.5	31.9	
	2%	DB	27.3	38.7	54.2	72.8	80.7	85.6	88.9	86.6	77.8	67.9	51.1	32.1	
		MCWB	23.8	32.1	41.4	52.6	59.4	66.0	73.1	73.2	65.1	54.6	43.6	29.3	
	5%	DB	22.8	34.8	48.8	68.0	77.1	82.7	85.9	84.1	74.9	63.6	46.4	28.5	
		MCWB	19.9	30.1	38.2	50.0	57.7	65.7	71.9	72.0	63.0	51.9	40.6	25.5	
	10%	DB	18.9	31.6	44.5	63.2	73.2	79.7	83.2	81.4	72.0	59.6	42.3	25.0	
		MCWB	16.4	27.6	36.4	47.6	56.5	64.9	71.3	70.9	61.6	49.9	37.7	22.6	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.4	36.6	46.9	59.1	65.6	71.2	77.7	77.0	70.5	58.9	48.5	32.9	
		MCDB	32.6	42.7	59.8	73.0	80.3	82.1	87.8	86.2	77.8	69.9	55.7	35.6	
	2%	WB	23.8	33.2	42.3	54.1	62.2	69.2	75.8	75.1	67.8	56.0	44.7	29.4	
		MCDB	27.0	37.4	51.7	69.9	74.3	79.8	84.5	83.1	73.9	64.9	49.9	31.9	
	5%	WB	20.0	30.6	39.4	51.3	60.1	67.8	74.2	73.7	65.6	53.6	41.5	25.9	
		MCDB	22.7	34.9	47.5	65.4	72.2	78.0	81.7	81.0	71.9	61.7	45.8	28.3	
	10%	WB	16.5	27.4	36.7	48.7	58.0	66.4	72.8	72.6	63.6	51.0	37.7	22.5	
		MCDB	18.9	31.5	44.0	60.5	69.8	75.3	79.6	78.8	69.6	58.0	41.7	25.0	
Mean Daily Temperature Range			MDBR	20.2	22.5	20.6	23.5	24.1	20.3	16.5	16.7	21.8	23.0	17.5	18.2
	5% DB	MCDBR	21.0	22.4	25.9	32.9	32.3	26.9	21.9	19.9	23.8	28.7	22.1	18.4	
		MCWBR	17.8	16.9	15.3	15.9	13.4	10.2	8.1	8.2	11.3	15.5	15.0	15.8	
		MCDBR	20.5	20.7	24.0	29.1	26.5	20.8	16.9	16.4	18.5	24.8	20.1	17.7	
	5% WB	MCWBR	17.7	16.2	15.0	14.7	12.2	8.9	7.1	7.5	9.9	14.4	14.3	15.6	
Clear-Sky Solar Irradiance	taub		0.356	0.420	0.496	0.569	0.611	0.639	0.585	0.518	0.461	0.480	0.423	0.368	
	taud		1.985	1.841	1.757	1.695	1.656	1.667	1.847	2.014	2.082	1.917	1.955	1.987	
	Ebn at Noon		234	235	233	227	222	216	226	239	243	214	207	216	
	Edh at Noon		38	52	64	73	78	77	64	52	46	48	40	35	
All-Sky Solar Radiation	RadAvg		765	1054	1376	1503	1689	1637	1472	1461	1362	1020	671	610	
	RadStd		46	54	71	105	148	168	152	142	128	82	82	44	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page