

LINJIANG, China

WMO: 543740

Lat: 41.8021N

Lon: 126.8945E

Elev: 381

StdP: 96.83

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.3	-23.5	-29.2	0.3	-24.3	-27.3	0.3	-22.4	5.3	-6.2	4.4	-8.7	0.9	0	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	31.1	21.8	29.6	21.3	28.3	20.9	24.0	28.6	23.2	27.2	22.4	26.0	2.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	18.2	26.1	22.0	17.5	25.2	21.3	16.7	24.6	74.5	28.8	71.2	27.2	68.2	26.1	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.3	4.4	3.6	-28.1	33.7	2.2	1.6	-29.6	34.8	-30.9	35.7	-32.2	36.6	-33.8	37.8
			-28.3	25.2	2.2	1.1	-29.8	26.0	-31.1	26.7	-32.3	27.3	-33.9	28.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	-14.4	-9.3	-0.9	7.9	14.5	19.8	23.3	22.1	16.0	7.9	-2.2	-11.9
	DBStd	13.60	4.37	5.27	4.90	4.51	3.38	2.69	2.23	2.75	3.33	4.23	5.51	4.93
	HDD10.0	2868	757	540	338	93	5	0	0	0	2	91	365	677
	HDD18.3	4801	1015	773	597	314	123	17	1	4	83	323	614	936
	CDD10.0	1464	0	0	0	29	146	293	411	377	182	27	0	0
	CDD18.3	356	0	0	0	1	6	59	153	123	14	0	0	0
	CDH23.3	2552	0	0	0	21	161	501	1042	749	76	2	0	0
	CDH26.7	705	0	0	0	1	29	134	334	201	6	0	0	0
Wind	WSAvg	1.3	0.9	1.1	1.5	1.8	1.7	1.4	1.2	1.1	1.2	1.3	1.2	1.0
Precipitation	PrecAvg	837	10	11	17	51	75	120	203	195	76	36	30	15
	PrecMax	1238	27	33	40	132	168	226	318	416	152	82	66	28
	PrecMin	644	2	1	4	8	40	37	77	89	18	5	6	4
	PrecStd	135	7	8	10	28	31	46	72	85	37	21	16	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.7	6.7	15.6	26.1	29.7	32.0	33.9	32.6	27.5	22.6	14.2	2.6
		MCWB	-1.6	1.8	7.4	13.3	16.7	18.7	23.5	23.8	19.8	14.0	8.6	-0.1
	2%	DB	-2.6	3.7	12.3	22.7	27.1	29.8	31.6	30.3	25.4	19.9	10.6	0.1
		MCWB	-4.6	0.0	5.2	11.5	15.2	18.9	22.8	22.9	18.4	12.6	6.4	-1.5
	5%	DB	-5.1	1.6	9.3	20.0	25.1	28.1	30.0	28.9	23.8	17.6	8.0	-1.9
		MCWB	-6.7	-1.1	3.5	10.0	14.3	18.7	22.2	22.2	17.2	11.0	4.8	-3.6
	10%	DB	-7.3	-0.2	7.0	17.3	22.9	26.5	28.5	27.5	22.2	15.4	5.7	-3.9
		MCWB	-8.7	-2.4	2.4	8.7	13.6	18.3	21.9	21.6	16.5	9.9	3.1	-5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.4	2.6	8.3	15.1	18.6	21.8	25.4	25.0	21.4	15.0	9.2	0.5
		MCDB	0.3	5.9	15.4	22.8	26.8	27.8	31.0	30.1	25.5	21.1	13.1	2.0
	2%	WB	-4.5	0.7	5.7	12.3	16.8	20.7	24.3	23.9	19.9	13.3	7.1	-1.5
		MCDB	-2.8	3.0	10.9	21.0	23.5	26.6	29.1	28.4	23.3	18.3	10.0	-0.1
	5%	WB	-6.7	-0.8	4.1	10.7	15.6	19.9	23.5	23.2	18.7	12.0	5.3	-3.4
		MCDB	-5.1	1.6	8.6	18.5	22.4	25.6	27.6	27.2	22.1	16.5	7.7	-2.0
	10%	WB	-8.6	-2.6	2.6	9.3	14.4	19.1	22.7	22.5	17.5	10.5	3.2	-5.3
		MCDB	-7.3	-0.3	6.7	15.8	21.0	24.1	26.4	26.0	20.9	14.5	5.4	-3.9
Mean Daily Temperature Range	5% DB	MDBR	11.2	12.5	11.4	13.1	13.4	11.3	9.1	9.3	12.1	12.8	9.7	10.1
		MCDBR	11.7	12.4	14.4	18.3	18.0	14.9	12.2	11.1	13.2	15.9	12.3	10.2
		MCWBR	9.9	9.4	8.5	8.8	7.5	5.7	4.5	4.6	6.3	8.6	8.3	8.8
	5% WB	MCDBR	11.4	11.5	13.3	16.2	14.7	11.5	9.4	9.1	10.3	13.8	11.1	9.8
	MCWBR	9.8	9.0	8.3	8.2	6.8	4.9	4.0	4.1	5.5	8.0	7.9	8.7	
Clear-Sky Solar Irradiance	taub	0.356	0.420	0.496	0.569	0.611	0.639	0.585	0.518	0.461	0.480	0.423	0.368	
	taud	1.985	1.841	1.757	1.695	1.656	1.667	1.847	2.014	2.082	1.917	1.955	1.987	
	Ebn at Noon	739	742	734	716	699	680	714	752	766	676	653	681	
	Edh at Noon	120	164	201	230	245	243	201	165	144	151	125	111	
All-Sky Solar Radiation	RadAvg	2.41	3.32	4.34	4.74	5.33	5.16	4.64	4.61	4.29	3.22	2.12	1.92	
	RadStd	0.15	0.17	0.22	0.33	0.47	0.53	0.48	0.45	0.40	0.26	0.26	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page