

BEIJING, China

WMO: 545110

Lat: 39.8060N

Lon: 116.4693E

Elev: 107

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	14.3	-18.4	2.0	23.7	-14.5	2.5	25.3	27.9	25.7	24.9	25.1	6.3	0	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	95.3	71.7	93.0	72.0	90.0	72.2	80.9	87.3	79.1	85.5	77.8	84.2	8.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.5	84.7	77.3	142.5	83.0	75.6	134.4	81.6	45.0	87.0	43.0	85.4	41.4	83.8	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.7	18.7	15.4	6.0	101.5	4.3	3.4	2.9	103.9	0.3	105.9	-2.1	107.8	-5.2	110.2	
			3.8	83.9	3.8	1.8	1.0	85.3	-1.2	86.3	-3.3	87.3	-6.0	88.7	
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.4	26.3	32.2	44.4	58.2	69.4	77.1	80.8	78.7	69.7	56.4	40.9	29.4	(6)
(7)		DBStd	20.13	5.77	6.30	7.23	6.38	5.60	4.92	4.14	3.86	5.28	6.16	7.09	5.47	(7)
(8)		HDD50	2383	736	498	203	9	0	0	0	0	16	283	638		(8)
(9)		HDD65	5115	1201	918	638	216	22	1	0	19	273	724	1103		(9)
(10)		CDD50	4355	0	0	30	257	601	813	954	888	590	214	8	0	(10)
(11)		CDD65	1613	0	0	0	14	157	364	489	424	159	6	0	0	(11)
(12)		CDH74	16332	0	0	7	234	1744	3719	5297	4051	1215	65	0	0	(12)
(13)		CDH80	6608	0	0	1	46	612	1682	2362	1564	333	8	0	0	(13)
(14)	Wind	WSAvg	6.0	6.6	6.4	7.2	7.3	6.8	5.6	5.0	4.7	4.9	5.2	5.7	6.4	(14)
(15)	Precipitation	PrecAvg	21.4	0.1	0.2	0.4	0.9	1.5	3.1	6.9	4.4	2.2	1.1	0.5	0.1	(15)
(16)		PrecMax	32.6	0.5	0.9	1.7	3.1	3.5	8.9	17.6	10.0	4.5	2.6	3.0	0.4	(16)
(17)		PrecMin	11.4	0.0	0.0	0.0	0.1	0.2	0.7	1.9	1.8	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	5.4	0.2	0.3	0.5	0.8	0.7	1.7	3.7	2.2	1.3	0.8	0.7	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	57.2	73.7	84.8	94.6	98.9	100.3	95.3	89.9	80.4	66.3	51.1	(19)
(20)		MCWB	35.0	40.3	51.0	59.0	65.3	68.1	72.9	74.0	69.5	59.5	48.6	36.9		(20)
(21)		2%	DB	43.1	52.0	68.2	80.2	89.8	95.0	96.3	91.8	86.7	75.2	61.0	46.4	(21)
(22)		MCWB	31.8	37.5	49.2	57.7	63.6	68.8	73.7	74.3	68.1	58.7	46.5	34.3		(22)
(23)		5%	DB	39.9	48.3	63.3	76.1	86.2	91.8	93.1	89.8	84.0	71.5	57.1	42.9	(23)
(24)		MCWB	29.8	35.6	46.0	56.3	62.9	69.0	74.9	74.3	67.4	56.1	44.7	32.8		(24)
(25)		10%	DB	37.1	44.7	58.8	72.4	82.8	89.2	90.0	87.8	80.8	68.1	53.5	39.5	(25)
(26)		MCWB	28.0	33.9	43.5	54.1	61.6	68.7	75.3	74.5	66.2	54.9	43.0	30.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.2	42.0	54.8	65.9	72.1	77.5	83.3	83.7	77.4	66.5	52.2	38.7	(27)
(28)		MADB	46.6	50.2	69.4	78.0	85.0	87.6	89.8	87.6	84.4	73.6	60.4	45.4		(28)
(29)		2%	WB	32.4	39.5	50.7	61.8	69.4	75.4	81.3	80.8	73.9	63.5	49.3	35.7	(29)
(30)		MADB	41.4	49.1	64.8	73.2	82.3	85.2	88.0	86.6	79.9	69.2	56.3	44.3		(30)
(31)		5%	WB	30.4	36.9	47.4	59.5	67.3	73.7	79.8	79.1	71.5	60.8	47.0	33.6	(31)
(32)		MADB	38.4	47.0	60.1	70.7	79.6	83.2	86.5	84.8	78.3	66.6	54.0	41.1		(32)
(33)		10%	WB	28.6	34.5	44.6	56.9	65.3	72.3	78.5	77.7	69.4	58.5	44.6	31.7	(33)
(34)		MADB	35.7	43.9	56.5	67.7	76.8	81.9	85.1	83.6	76.5	64.3	51.9	38.3		(34)
(35)	Mean Daily Temperature Range	MDBR	18.3	20.1	21.6	22.5	22.9	19.9	16.4	16.8	19.6	20.2	18.6	17.5		(35)
(36)		5% DB	MADB	22.7	25.7	29.5	29.2	29.5	26.2	21.8	20.1	23.6	24.7	24.1	22.7	(36)
(37)		MCWBR	14.5	15.5	15.1	13.1	11.1	8.9	8.0	8.4	9.4	11.5	13.2	13.8		(37)
(38)		5% WB	MADB	21.3	23.5	26.7	23.8	22.7	18.7	15.9	15.2	17.7	18.1	21.0	20.3	(38)
(39)		MCWBR	13.9	14.8	14.5	12.9	11.3	8.8	8.5	8.7	9.4	10.5	12.7	12.8		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.430	0.514	0.535	0.604	0.652	0.797	0.795	0.756	0.676	0.618	0.485	0.441		(40)
(41)		taud	1.954	1.789	1.779	1.688	1.622	1.438	1.478	1.528	1.615	1.671	1.898	1.981		(41)
(42)		Ebn at Noon	215	212	226	221	214	184	183	185	188	179	194	200		(42)
(43)		Edh at Noon	42	57	64	74	81	98	93	86	75	63	44	38		(43)
(44)	All-Sky Solar Radiation	RadAvg	773	1011	1434	1713	1904	1686	1531	1506	1332	1038	790	692		(44)
(45)		RadStd	62	104	125	95	136	163	105	82	95	104	108	68		(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) -0.68	(i) -1.15	(j) N/A	(k) N/A	(l) N/A	(m) +106	(46)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page