

BAODING, China

WMO: 546020

Lat: 38.7373N

Lon: 115.4776E

Elev: 59

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.6	16.0	-12.6	2.8	27.8	-8.5	3.5	28.6	15.2	34.3	12.8	31.3	2.8	220	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.5	95.8	73.1	93.0	73.6	90.7	73.7	81.5	88.5	79.7	86.8	78.2	85.1	6.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	153.8	86.0	77.7	144.4	84.4	76.1	136.8	83.1	45.4	88.4	43.5	87.0	41.9	85.2	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.1	10.2	8.0	100.4	4.5	2.9	4.8	102.5	2.1	104.2	-0.4	105.8	-3.7	107.9
			6.1	83.4	4.0	1.9	3.2	84.7	0.9	85.8	-1.4	86.9	-4.3	88.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.7	27.5	34.3	46.8	59.6	70.0	78.4	81.7	78.9	70.4	58.0	42.7	31.1	(6)
	DBStd	19.77	5.71	6.42	7.34	6.69	5.70	5.22	4.57	4.13	5.42	6.29	7.36	5.44	(7)
	HDD50	2129	697	439	152	8	0	0	0	0	0	10	238	585	(8)
	HDD65	4755	1162	859	565	185	20	1	0	0	16	228	669	1050	(9)
	CDD50	4585	0	0	52	296	619	851	982	896	613	258	18	0	(10)
	CDD65	1738	0	0	1	23	174	401	517	432	179	11	0	0	(11)
	CDH74	17537	0	0	16	237	1603	4311	5906	4151	1239	74	0	0	(12)
	CDH80	7131	0	0	3	41	524	2002	2703	1534	316	8	0	0	(13)
(14) Wind	WSAvg	4.5	3.9	4.3	5.4	5.8	5.6	5.0	4.4	4.0	3.9	3.9	3.9	3.7	(14)
(15) Precipitation	PrecAvg	19.7	0.1	0.2	0.4	0.9	1.4	2.8	6.1	4.3	2.0	0.9	0.6	0.1	(15)
	PrecMax	30.9	0.7	1.2	1.7	2.4	3.4	5.6	15.0	11.1	4.3	3.6	2.1	0.4	(16)
	PrecMin	11.4	0.0	0.0	0.0	0.1	0.1	0.7	2.3	1.6	0.3	0.1	0.0	0.0	(17)
	PrecStd	5.0	0.2	0.3	0.5	0.6	0.7	1.4	2.9	2.2	1.1	0.7	0.6	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	57.8	75.8	84.5	92.8	99.4	100.5	94.1	89.5	80.8	66.8	51.1	(19)
		MCWB	35.2	41.2	52.6	62.0	66.3	69.2	72.9	78.8	72.4	62.0	49.8	37.5	(20)
	2%	DB	43.1	53.2	69.5	80.0	88.9	95.9	96.3	91.4	86.3	76.0	61.6	46.2	(21)
		MCWB	32.2	39.3	51.0	60.0	65.6	69.6	75.6	77.0	70.1	58.9	48.7	35.6	(22)
	5%	DB	39.9	49.2	64.6	76.3	85.9	93.2	93.5	89.4	83.8	72.2	57.2	42.7	(23)
		MCWB	30.5	37.5	47.8	58.5	65.0	70.1	76.1	76.4	68.9	57.8	46.4	33.6	(24)
	10%	DB	36.9	45.8	59.9	72.6	82.7	90.2	91.0	87.4	81.0	68.8	53.9	39.7	(25)
		MCWB	29.2	35.7	45.3	56.7	63.9	69.5	76.2	75.7	67.6	56.8	45.1	32.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.3	44.1	56.9	67.6	73.0	77.3	83.7	83.3	77.5	67.1	53.3	39.6	(27)
		MCDB	45.5	52.9	71.2	77.5	84.6	88.9	91.2	89.6	83.9	73.9	59.6	46.8	(28)
	2%	WB	33.2	41.0	52.9	63.7	70.5	75.4	82.0	81.3	74.6	63.8	50.7	36.9	(29)
		MCDB	41.1	50.6	65.5	74.5	82.5	87.5	89.5	87.7	81.8	69.8	58.4	44.0	(30)
	5%	WB	31.4	38.6	49.6	61.3	68.6	73.9	80.4	79.6	72.3	61.6	48.5	34.9	(31)
		MCDB	38.2	47.7	62.0	72.3	80.6	85.1	88.0	85.9	79.8	67.9	55.3	41.1	(32)
	10%	WB	29.8	36.4	46.7	58.9	66.6	72.4	78.9	78.1	70.2	59.4	46.3	33.1	(33)
		MCDB	35.9	44.9	58.1	69.7	78.0	83.5	86.4	84.1	77.7	65.5	52.3	38.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	16.7	18.6	19.4	19.7	18.6	14.5	14.1	16.8	17.1	15.3	14.4	(35)
		MCDBR	20.0	22.0	25.6	25.7	25.4	24.2	19.2	16.7	20.2	21.8	20.4	19.4	(36)
	5% WB	MCWBR	12.5	12.7	12.4	11.5	9.8	7.2	6.0	6.5	7.9	9.9	11.1	11.7	(37)
		MCWBR	17.2	19.6	24.3	21.2	20.9	17.6	15.0	13.7	15.9	16.7	18.1	16.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.471	0.550	0.557	0.613	0.657	0.802	0.798	0.771	0.695	0.644	0.521	0.471	(40)
		taud	1.855	1.715	1.723	1.657	1.607	1.421	1.466	1.493	1.574	1.618	1.806	1.898	(41)
	Ebn at Noon		203	204	221	220	213	184	183	183	185	175	185	192	(42)
		Edh at Noon	48	62	68	77	82	100	95	90	78	68	49	43	(43)
(44) All-Sky Solar Radiation	RadAvg		765	972	1413	1696	1866	1674	1496	1452	1290	1017	785	690	(44)
	RadStd		66	120	130	102	144	155	97	99	107	115	121	80	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page