

CANGZHOU, China

WMO: 546160

Lat: 38.333N

Lon: 116.833E

Elev: 36

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.1	18.1	-13.7	2.6	28.0	-8.2	3.6	28.3	20.7	30.6	18.1	29.8	3.8	340	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	93.6	73.7	91.4	74.3	89.4	74.1	81.3	87.9	79.8	86.1	78.3	84.4	7.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	153.5	85.6	78.1	146.0	84.0	76.6	138.7	82.4	45.3	88.2	43.6	86.2	42.1	84.5	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	16.3	13.9	10.0	99.1	4.8	2.6	6.5	101.0	3.6	102.5	0.9	104.0	-2.6	105.9
			7.8	83.7	3.8	1.9	5.1	85.1	2.9	86.2	0.7	87.3	-2.0	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.5	28.6	34.3	44.1	58.9	68.5	77.4	80.3	79.0	71.1	59.1	43.4	32.1	(6)
	DBStd	19.36	5.19	5.88	7.00	7.01	6.75	5.01	4.02	3.65	4.95	6.90	8.28	5.38	(7)
	HDD50	2115	663	441	208	10	0	0	0	0	0	10	228	555	(8)
	HDD65	4769	1128	860	647	206	43	1	0	0	10	205	649	1020	(9)
	CDD50	4492	0	1	27	278	574	821	938	899	632	293	29	0	(10)
	CDD65	1668	0	0	0	23	152	372	473	434	192	22	0	0	(11)
	CDH74	15816	0	0	3	198	1425	3750	4914	4144	1252	130	0	0	(12)
	CDH80	5927	0	0	0	32	489	1638	1993	1480	279	16	0	0	(13)
(14) Wind	WSAvg	6.2	4.8	5.8	7.2	8.3	7.8	6.9	6.2	5.1	5.8	5.8	5.6	4.7	(14)
(15) Precipitation	PrecAvg	24.1	0.1	0.2	0.3	0.9	1.4	2.8	8.6	6.4	1.9	0.9	0.5	0.2	(15)
	PrecMax	45.7	0.9	0.9	1.8	6.5	4.6	6.1	17.8	16.2	5.9	2.8	1.3	1.0	(16)
	PrecMin	9.7	0.0	0.0	0.0	0.0	0.1	0.3	1.7	0.4	0.1	0.1	0.0	0.0	(17)
	PrecStd	7.9	0.2	0.2	0.4	1.2	1.2	1.6	3.9	4.0	1.4	0.7	0.4	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.0	60.0	70.0	84.0	93.3	98.4	96.3	92.8	88.8	82.4	67.8	51.3	(19)
		MCWB	35.8	43.5	51.7	61.9	66.6	69.6	74.6	78.8	72.5	64.7	52.7	42.1	(20)
	2%	DB	42.9	52.2	64.6	79.2	88.9	94.0	93.5	90.7	85.6	77.6	63.8	46.4	(21)
		MCWB	33.2	39.9	48.4	59.1	66.4	70.4	77.1	76.9	70.0	62.1	49.7	37.6	(22)
	5%	DB	40.0	47.9	60.3	75.5	85.3	91.4	91.4	89.1	83.2	73.9	59.4	43.2	(23)
		MCWB	31.3	37.0	46.6	58.0	65.2	70.4	77.6	75.7	68.5	59.3	48.0	35.6	(24)
	10%	DB	37.1	44.3	56.7	71.9	82.0	88.7	89.0	87.4	80.9	70.6	55.1	40.5	(25)
		MCWB	29.8	34.7	44.3	55.5	64.0	69.8	77.2	75.1	67.1	57.8	45.9	34.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.8	45.0	54.6	66.0	73.0	78.3	84.5	81.9	77.3	66.7	54.5	42.5	(27)
		MCDB	45.6	57.5	65.2	78.0	84.2	87.3	91.6	89.5	83.0	77.9	63.0	50.7	(28)
	2%	WB	34.7	40.5	50.8	62.1	70.0	76.2	82.3	80.2	75.1	64.3	52.1	39.4	(29)
		MCDB	40.8	51.2	61.5	76.0	83.1	86.9	88.7	87.2	80.8	73.7	59.5	44.3	(30)
	5%	WB	32.3	38.0	47.7	60.0	68.0	73.8	80.9	79.0	72.3	62.1	49.9	37.1	(31)
		MCDB	37.2	45.6	58.5	72.3	80.7	84.2	87.1	85.1	79.2	70.3	56.9	41.3	(32)
	10%	WB	30.8	35.9	45.2	57.8	66.1	72.2	79.4	77.9	70.3	59.8	47.4	35.0	(33)
		MCDB	35.8	42.2	55.1	68.7	77.4	82.6	85.4	83.8	77.6	67.8	54.3	39.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	16.3	16.8	19.3	19.5	18.6	14.2	13.9	16.8	17.4	15.7	13.5	(35)
		MCDBR	18.5	22.0	22.6	23.3	25.0	23.2	17.7	16.1	19.1	20.5	21.3	17.8	(36)
		MCWBR	11.4	13.3	12.1	10.5	9.9	8.1	6.7	5.6	7.4	9.0	11.3	11.2	(37)
	5% WB	MCDBR	15.5	19.5	20.5	22.0	21.0	19.1	14.0	12.7	15.4	17.6	18.1	15.5	(38)
		MCWBR	10.6	12.3	11.6	11.6	10.7	8.7	7.5	5.7	7.4	8.8	11.3	10.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.492	0.565	0.581	0.631	0.672	0.809	0.798	0.758	0.684	0.663	0.555	0.500	(40)
	taud		1.793	1.680	1.664	1.609	1.573	1.397	1.458	1.510	1.585	1.579	1.730	1.821	(41)
	Ebn at Noon		197	200	216	215	210	183	183	186	188	172	176	183	(42)
	Edh at Noon		51	65	73	81	86	102	95	89	78	71	54	47	(43)
(44) All-Sky Solar Radiation	RadAvg		745	960	1409	1681	1877	1698	1520	1454	1307	1012	771	674	(44)
	RadStd		81	125	125	95	134	152	104	108	114	103	114	82	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page