

ZHOU SHUIZI, China

WMO: 546620

Lat: 38.908N

Lon: 121.660E

Elev: 97

StdP: 100.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.2	-10.4	-22.1	0.5	-7.8	-20.0	0.6	-6.6	10.9	-6.2	10.0	-5.5	4.0	0	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.7	31.9	23.6	30.2	23.2	29.1	22.8	26.3	29.1	25.7	28.2	25.0	27.3	3.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.4	28.2	25.0	20.3	27.3	24.1	19.2	26.5	83.4	29.4	79.9	28.6	76.8	27.1	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.7	7.7	-14.4	34.5	2.4	1.7	-16.1	35.7	-17.5	36.6	-18.8	37.6	-20.5	38.8		
			-15.3	27.8	2.2	1.1	-16.9	28.6	-18.3	29.2	-19.5	29.8	-21.1	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	-4.0	-1.2	4.5	11.4	17.6	21.9	25.1	25.4	21.2	14.0	5.7	-1.1	(6)
(7)		DBStd	10.84	3.93	3.95	3.94	3.40	3.21	2.63	2.23	2.05	2.64	3.74	4.61	4.03	(7)
(8)		HDD10.0	1441	433	314	174	23	0	0	0	0	11	142	344		(8)
(9)		HDD18.3	3060	691	548	428	209	53	3	0	7	139	379	602		(9)
(10)		CDD10.0	2094	0	0	4	65	235	358	468	479	336	136	13	0	(10)
(11)		CDD18.3	671	0	0	0	1	30	111	210	221	92	6	0	0	(11)
(12)		CDH23.3	4355	0	0	0	7	174	608	1475	1673	404	14	0	0	(12)
(13)		CDH26.7	1102	0	0	0	1	30	161	415	438	57	1	0	0	(13)
(14)	Wind	WSAvg	3.6	3.6	3.7	4.0	4.2	3.9	3.4	3.2	3.0	3.1	3.3	3.7	3.6	(14)
(15)	Precipitation	PrecAvg	633	9	7	13	33	43	85	173	147	59	28	20	10	(15)
(16)		PrecMax	942	39	29	68	88	133	244	388	368	151	79	49	60	(16)
(17)		PrecMin	341	0	0	1	4	7	16	14	11	5	2	2	0	(17)
(18)		PrecStd	169	11	8	14	26	31	65	92	94	39	19	15	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	10.2	18.1	24.0	29.8	33.1	34.1	33.2	30.0	25.1	18.8	11.1	(19)
(20)		0.4%	MCWB	3.0	4.5	9.2	12.4	16.7	20.1	25.0	25.6	21.4	18.2	12.7	8.2	(20)
(21)		2%	DB	5.6	8.0	14.8	21.0	27.0	30.1	32.0	31.2	28.1	22.9	16.3	9.1	(21)
(22)		2%	MCWB	2.6	3.2	7.6	11.9	15.6	19.6	24.4	24.6	20.8	17.0	12.2	6.4	(22)
(23)		5%	DB	4.1	6.2	12.1	19.0	25.1	28.2	30.2	30.1	26.9	21.1	14.9	7.8	(23)
(24)		5%	MCWB	1.4	2.6	5.9	10.8	14.9	19.1	24.0	24.1	20.2	16.0	11.3	5.0	(24)
(25)		10%	DB	2.7	4.9	10.2	17.1	23.4	26.8	29.0	29.0	25.8	19.9	13.3	6.0	(25)
(26)		10%	MCWB	0.2	2.0	4.9	9.9	14.4	19.0	23.8	23.9	19.9	15.3	10.2	3.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	6.1	10.5	15.4	19.6	23.2	27.3	27.7	24.7	20.1	15.2	9.5	(27)
(28)		0.4%	MCDWB	5.9	8.1	16.2	20.6	25.8	27.5	31.2	30.5	27.0	22.0	16.5	10.3	(28)
(29)		2%	WB	3.0	4.6	8.5	13.5	17.9	22.2	26.3	26.6	23.4	18.9	13.3	7.0	(29)
(30)		2%	MCDWB	5.0	6.5	12.4	18.2	23.2	25.9	29.5	29.2	25.7	21.2	15.1	8.6	(30)
(31)		5%	WB	1.6	3.5	7.1	12.3	16.9	21.3	25.7	25.9	22.4	17.7	12.0	5.1	(31)
(32)		5%	MCDWB	3.7	5.4	10.6	16.5	21.9	24.8	28.5	28.2	24.9	20.1	14.4	7.0	(32)
(33)		10%	WB	0.2	2.2	5.8	11.1	16.0	20.7	24.9	25.3	21.5	16.5	10.5	3.4	(33)
(34)		10%	MCDWB	2.2	4.4	9.2	15.1	20.4	24.0	27.4	27.5	24.1	19.0	13.0	5.5	(34)
(35)	Mean Daily Temperature Range	MDBR	7.8	8.1	8.4	8.8	9.1	8.1	6.7	6.7	8.1	8.8	8.6	8.1	(35)	
(36)		5% DB	MCDBR	10.0	10.0	11.0	11.5	11.4	10.7	8.7	7.9	9.3	10.0	10.8	10.4	(36)
(37)		5% DB	MCWBR	8.0	7.1	6.6	6.3	5.7	4.9	4.2	3.9	4.9	6.1	7.9	8.3	(37)
(38)		5% WB	MCDWR	9.5	9.0	9.9	10.1	9.6	8.1	7.2	6.5	7.8	9.0	9.9	9.7	(38)
(39)		5% WB	MCWBR	8.1	7.2	6.7	6.4	5.9	4.3	3.9	3.8	5.1	6.6	8.4	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.432	0.494	0.540	0.607	0.637	0.722	0.708	0.626	0.558	0.574	0.516	0.447	(40)	
(41)		taud	1.944	1.820	1.763	1.679	1.670	1.575	1.644	1.802	1.877	1.747	1.834	1.927	(41)	
(42)		Ebn at Noon	685	694	713	696	687	630	634	675	692	610	589	629	(42)	
(43)		Edh at Noon	136	176	206	238	244	269	249	208	182	187	152	129	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.34	3.14	4.50	5.27	5.88	5.38	4.83	4.75	4.43	3.32	2.33	1.96	(44)	
(45)		RadStd	0.19	0.26	0.33	0.28	0.46	0.48	0.45	0.46	0.33	0.25	0.25	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	-0.87	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page