

DEZHOU, China

WMO: 547140

Lat: 37.433N

Lon: 116.317E

Elev: 22

StdP: 101.06

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.3	(c) -6.8	(d) -22.2	(e) 0.5	(f) -2.3	(g) -19.6	(h) 0.7	(i) -0.5	(j) 7.2	(k) -0.3	(l) 6.4	(m) 0.5	(n) 1.5	(o) 220	(p) 0.419

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.6	(c) 34.2	(d) 24.3	(e) 32.9	(f) 24.3	(g) 31.9	(h) 24.0	(i) 27.8	(j) 31.5	(k) 26.9	(l) 30.5	(m) 26.1	(n) 29.5	(o) 3.3	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.4	30.3	25.9	21.3	29.6	25.0	20.2	28.7	89.6	31.4	85.2	30.6	81.5	29.7	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.4	(b) 6.4	(c) 5.5	(e) -10.8	(f) 36.9	(g) 1.4	(h) 1.0	(i) -11.8	(j) 37.7	(k) -12.7	(l) 38.3	(m) -13.5	(n) 38.9	(o) -14.5	(p) 39.6		
(a) 7.4	(b) 6.4	(c) 5.5	(e) -12.2	(f) 29.0	(g) 1.4	(h) 1.1	(i) -13.2	(j) 29.8	(k) -14.1	(l) 30.4	(m) -14.8	(n) 31.1	(o) -15.9	(p) 31.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	-1.0	2.0	7.2	15.7	20.7	25.5	27.1	26.1	22.1	15.4	7.2	0.9	(6)
(7)		DBStd	10.53	2.82	3.20	4.06	3.72	3.51	2.67	2.17	2.03	2.52	3.59	4.74	3.12	(7)
(8)		HDD10.0	1068	341	224	106	4	0	0	0	0	0	2	107	283	(8)
(9)		HDD18.3	2496	599	457	346	94	19	1	0	0	2	103	334	542	(9)
(10)		CDD10.0	2579	0	1	18	176	330	466	531	501	363	171	23	0	(10)
(11)		CDD18.3	966	0	0	0	16	91	216	273	242	116	13	0	0	(11)
(12)		CDH23.3	9110	0	0	1	104	757	2208	2912	2298	744	86	0	0	(12)
(13)	CDH26.7	3354	0	0	0	10	223	935	1187	822	166	11	0	0	(13)	
(14)	Wind	WSAvg	2.4	1.9	2.1	2.8	3.3	3.0	2.6	2.4	2.0	2.2	2.3	2.3	2.1	(14)
(15)	Precipitation	PrecAvg	571	4	6	10	29	32	63	194	141	49	28	13	4	(15)
(16)		PrecMax	1058	18	39	32	136	103	176	467	329	134	118	46	16	(16)
(17)		PrecMin	257	0	0	0	0	7	14	31	7	3	0	0	0	(17)
(18)		PrecStd	190	5	9	9	27	22	44	100	82	34	27	12	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	16.7	20.9	28.0	33.4	36.8	35.9	33.7	31.1	28.2	20.7	12.8	(19)
(20)			MCWB	2.7	8.6	11.3	17.3	22.2	20.6	23.9	26.9	23.6	18.5	11.3	6.9	(20)
(21)		2%	DB	7.0	11.8	18.6	26.3	31.0	34.3	34.3	32.5	29.7	25.7	18.4	9.6	(21)
(22)			MCWB	1.6	5.2	10.1	16.5	19.6	21.4	25.8	25.7	22.0	16.3	10.5	4.4	(22)
(23)		5%	DB	5.5	9.2	16.2	24.2	29.1	32.8	33.1	31.7	28.6	23.9	16.1	7.5	(23)
(24)			MCWB	0.7	3.3	8.7	15.1	19.3	21.8	25.8	24.9	21.1	15.5	10.2	3.1	(24)
(25)		10%	DB	3.8	7.2	14.0	22.4	27.6	31.4	31.9	30.7	27.4	22.0	13.6	5.8	(25)
(26)			MCWB	-0.2	2.1	7.3	14.0	18.4	21.3	25.6	24.5	20.0	14.5	8.8	2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	9.3	13.0	19.6	23.0	26.1	29.2	28.2	26.0	19.5	13.4	7.1	(27)
(28)			MCD B	7.9	16.0	19.5	25.6	30.7	29.8	33.1	31.8	29.6	26.1	17.1	12.0	(28)
(29)		2%	WB	2.5	5.6	11.0	17.9	21.7	24.6	28.5	27.5	24.3	17.9	12.0	5.2	(29)
(30)			MCD B	5.9	10.9	16.6	24.0	28.4	29.5	32.1	31.2	27.6	24.1	16.4	8.5	(30)
(31)		5%	WB	1.2	4.1	9.4	16.6	20.7	23.7	27.4	26.6	22.9	16.5	10.7	4.0	(31)
(32)			MCD B	4.2	7.9	15.0	22.5	26.7	29.3	30.9	30.2	27.0	21.8	14.4	6.4	(32)
(33)		10%	WB	0.3	2.9	8.2	15.1	19.6	22.8	26.6	25.7	21.8	15.3	9.4	2.7	(33)
(34)			MCD B	3.0	6.2	13.2	20.7	25.4	28.4	30.0	29.2	25.7	20.2	13.0	5.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	8.7	9.0	10.1	10.3	9.9	7.6	7.6	9.1	10.0	8.6	7.3	(35)
(36)			MCD BR	10.3	12.0	12.0	11.9	12.6	11.8	9.5	8.6	10.0	12.0	11.8	10.3	(36)
(37)			MCWBR	6.3	7.1	6.4	5.7	5.2	4.0	3.6	3.3	4.2	5.0	5.9	6.3	(37)
(38)		5% WB	MCD BR	8.7	10.7	10.7	10.9	10.6	9.6	7.8	7.3	8.3	10.0	9.4	8.7	(38)
(39)			MCWBR	5.9	6.7	6.5	6.3	5.5	4.7	4.1	3.5	4.2	4.9	5.9	5.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.521	0.593	0.603	0.638	0.671	0.813	0.791	0.766	0.697	0.682	0.582	0.524	(40)	
(41)		taud	1.742	1.634	1.630	1.596	1.580	1.391	1.473	1.500	1.570	1.554	1.680	1.771	(41)	
(42)		Ebn at Noon	601	613	667	677	666	576	584	583	589	534	539	562	(42)	
(43)		Edh at Noon	172	217	238	260	269	325	297	283	250	233	183	158	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.20	2.82	4.24	5.10	5.75	5.29	4.70	4.47	3.97	3.12	2.33	2.04	(44)	
(45)		RadStd	0.27	0.44	0.37	0.33	0.43	0.42	0.32	0.44	0.41	0.31	0.37	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page