

LINGXIAN, China

WMO: 547150

Lat: 37.3214N

Lon: 116.5628E

Elev: 62

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	16.5	-7.5	3.7	26.7	-3.5	4.6	25.9	18.8	38.9	16.4	36.0	2.8	110	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	95.1	74.6	92.7	75.2	90.3	75.2	82.4	88.7	80.9	87.2	79.4	85.3	8.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.8	160.4	86.5	79.1	151.6	85.0	77.7	144.2	83.6	46.5	88.7	44.8	87.5	43.2	85.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.3	15.7	13.6	DB	6.2	99.9	5.4	3.0	2.3	102.0	-0.8	103.8	-3.8	105.4	-7.7	107.6
			WB	5.4	84.7	4.7	1.5	2.0	85.8	-0.8	86.7	-3.4	87.5	-6.9	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	28.6	35.0	46.9	58.1	68.4	78.2	81.3	78.5	70.5	59.6	44.2	32.4	(6)
	DBStd	19.20	5.74	7.03	7.59	6.90	5.60	4.97	4.00	4.30	5.23	6.69	7.56	5.75	(7)
	HDD50	2005	662	421	151	12	0	0	0	0	0	9	204	546	(8)
	HDD65	4621	1127	840	561	224	30	0	0	0	15	189	624	1011	(9)
	CDD50	4533	0	1	56	256	570	846	970	883	614	307	30	0	(10)
	CDD65	1674	0	0	1	17	136	396	505	418	179	22	0	0	(11)
	CDH74	16496	0	0	8	141	1192	4272	5565	3892	1277	149	0	0	(12)
	CDH80	6541	0	0	0	18	318	2003	2430	1424	330	18	0	0	(13)
(14) Wind	WSAvg	5.9	5.2	6.3	7.7	7.8	6.7	6.4	5.4	4.6	4.7	5.3	5.5	5.2	(14)
(15) Precipitation	PrecAvg	22.2	0.1	0.4	0.4	0.9	1.7	2.9	7.2	4.8	1.7	1.1	0.6	0.2	(15)
	PrecMax	37.2	1.0	1.2	1.7	2.8	4.1	6.8	18.8	12.1	5.8	8.5	3.1	0.7	(16)
	PrecMin	11.8	0.0	0.0	0.0	0.0	0.2	0.4	1.3	1.2	0.1	0.0	0.0	0.0	(17)
	PrecStd	6.3	0.2	0.4	0.4	0.7	0.9	1.5	4.6	2.7	1.1	1.6	0.7	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	59.8	74.1	82.6	90.8	98.6	98.5	93.9	89.0	82.2	68.5	51.9	(19)
		MCWB	37.8	46.4	57.4	66.8	69.6	70.8	75.5	80.5	72.8	65.1	55.0	41.6	(20)
	2%	DB	44.8	54.8	69.0	77.8	86.5	95.6	95.1	91.2	86.1	78.2	63.6	47.4	(21)
		MCWB	35.0	43.1	54.8	64.0	68.2	71.2	77.3	79.4	71.5	62.3	52.3	38.9	(22)
	5%	DB	41.4	51.1	64.5	74.3	83.6	93.1	92.6	89.1	83.9	74.5	59.8	44.3	(23)
		MCWB	33.2	41.1	51.8	61.3	67.6	70.2	77.9	78.5	69.9	60.1	49.8	36.8	(24)
	10%	DB	38.3	47.3	60.0	70.9	80.6	90.3	87.1	81.4	71.1	56.0	41.5		(25)
		MCWB	31.5	38.7	48.2	59.2	66.3	70.2	77.8	77.5	68.8	58.8	47.8	35.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.3	49.1	61.1	70.7	74.5	78.9	84.9	84.3	78.3	68.8	57.3	44.1	(27)
		MCDB	47.5	57.4	71.2	79.5	84.4	89.4	91.4	90.4	85.0	77.6	64.5	49.2	(28)
	2%	WB	36.2	45.2	56.4	66.3	72.2	76.4	82.8	82.4	75.2	66.1	54.3	40.8	(29)
		MCDB	42.4	52.3	66.2	74.9	81.9	87.1	89.3	88.3	81.9	72.7	61.0	45.0	(30)
	5%	WB	34.3	42.0	53.2	63.6	70.3	74.6	81.4	80.9	73.0	63.8	51.6	38.4	(31)
		MCDB	39.9	49.0	63.0	71.9	80.2	85.2	88.1	86.3	79.6	69.8	57.7	42.6	(32)
	10%	WB	32.3	39.3	49.8	60.9	68.2	73.1	80.0	79.4	71.2	61.3	49.1	36.2	(33)
		MCDB	37.0	46.5	58.8	69.6	77.3	84.1	86.6	84.5	77.9	68.1	54.6	40.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.3	17.2	18.7	19.2	19.8	19.9	14.8	14.2	18.0	18.7	16.8	15.4	(35)
		MCDBR	21.4	22.4	23.1	23.0	24.1	24.4	18.9	16.5	21.6	23.2	21.9	19.7	(36)
	5% WB	MCWBR	14.0	13.6	12.9	12.9	10.8	7.3	6.1	6.8	8.6	9.8	12.3	12.5	(37)
		MCWBR	18.5	20.2	21.7	20.9	20.0	18.9	14.4	14.0	16.5	18.0	18.5	16.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.524	0.595	0.606	0.639	0.670	0.811	0.789	0.762	0.693	0.683	0.586	0.527	(40)
		taud	1.739	1.634	1.625	1.596	1.582	1.394	1.477	1.508	1.578	1.553	1.674	1.762	(41)
	Ebn at Noon		190	194	211	215	211	183	186	186	188	169	170	178	(42)
		Edh at Noon	55	69	76	82	85	102	94	89	79	74	58	51	(43)
(44) All-Sky Solar Radiation	RadAvg		702	900	1347	1614	1825	1676	1492	1419	1262	996	745	651	(44)
	RadStd		85	139	117	104	135	134	104	144	130	98	117	81	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page