

TAI SHAN, China

WMO: 548260

Lat: 36.2556N

Lon: 117.1056E

Elev: 5039

StdP: 12.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	5.7	-28.4	1.4	14.8	-22.9	1.9	15.0	43.3	13.9	40.0	19.5	22.0	0	0.752

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	73.1	63.5	71.4	63.7	70.0	64.2	70.0	70.5	68.8	69.4	67.5	68.3	7.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.8	132.6	70.2	68.6	127.0	69.1	67.2	121.0	68.0	37.6	70.5	36.5	69.4	35.2	68.6	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
39.2	34.6	31.1	-4.1	77.2	4.5	2.4	-7.3	78.9	-10.0	80.3	-12.5	81.7	-15.8	83.4		
			-5.4	71.6	4.4	1.4	-8.5	72.6	-11.1	73.5	-13.6	74.3	-16.8	75.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	19.1	23.0	32.6	44.1	54.1	61.4	65.3	63.3	56.1	46.2	33.7	22.3
	DBStd	17.57	7.90	7.89	8.65	8.06	6.00	4.64	3.61	4.17	5.40	6.74	8.29	8.07
	HDD50	4003	957	755	540	208	29	1	0	0	13	153	489	858
	HDD65	7918	1422	1175	1003	628	338	121	39	78	270	583	938	1323
	CDD50	1654	0	0	1	31	157	344	475	414	196	35	1	0
	CDD65	95	0	0	0	0	2	14	50	27	2	0	0	0
	CDH74	41	0	0	0	1	1	12	22	4	1	0	0	0
	CDH80	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	14.5	16.1	14.9	16.0	16.5	15.7	12.7	11.7	11.6	12.0	13.6	16.0	16.8
Precipitation	PrecAvg	42.8	0.6	0.7	1.1	1.9	2.6	4.9	13.0	9.0	4.6	2.5	1.1	0.5
	PrecMax	72.8	2.2	2.8	2.6	5.6	7.4	14.0	26.2	21.4	10.7	11.1	4.5	2.5
	PrecMin	21.8	0.0	0.0	0.2	0.1	0.3	0.4	4.0	1.4	0.2	0.1	0.0	0.0
	PrecStd	12.2	0.6	0.7	0.6	1.5	1.9	3.5	5.3	5.0	2.8	2.4	1.0	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.4	47.0	56.1	66.4	71.0	75.6	76.5	74.3	70.7	63.6	54.2	42.4
		MCWB	34.1	39.5	44.3	53.0	55.1	60.6	62.1	67.2	58.8	50.9	42.3	30.5
	2%	DB	36.2	40.8	51.6	61.2	67.4	72.2	73.5	71.7	67.4	59.7	50.0	39.0
		MCWB	28.1	33.0	42.1	51.6	53.2	59.2	64.4	66.4	60.3	49.4	41.3	29.9
	5%	DB	32.7	36.5	47.8	57.9	64.9	70.2	71.7	70.1	65.2	57.3	47.6	36.0
		MCWB	25.2	30.1	38.7	49.1	52.5	58.8	65.8	66.4	57.7	48.1	39.0	28.3
	10%	DB	29.5	33.6	44.7	55.0	62.7	68.4	70.2	68.7	63.2	54.9	44.7	33.3
		MCWB	23.3	27.6	36.6	46.8	52.0	58.3	66.1	65.5	56.5	47.3	37.0	26.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.7	40.7	50.3	59.4	61.1	67.6	71.7	71.4	67.2	57.7	48.1	37.1
		MCDB	37.7	42.3	52.6	60.1	63.0	68.9	72.0	72.3	67.7	58.7	50.6	37.9
	2%	WB	29.3	34.6	44.1	54.7	58.9	65.4	70.3	69.7	63.3	54.0	44.6	32.0
		MCDB	34.1	39.0	48.5	58.7	62.1	67.7	70.8	70.3	64.7	55.9	47.1	35.4
	5%	WB	26.0	31.3	40.8	51.6	57.0	63.5	69.3	68.4	60.9	51.3	41.4	29.3
		MCDB	32.0	35.2	45.6	56.3	61.4	66.4	69.9	69.1	63.0	54.6	45.4	34.0
	10%	WB	23.4	28.6	37.9	48.6	55.0	61.7	68.3	67.1	58.9	49.3	38.3	27.1
		MCDB	28.8	33.1	43.5	53.2	60.0	65.2	68.9	67.9	61.3	52.8	43.0	32.5
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.1	10.5	10.8	10.2	9.3	6.5	6.4	8.0	8.7	8.9	8.7
		MCDBR	10.5	11.4	12.4	12.6	11.4	11.5	8.3	7.8	9.1	10.0	9.8	10.0
		MCWBR	7.8	9.2	9.9	9.9	9.3	8.4	8.1	8.2	9.0	8.5	8.2	7.6
	5% WB	MCDBR	10.0	10.7	12.2	11.7	9.9	8.9	5.8	6.1	7.7	8.4	9.5	9.0
		MCWBR	8.7	9.8	10.9	10.5	9.7	8.5	6.3	6.3	8.9	8.4	9.9	8.8
Clear-Sky Solar Irradiance	taub	0.378	0.429	0.442	0.459	0.474	0.567	0.551	0.526	0.479	0.481	0.425	0.381	
	taud	2.035	1.930	1.933	1.940	1.947	1.753	1.857	1.904	1.966	1.873	1.949	2.034	
	Ebn at Noon	246	248	259	262	260	235	238	241	245	227	226	235	
	Edh at Noon	41	51	56	59	59	72	64	60	54	54	44	38	
All-Sky Solar Radiation	RadAvg	738	925	1348	1598	1787	1663	1475	1407	1257	1022	777	680	
	RadStd	84	135	113	96	128	137	124	159	129	109	115	76	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	+2.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+184	+106	

Nomenclature: See separate page