

YIYUAN, China

WMO: 548360

Lat: 36.183N

Lon: 118.150E

Elev: 991

StdP: 14.18

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	17.0	-11.1	3.1	25.5	-6.9	3.9	26.0	15.7	28.6	13.7	30.4	2.5	250	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	92.2	73.6	89.9	72.9	87.8	72.4	80.1	86.6	78.7	85.0	77.4	83.2	7.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.4	152.9	83.8	77.0	145.9	82.7	75.6	139.2	81.6	44.7	86.8	43.2	85.2	41.8	83.2	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.7	12.6	11.1	8.9	95.9	4.0	2.8	6.0	97.9	3.7	99.5	1.4	101.1	-1.5	103.1
			6.9	81.5	3.8	1.5	4.2	82.5	2.0	83.4	-0.2	84.2	-3.0	85.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.1	29.1	34.4	45.5	57.8	68.0	75.2	79.4	77.3	69.3	58.3	44.5	33.0	(6)
(7)		DBStd	18.50	5.89	6.79	7.89	7.46	5.94	4.65	4.18	4.46	5.13	6.07	7.19	6.04	(7)
(8)		HDD50	2018	647	438	187	16	0	0	0	0	9	193	528		(8)
(9)		HDD65	4695	1112	858	607	235	36	1	0	0	19	219	615	993	(9)
(10)		CDD50	4239	0	0	46	251	558	755	911	846	578	266	28	0	(10)
(11)		CDD65	1443	0	0	1	21	130	307	446	382	146	10	0	0	(11)
(12)		CDH74	12647	0	0	11	214	1230	2768	4278	3172	898	76	0	0	(12)
(13)		CDH80	4259	0	0	1	44	360	1043	1619	997	190	5	0	0	(13)
(14)	Wind	WSAvg	4.6	4.1	4.6	5.5	5.9	5.5	4.6	4.4	4.2	3.8	3.8	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	27.6	0.3	0.4	0.7	1.4	1.8	3.5	8.9	5.5	2.8	1.2	0.6	0.4	(15)
(16)		PrecMax	63.7	1.6	1.5	1.9	4.5	5.7	10.2	18.9	18.1	13.1	3.4	3.0	2.2	(16)
(17)		PrecMin	16.1	0.0	0.0	0.0	0.0	0.1	0.2	1.2	1.3	0.4	0.0	0.0	0.0	(17)
(18)		PrecStd	9.4	0.4	0.4	0.5	1.1	1.4	2.4	4.3	3.5	2.4	1.0	0.6	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.3	58.6	74.7	85.4	91.8	94.5	95.1	93.0	88.2	79.7	69.2	53.7	(19)
(20)		MCWB	38.1	46.6	55.7	63.9	63.7	69.1	75.4	78.3	69.8	60.7	53.6	44.8		(20)
(21)		2%	DB	45.6	53.7	68.7	79.5	87.3	91.2	92.5	89.8	84.6	76.1	63.8	49.4	(21)
(22)		MCWB	35.9	42.2	51.2	59.9	63.5	67.7	76.2	77.0	68.4	59.4	50.3	41.8		(22)
(23)		5%	DB	42.2	50.1	63.9	75.7	83.9	88.8	90.3	87.5	81.9	72.7	59.9	45.8	(23)
(24)		MCWB	34.1	39.7	48.9	57.5	62.3	68.1	76.2	75.6	66.9	58.5	48.9	38.5		(24)
(25)		10%	DB	39.2	46.9	59.4	71.8	80.8	86.3	87.8	85.4	79.3	69.4	56.3	42.8	(25)
(26)		MCWB	32.2	37.4	46.1	55.4	61.2	67.5	75.7	74.5	66.1	57.4	47.7	36.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.1	49.3	58.1	67.2	70.9	76.9	81.6	81.8	76.1	66.7	57.5	48.4	(27)
(28)		MCDWB	46.2	54.8	69.9	79.0	78.8	85.9	88.8	88.4	82.2	70.6	62.5	51.4		(28)
(29)		2%	WB	37.7	44.3	53.9	62.9	67.9	74.9	80.3	80.1	72.7	63.6	54.2	42.9	(29)
(30)		MCDWB	43.2	52.2	65.2	75.0	79.0	82.9	87.0	86.3	78.4	69.8	59.4	46.7		(30)
(31)		5%	WB	34.9	41.1	50.4	60.2	66.1	72.9	79.2	78.7	70.8	61.6	51.3	39.7	(31)
(32)		MCDWB	41.2	47.8	61.6	72.0	78.2	81.1	85.9	84.4	77.1	68.9	57.7	44.6		(32)
(33)		10%	WB	32.6	38.2	47.1	57.5	64.2	71.4	78.0	77.3	69.1	59.6	48.4	37.0	(33)
(34)		MCDWB	38.3	45.6	57.9	68.6	75.5	80.1	84.4	82.5	75.4	66.9	55.3	41.8		(34)
(35)	Mean Daily Temperature Range	MDBR	15.8	16.4	18.4	19.1	19.4	17.5	13.5	13.1	16.1	18.2	17.0	15.2		(35)
(36)		5% DB	MCDBR	20.7	21.5	24.5	23.9	24.7	22.3	17.1	15.6	20.0	22.9	22.9	20.2	(36)
(37)		MCWBR	13.1	12.9	12.2	10.3	8.4	6.9	5.1	5.2	6.6	9.1	11.6	12.6		(37)
(38)		5% WB	MCDBR	18.2	19.2	22.9	21.9	19.4	15.5	13.4	12.5	14.4	16.8	18.7	17.1	(38)
(39)		MCWBR	12.3	12.7	12.5	11.1	9.1	6.8	5.4	5.2	6.5	8.4	11.9	12.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.499	0.569	0.599	0.618	0.635	0.758	0.730	0.682	0.618	0.630	0.564	0.503		(40)
(41)		taud	1.769	1.663	1.634	1.639	1.644	1.470	1.574	1.646	1.717	1.626	1.701	1.786		(41)
(42)		Ebn at Noon	202	204	214	221	220	194	198	204	208	185	180	189		(42)
(43)		Edh at Noon	54	68	76	79	80	95	85	78	69	69	58	50		(43)
(44)	All-Sky Solar Radiation	RadAvg	751	940	1359	1609	1782	1651	1461	1405	1270	1041	789	691		(44)
(45)		RadStd	86	127	108	82	128	139	134	152	121	105	111	71		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page