

HEZE CAOZHOU, China

WMO: 549060

Lat: 35.250N

Lon: 115.433E

Elev: 167

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.7	21.7	0.4	5.6	33.6	4.7	7.0	33.6	16.4	33.5	14.1	35.5	2.6	200	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.0	94.0	77.2	91.7	77.4	89.5	77.0	82.6	89.8	81.1	87.7	79.7	85.7	5.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	160.4	87.7	79.2	152.6	85.8	77.9	146.0	84.1	46.9	89.8	45.2	87.8	43.6	85.8	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.0	10.2	13.2	98.3	5.1	2.1	9.5	99.8	6.5	101.0	3.6	102.1	-0.1	103.6
			11.5	85.0	4.7	1.3	8.1	85.9	5.3	86.7	2.7	87.4	-0.7	88.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	32.6	37.2	45.5	59.7	68.5	77.2	81.2	78.5	71.3	59.9	46.0	35.8	(6)
	DBStd	18.05	5.01	5.79	7.07	6.70	6.00	4.86	4.24	4.00	4.92	6.51	8.19	5.88	(7)
	HDD50	1697	539	362	175	9	0	0	0	0	0	5	165	442	(8)
	HDD65	4270	1004	779	604	181	35	1	0	0	9	181	570	906	(9)
	CDD50	4577	0	3	36	300	572	816	968	885	638	313	45	1	(10)
	CDD65	1675	0	0	0	22	143	367	503	420	196	24	0	0	(11)
	CDH74	15665	0	0	0	202	1184	3607	5432	3773	1282	183	2	0	(12)
	CDH80	5910	0	0	0	36	346	1528	2326	1345	302	27	0	0	(13)
(14) Wind	WSAvg	4.0	3.9	4.3	5.1	5.1	4.3	3.7	3.6	3.2	3.2	3.3	4.2	3.9	(14)
(15) Precipitation	PrecAvg	25.4	0.3	0.4	0.9	1.4	2.0	2.9	7.2	4.9	3.0	1.4	0.7	0.3	(15)
	PrecMax	39.4	1.5	1.8	2.5	6.1	6.3	14.2	23.6	11.5	9.1	3.6	2.9	1.6	(16)
	PrecMin	13.7	0.0	0.0	0.0	0.1	0.0	0.5	1.3	0.4	0.2	0.0	0.0	0.0	(17)
	PrecStd	6.8	0.4	0.4	0.6	1.3	1.7	2.7	4.5	2.8	2.4	1.1	0.7	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.6	64.3	70.0	84.5	91.1	96.6	96.6	94.0	88.7	83.5	72.0	60.6	(19)
		MCWB	41.9	52.2	52.5	68.5	72.8	71.8	78.3	82.5	75.1	65.5	55.5	48.0	(20)
	2%	DB	47.5	56.2	66.0	79.4	86.8	93.9	94.3	90.7	86.0	78.7	66.7	53.1	(21)
		MCWB	38.4	47.0	51.1	64.4	69.5	71.9	80.0	79.5	72.5	63.7	53.4	43.4	(22)
	5%	DB	43.9	51.3	62.1	75.4	83.8	91.2	92.4	88.9	83.5	75.3	62.3	48.6	(23)
		MCWB	36.2	41.2	49.0	61.5	68.2	72.6	80.0	78.4	70.9	60.7	51.6	40.6	(24)
	10%	DB	40.8	47.0	58.3	72.0	81.0	88.2	90.1	86.9	81.2	72.0	57.8	45.0	(25)
		MCWB	34.8	38.9	47.9	58.8	67.6	71.8	79.4	77.3	69.4	59.5	49.1	39.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.6	53.7	56.8	70.7	75.6	79.8	85.4	83.6	78.2	69.6	58.2	48.8	(27)
		MCDB	50.6	61.5	63.8	80.5	83.7	87.9	92.4	92.1	84.6	77.4	66.2	57.7	(28)
	2%	WB	39.6	46.8	52.9	66.4	72.8	77.8	83.6	81.6	75.7	65.7	55.4	45.1	(29)
		MCDB	45.5	55.4	62.6	76.6	82.8	85.9	90.6	88.6	81.7	75.2	63.4	50.7	(30)
	5%	WB	37.6	42.8	50.8	63.9	71.0	75.8	82.1	80.2	73.9	62.8	53.1	42.2	(31)
		MCDB	42.1	49.1	59.2	72.3	80.4	85.0	89.0	86.3	80.0	71.8	60.5	46.6	(32)
	10%	WB	35.7	40.4	48.6	61.2	69.2	74.2	80.8	79.0	72.2	60.8	50.8	39.9	(33)
		MCDB	39.7	45.0	56.4	69.7	77.9	83.5	87.4	84.5	78.2	69.5	55.8	44.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	15.5	16.4	18.8	18.8	18.1	14.0	13.7	17.0	19.5	17.3	14.2	(35)
		MCDBR	19.5	22.8	23.0	23.5	23.7	23.1	17.8	16.0	19.1	23.1	24.2	21.8	(36)
	5% WB	MCWBR	12.1	13.6	11.9	12.2	10.9	7.8	7.2	6.6	7.8	9.9	12.7	13.2	(37)
		MCWBR	16.7	19.5	19.5	20.6	20.2	18.1	14.4	13.6	15.4	19.8	21.1	18.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.564	0.637	0.642	0.654	0.670	0.806	0.777	0.764	0.710	0.710	0.633	0.564	(40)
		taud	1.672	1.568	1.584	1.587	1.602	1.414	1.507	1.517	1.567	1.521	1.602	1.699	(41)
	Ebn at Noon		185	188	205	213	213	185	189	187	187	168	165	174	(42)
		Edh at Noon	61	76	81	84	84	101	92	89	81	78	65	56	(43)
(44) All-Sky Solar Radiation	RadAvg		705	873	1284	1525	1693	1650	1465	1394	1202	976	753	657	(44)
	RadStd		88	141	108	123	128	122	135	181	156	108	113	89	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	N/A

Nomenclature: See separate page