

HEZE CAOZHOU, China

WMO: 549060

Lat: 35.250N

Lon: 115.433E

Elev: 51

StdP: 100.71

Time Zone: 8.00 (E08)

Period: 86-94

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.4	(c) -5.7	(d) -17.5	(e) 0.8	(f) 0.9	(g) -15.2	(h) 1.0	(i) 0.9	(j) 7.3	(k) 0.8	(l) 6.3	(m) 2.0	(n) 1.1	(o) 200	(p) 0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	34.5	25.1	33.2	25.2	32.0	25.0	28.1	32.1	27.3	30.9	26.5	29.9	2.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	22.9	30.9	26.2	21.8	29.9	25.5	20.9	29.0	91.1	32.1	87.2	31.0	83.5	29.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.4	(b) 5.4	(c) 4.6	(e) -10.5	(f) 36.8	(g) 2.8	(h) 1.2	(i) -12.5	(j) 37.6	(k) -14.2	(l) 38.3	(m) -15.8	(n) 39.0	(o) -17.8	(p) 39.8		
(a) 6.4	(b) 5.4	(c) 4.6	(e) -11.4	(f) 29.5	(g) 2.6	(h) 0.7	(i) -13.3	(j) 30.0	(k) -14.8	(l) 30.4	(m) -16.3	(n) 30.8	(o) -18.2	(p) 31.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	0.3	2.9	7.5	15.4	20.3	25.1	27.3	25.9	21.8	15.5	7.8	2.1		
	DBStd	10.03	2.78	3.22	3.93	3.72	3.34	2.70	2.35	2.22	2.74	3.61	4.55	3.26		
	HDD10.0	943	299	201	97	5	0	0	0	0	0	3	92	246		
	HDD18.3	2372	558	433	336	101	19	1	0	0	5	101	317	503		
	CDD10.0	2543	0	2	20	167	318	453	538	492	354	174	25	1		
	CDD18.3	931	0	0	0	12	79	204	279	233	109	13	0	0		
	CDH23.3	8703	0	0	0	112	658	2004	3018	2096	712	102	1	0		
	CDH26.7	3283	0	0	0	20	192	849	1292	747	168	15	0	0		
(14) Wind	WSAvg	1.8	1.8	1.9	2.3	2.3	1.9	1.7	1.6	1.4	1.4	1.5	1.9	1.8		
(15) Precipitation	PrecAvg	646	7	10	22	35	51	73	182	125	77	36	18	8		
	PrecMax	1001	38	46	64	156	161	360	599	291	230	91	73	40		
	PrecMin	347	0	0	0	3	1	12	34	10	4	1	0	0		
	PrecStd	172	10	11	16	33	44	68	115	72	60	28	17	10		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	17.9	21.1	29.2	32.9	35.9	35.9	34.4	31.5	28.6	22.2	15.9		
		MCWB	5.5	11.2	11.4	20.3	22.7	22.1	25.7	28.0	23.9	18.6	13.0	8.9		
	2%	DB	8.6	13.5	18.9	26.3	30.5	34.4	34.6	32.6	30.0	26.0	19.3	11.7		
		MCWB	3.6	8.3	10.6	18.0	20.8	22.2	26.7	26.4	22.5	17.6	11.9	6.3		
	5%	DB	6.6	10.7	16.7	24.1	28.8	32.9	33.5	31.6	28.6	24.1	16.9	9.2		
		MCWB	2.4	5.1	9.5	16.4	20.1	22.6	26.7	25.8	21.6	15.9	10.9	4.8		
	10%	DB	4.9	8.3	14.6	22.2	27.2	31.2	32.3	30.5	27.3	22.2	14.3	7.2		
		MCWB	1.6	3.8	8.8	14.9	19.8	22.1	26.3	25.2	20.8	15.3	9.5	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	12.0	13.8	21.5	24.2	26.5	29.7	28.7	25.7	20.9	14.6	9.3		
		MCDB	10.4	16.4	17.7	27.0	28.7	31.1	33.6	33.4	29.2	25.2	19.0	14.3		
	2%	WB	4.2	8.2	11.6	19.1	22.7	25.4	28.7	27.6	24.3	18.7	13.0	7.3		
		MCDB	7.5	13.0	17.0	24.8	28.2	29.9	32.6	31.4	27.6	24.0	17.5	10.4		
	5%	WB	3.1	6.0	10.4	17.7	21.6	24.4	27.8	26.8	23.3	17.1	11.7	5.7		
		MCDB	5.6	9.5	15.1	22.4	26.9	29.5	31.7	30.2	26.6	22.1	15.8	8.1		
	10%	WB	2.0	4.7	9.2	16.2	20.7	23.4	27.1	26.1	22.3	16.0	10.4	4.4		
		MCDB	4.3	7.2	13.6	21.0	25.5	28.6	30.8	29.2	25.7	20.8	13.2	6.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.6	9.1	10.4	10.4	10.1	7.8	7.6	9.4	10.8	9.6	7.9		
		MCDBR	10.8	12.7	12.8	13.0	13.1	12.9	9.9	8.9	10.6	12.8	13.5	12.1		
	5% WB	MCWBR	6.7	7.5	6.6	6.8	6.0	4.3	4.0	3.7	4.3	5.5	7.1	7.3		
		MCWBR	9.3	10.8	10.8	11.5	11.2	10.1	8.0	7.6	8.5	11.0	11.7	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.564	0.637	0.642	0.654	0.670	0.806	0.777	0.764	0.710	0.710	0.633	0.564		
	taud		1.672	1.568	1.584	1.587	1.602	1.414	1.507	1.517	1.567	1.521	1.602	1.699		
	Ebn at Noon		583	593	647	672	670	583	596	591	591	530	519	549		
	Edh at Noon		193	239	254	265	264	318	289	281	255	246	205	178		
(44) All-Sky Solar Radiation	RadAvg		2.22	2.75	4.05	4.81	5.34	5.20	4.62	4.39	3.79	3.08	2.37	2.07		
	RadStd		0.28	0.45	0.34	0.39	0.40	0.39	0.43	0.57	0.49	0.34	0.36	0.28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+89	N/A

Nomenclature: See separate page