

DINGTAO, China

WMO: 549090

Lat: 35.0907N

Lon: 115.5232E

Elev: 167

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	21.0	-1.3	5.2	30.3	3.2	6.5	28.9	17.0	36.7	15.4	35.0	3.4	20	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	94.7	77.0	92.6	76.8	90.3	76.5	83.1	90.0	81.8	88.2	80.4	86.3	7.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	163.8	87.7	80.0	156.7	86.3	78.7	149.9	84.6	47.4	90.2	45.9	88.5	44.4	86.5	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	13.8	11.9	11.3	99.4	3.5	2.5	8.8	101.2	6.7	102.7	4.8	104.1	2.2	105.9
			9.8	85.1	3.3	1.3	7.4	86.1	5.5	86.9	3.6	87.6	1.2	88.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.6	32.2	38.5	49.3	59.6	69.2	78.4	81.3	78.9	70.9	61.2	47.1	35.8	(6)
	DBStd	17.96	5.58	7.05	7.50	6.89	5.72	4.81	4.31	4.71	5.31	6.23	7.59	5.64	(7)
	HDD50	1578	553	326	106	9	0	0	0	0	0	4	140	440	(8)
	HDD65	4064	1018	742	489	188	24	0	0	0	12	149	537	905	(9)
	CDD50	4726	0	4	83	296	595	853	971	894	626	350	54	0	(10)
	CDD65	1738	0	0	1	26	154	403	506	430	188	30	0	0	(11)
	CDH74	16869	0	0	13	214	1315	4233	5498	4062	1324	207	3	0	(12)
	CDH80	6638	0	0	0	36	399	1926	2367	1516	367	27	0	0	(13)
(14) Wind	WSAvg	5.4	5.4	6.2	6.8	6.5	5.8	5.7	4.8	4.3	4.3	4.7	5.3	5.2	(14)
(15) Precipitation	PrecAvg	25.9	0.2	0.6	0.7	1.2	2.2	2.8	6.9	5.5	3.3	1.2	1.0	0.4	(15)
	PrecMax	42.6	1.4	1.2	2.9	3.4	5.1	8.0	13.1	11.6	11.6	4.3	3.9	1.4	(16)
	PrecMin	15.0	0.0	0.0	0.0	0.2	0.0	0.2	2.0	0.9	0.2	0.0	0.0	0.0	(17)
	PrecStd	6.3	0.3	0.4	0.8	0.9	1.3	2.0	3.0	3.3	3.1	1.2	1.1	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	63.0	75.5	84.3	93.0	98.1	97.2	94.9	90.7	83.3	72.4	56.9	(19)
		MCWB	41.7	51.2	60.6	69.4	68.5	71.9	79.2	82.5	75.5	64.0	57.9	44.3	(20)
	2%	DB	48.5	58.0	70.9	79.7	87.8	94.8	94.7	91.7	87.0	79.2	66.6	51.7	(21)
		MCWB	39.0	46.7	56.7	65.4	69.2	72.3	80.1	81.1	72.8	62.7	54.2	41.6	(22)
	5%	DB	44.8	54.0	66.5	75.9	84.3	92.6	92.6	89.5	84.2	75.9	62.7	48.1	(23)
		MCWB	36.8	43.9	54.2	63.2	68.6	72.0	80.1	79.8	71.5	61.8	52.2	40.7	(24)
	10%	DB	41.4	50.3	62.3	72.3	81.2	89.9	90.2	87.4	81.5	72.3	59.0	45.0	(25)
		MCWB	34.5	42.1	51.0	60.8	67.3	71.7	79.4	78.6	69.6	60.2	50.0	38.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	53.0	63.3	72.0	74.7	80.6	85.1	84.3	80.8	68.9	60.3	47.2	(27)
		MCDB	50.9	60.7	71.3	81.6	83.4	89.2	92.3	91.3	85.8	75.5	67.7	52.2	(28)
	2%	WB	40.0	48.3	58.9	68.3	72.8	78.1	83.6	82.8	76.0	66.6	56.3	44.1	(29)
		MCDB	46.7	55.3	67.9	76.8	82.2	87.0	90.8	89.4	82.0	74.0	63.4	48.8	(30)
	5%	WB	37.6	45.5	55.6	65.1	70.8	76.4	82.3	81.7	73.7	64.5	53.9	41.8	(31)
		MCDB	43.6	52.1	64.9	73.5	80.2	85.9	89.2	87.6	80.5	70.9	59.9	46.7	(32)
	10%	WB	35.3	42.7	52.4	62.5	68.9	74.6	81.0	80.4	72.0	62.5	51.6	39.5	(33)
		MCDB	40.0	48.9	60.6	70.6	77.9	84.2	87.6	85.4	78.7	69.4	57.6	44.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	15.7	17.5	18.3	18.7	18.7	13.7	13.7	16.5	17.7	16.5	15.1	(35)
		MCDBR	20.2	21.8	22.8	22.5	23.7	23.3	17.1	15.8	20.5	22.9	22.2	20.8	(36)
	5% WB	MCWBR	12.9	13.1	12.7	12.1	10.1	7.2	6.2	6.6	8.0	9.3	11.5	12.9	(37)
		MCWBR	17.8	18.7	21.2	20.1	19.2	17.7	14.8	13.7	16.3	17.6	17.9	17.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.567	0.639	0.644	0.654	0.671	0.805	0.774	0.762	0.708	0.710	0.635	0.567	(40)
		taud	1.666	1.565	1.580	1.586	1.602	1.415	1.513	1.520	1.571	1.520	1.597	1.691	(41)
	Ebn at Noon		185	188	205	213	213	185	190	188	188	168	164	174	(42)
		Edh at Noon	62	76	81	84	84	101	91	89	81	78	66	57	(43)
(44) All-Sky Solar Radiation	RadAvg		706	872	1281	1520	1682	1642	1462	1393	1197	979	754	658	(44)
	RadStd		89	143	108	123	127	122	141	181	159	108	113	90	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+196	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	N/A

Nomenclature: See separate page