

FEIXIAN, China

WMO: 549290

Lat: 35.2607N

Lon: 117.9612E

Elev: 394

StdP: 14.49

Time Zone: 8.00 (E08)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.7	20.6	-5.9	4.1	27.1	-1.6	5.1	28.4	14.9	29.7	12.9	31.3	2.6	290	0.373

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	93.6	75.8	91.6	75.1	89.3	74.8	81.5	89.0	80.3	87.4	79.1	85.5	5.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	155.2	86.1	78.3	149.1	85.0	77.1	143.4	83.9	45.7	89.5	44.4	87.4	43.1	86.0	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.2	11.3	9.7	DB	12.9	98.2	3.7	2.7	10.2	100.1	8.0	101.7	5.9	103.2	3.2	105.2	(4)
			WB	10.5	83.2	3.6	1.3	8.0	84.2	5.9	84.9	3.9	85.7	1.3	86.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	32.4	37.5	48.3	60.2	69.9	77.0	81.1	79.4	72.0	61.4	47.7	35.9	(6)
(7)		DBStd	17.97	5.58	6.39	7.44	6.87	5.84	4.84	4.21	4.44	4.79	5.77	7.12	5.92	(7)
(8)		HDD50	1588	544	352	121	6	0	0	0	0	2	124	439		(8)
(9)		HDD65	4059	1009	771	518	174	20	1	0	5	140	518	903		(9)
(10)		CDD50	4751	0	1	69	312	616	809	963	911	659	354	56	1	(10)
(11)		CDD65	1749	0	0	1	30	172	360	498	446	214	28	0	0	(11)
(12)		CDH74	16146	0	0	17	296	1528	3374	5204	4228	1357	140	2	0	(12)
(13)		CDH80	5844	0	0	2	65	489	1370	2095	1485	323	15	0	0	(13)
(14)	Wind	WSAvg	4.1	3.7	4.2	5.1	5.4	4.9	4.5	4.0	3.8	3.3	3.3	3.6	3.8	(14)
(15)	Precipitation	PrecAvg	32.3	0.4	0.7	0.8	1.4	2.8	4.2	8.3	8.1	2.6	1.3	1.1	0.6	(15)
(16)		PrecMax	46.5	2.1	2.4	3.3	3.5	6.9	10.2	17.6	16.0	10.1	3.5	4.6	1.7	(16)
(17)		PrecMin	16.3	0.0	0.0	0.0	0.2	0.1	0.5	2.1	1.9	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.5	0.5	0.5	0.8	0.8	1.6	2.6	3.7	3.9	2.0	1.1	1.3	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.3	60.7	75.7	86.3	93.2	96.3	96.8	94.7	89.7	81.6	71.6	56.5	(19)
(20)		MCWB	41.0	48.8	57.4	65.6	65.9	71.9	77.8	80.3	72.4	63.9	56.4	47.0		(20)
(21)		2%	DB	47.6	55.8	70.7	80.9	88.6	92.9	93.9	91.8	85.9	77.6	66.1	52.0	(21)
(22)		MCWB	38.7	44.1	54.1	62.5	65.9	69.5	78.9	79.4	70.9	62.0	53.4	44.4		(22)
(23)		5%	DB	44.5	52.2	66.1	76.9	85.0	90.4	91.7	89.3	83.6	74.6	62.3	48.5	(23)
(24)		MCWB	37.0	42.4	52.1	60.1	65.1	70.2	78.8	77.8	69.4	61.1	52.3	41.3		(24)
(25)		10%	DB	41.9	48.9	61.6	73.2	82.0	87.8	89.1	87.2	81.3	71.6	59.2	45.5	(25)
(26)		MCWB	35.7	40.8	48.8	58.1	63.9	70.1	77.9	76.5	68.1	60.0	51.1	39.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	51.1	60.2	69.4	72.7	79.2	83.1	82.8	78.2	68.6	60.3	50.9	(27)
(28)		MCDWB	50.0	57.6	72.0	81.8	80.5	88.2	91.4	90.0	84.0	73.5	65.0	53.4		(28)
(29)		2%	WB	41.2	46.9	56.6	65.6	70.1	77.0	81.8	81.3	74.6	66.3	57.3	45.6	(29)
(30)		MCDWB	44.9	53.2	67.7	76.6	80.9	85.5	89.7	88.3	80.6	71.8	62.8	49.5		(30)
(31)		5%	WB	38.4	43.9	53.4	62.9	68.3	75.1	80.8	80.3	72.8	64.3	54.7	42.9	(31)
(32)		MCDWB	43.5	50.0	63.3	73.2	80.2	83.3	88.6	86.7	79.0	71.2	60.4	46.8		(32)
(33)		10%	WB	36.1	41.5	50.3	60.1	66.5	73.2	79.6	79.1	71.3	62.4	51.7	40.5	(33)
(34)		MCDWB	41.0	47.9	59.8	70.4	77.9	82.2	86.7	84.9	77.7	69.4	58.4	44.9		(34)
(35)	Mean Daily Temperature Range	MDBR	14.9	15.2	17.8	18.7	18.2	16.5	12.6	12.4	15.0	16.9	16.4	14.9		(35)
(36)		5% DB	MCDBR	19.4	20.9	24.3	24.1	23.2	21.2	15.9	14.5	18.3	21.1	21.2	19.6	(36)
(37)		MCWBR	12.2	12.4	11.9	11.1	8.1	6.8	5.2	5.1	5.7	8.4	10.9	12.3		(37)
(38)		5% WB	MCDBR	16.7	18.0	22.7	21.3	19.0	16.0	13.7	12.7	13.4	15.6	16.9	15.9	(38)
(39)		MCWBR	11.5	11.9	12.5	11.6	8.7	6.9	5.8	5.5	5.9	7.8	10.5	11.4		(39)
(40)		Clear-Sky Solar Irradiance	taub	0.532	0.604	0.630	0.641	0.656	0.780	0.745	0.705	0.645	0.658	0.603	0.539	(40)
(41)	taud		1.720	1.619	1.596	1.615	1.623	1.448	1.560	1.621	1.683	1.594	1.643	1.730	(41)	
(42)	Ebn at Noon		194	197	208	216	216	190	195	200	203	180	172	181	(42)	
(43)	Edh at Noon		58	72	80	82	82	98	87	80	72	73	62	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	752	918	1330	1582	1730	1624	1453	1408	1258	1050	794	696	(44)	
(45)		RadStd	88	127	107	103	126	142	146	171	127	112	104	70	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page