

NGARI, China

WMO: 552280

Lat: 32.500N

Lon: 80.083E

Elev: 14042

StdP: 8.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-5.6	-35.6	1.2	17.7	-32.3	1.5	13.8	25.1	26.7	21.9	25.4	0.6	70	0.710

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	72.9	45.0	70.9	44.7	68.8	44.4	49.3	64.7	48.1	63.0	47.0	61.9	9.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
44.0	73.0	53.7	42.7	69.2	53.6	41.1	65.2	54.2	25.6	64.8	24.7	63.1	23.9	61.9	57.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.6	16.2	-15.8	77.0	6.7	1.9	-20.6	78.4	-24.6	79.5	-28.3	80.6	-33.2	82.0		
(5)			-17.0	51.0	6.0	2.0	-21.3	52.4	-24.8	53.6	-28.1	54.8	-32.5	56.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	35.0	11.5	15.9	23.8	33.1	41.6	52.0	59.0	57.5	49.5	34.0	24.1	16.8		
	DBStd	17.05	7.43	6.76	5.97	4.98	4.78	5.77	3.22	3.32	5.25	5.66	4.75	6.53		
	HDD50	6153	1192	954	813	507	261	48	1	0	73	496	777	1031		
	HDD65	10949	1657	1374	1278	957	724	391	186	233	465	961	1227	1496		
	CDD50	678	0	0	0	0	2	106	280	232	58	0	0	0		
	CDD65	1	0	0	0	0	0	0	1	0	0	0	0	0		
	CDH74	27	0	0	0	0	0	1	21	5	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	5.7	4.7	5.8	6.3	6.5	6.9	7.0	6.7	5.9	5.6	4.6	4.2	4.5		
	PrecAvg	2.6	0.1	0.0	0.1	0.0	0.1	0.1	0.8	1.0	0.2	0.0	0.0	0.0		
(15) Precipitation	PrecMax	5.4	0.2	0.2	0.4	0.2	0.6	0.7	2.0	2.3	1.1	0.4	0.4	0.4		
	PrecMin	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.0	0.1	0.0	0.1	0.0	0.1	0.2	0.5	0.6	0.3	0.1	0.1	0.1		
	PrecStd	1.0	0.1	0.0	0.1	0.0	0.1	0.2	0.5	0.6	0.3	0.1	0.1	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.7	39.3	49.3	55.4	63.1	73.1	76.4	74.6	69.2	58.4	46.6	40.9		
		MCWB	22.3	24.7	28.7	31.9	38.0	43.2	47.4	46.3	43.1	33.7	27.3	24.0		
	2%	DB	31.3	35.0	44.0	51.9	60.0	70.6	73.9	71.6	66.4	54.3	42.8	36.2		
		MCWB	19.5	22.2	26.9	30.7	35.7	43.0	45.6	45.4	42.1	32.7	25.2	21.7		
	5%	DB	27.8	31.7	40.3	49.1	57.5	68.0	71.9	69.5	63.9	51.1	39.9	32.7		
		MCWB	17.5	20.2	24.9	29.5	34.6	42.4	45.2	45.0	41.2	31.2	23.9	19.9		
	10%	DB	24.6	28.7	37.2	46.5	54.9	65.3	69.8	67.5	61.5	47.8	37.1	29.6		
		MCWB	15.5	18.4	23.2	28.4	33.4	41.1	44.9	44.9	39.9	29.4	22.6	18.1		
	0.4%	WB	23.1	26.3	29.4	33.0	39.8	47.3	52.7	51.0	46.0	36.8	27.8	24.9		
		MCDB	33.6	37.3	46.6	51.1	58.7	66.2	70.4	66.7	63.3	52.5	44.6	38.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	20.3	22.8	27.3	31.4	37.7	45.5	49.8	49.3	44.6	34.0	25.8	22.1		
		MCDB	29.7	33.6	42.8	49.6	55.5	64.4	65.9	64.1	61.2	51.5	41.5	35.1		
	5%	WB	17.9	20.7	25.4	30.2	36.1	44.1	48.4	48.2	43.4	31.8	24.2	20.2		
		MCDB	27.2	30.8	39.2	47.4	53.0	62.9	63.8	62.5	59.3	49.0	39.0	32.0		
	10%	WB	15.8	18.8	23.6	28.9	34.6	42.6	47.3	47.2	42.1	29.9	22.7	18.3		
		MCDB	24.4	28.2	36.4	45.1	51.6	61.2	62.8	61.1	57.3	46.7	36.7	29.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.6	22.5	23.6	24.0	24.0	22.6	21.1	19.4	21.7	24.6	26.6	25.5		
		MCDBR	26.1	26.3	28.1	27.9	26.9	25.0	24.4	21.9	23.2	26.9	29.3	28.1		
		MCWBR	18.2	17.8	16.7	14.1	12.1	9.3	8.2	6.5	8.5	13.3	17.5	18.5		
		MCDBR	24.3	24.4	26.2	25.5	24.1	22.7	20.2	18.5	20.1	24.9	28.3	27.6		
	5% WB	MCWBR	17.2	16.8	16.0	13.3	11.2	8.8	7.2	6.2	8.0	12.6	17.0	18.4		
		MCWBR	17.2	16.8	16.0	13.3	11.2	8.8	7.2	6.2	8.0	12.6	17.0	18.4		
(40) Clear-Sky Solar Irradiance	taub		0.195	0.221	0.255	0.300	0.312	0.302	0.308	0.303	0.242	0.206	0.185	0.180		
	taud		2.554	2.454	2.364	2.246	2.255	2.375	2.419	2.440	2.583	2.611	2.654	2.654		
	Ebn at Noon		339	335	327	313	308	310	307	309	328	338	343	343		
	Edh at Noon		25	31	37	44	44	39	37	36	29	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		1079	1340	1855	2172	2390	2410	2230	2053	1987	1768	1390	1143		
	RadStd		147	153	92	101	162	147	172	157	149	93	58	66		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	-2.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page