

BAINGOIN, China

WMO: 552790

Lat: 31.3973N

Lon: 90.0117E

Elev: 15423

StdP: 8.15

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.7	(c) -0.6	(d) -34.8	(e) 1.4	(f) 19.5	(g) -32.0	(h) 1.6	(i) 19.3	(j) 34.9	(k) 31.3	(l) 30.2	(m) 29.6	(n) 2.3	(o) 180	(p) 0.830

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 15.7	(c) 62.9	(d) 41.9	(e) 60.8	(f) 41.8	(g) 58.8	(h) 41.6	(i) 46.5	(j) 56.7	(k) 45.6	(l) 55.4	(m) 44.8	(n) 54.3	(o) 9.7	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.3	72.3	50.5	41.4	69.8	49.9	40.6	67.6	49.3	24.3	57.1	23.6	55.6	23.0	54.5	53.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.9	22.7	20.2	-12.5	67.0	4.1	2.4	-15.5	68.7	-17.9	70.2	-20.2	71.5	-23.3	73.3		
			-13.5	48.7	3.5	1.5	-16.0	49.8	-18.0	50.7	-20.0	51.5	-22.5	52.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	15.3	18.8	24.5	31.6	39.1	47.6	49.5	48.3	44.8	33.8	24.0	18.4
	DBStd	13.45	7.75	6.66	6.06	5.08	5.28	5.12	2.94	2.95	4.42	6.48	6.01	7.54
	HDD50	6274	1074	873	790	553	339	104	44	69	164	502	781	981
	HDD65	11662	1539	1293	1255	1003	802	522	480	519	606	966	1231	1446
	CDD50	86	0	0	0	0	2	32	29	15	8	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.0	11.0	11.8	11.3	10.0	8.5	8.2	6.9	6.3	7.6	7.8	9.0	10.1
Precipitation	PrecAvg	12.0	0.0	0.1	0.1	0.2	0.6	2.0	3.1	3.4	2.0	0.4	0.1	0.0
	PrecMax	18.5	0.2	0.3	0.4	0.7	2.5	4.2	6.2	6.7	4.6	1.6	0.7	0.2
	PrecMin	7.6	0.0	0.0	0.0	0.0	0.0	0.6	1.4	1.1	0.6	0.0	0.0	0.0
	PrecStd	2.4	0.1	0.1	0.1	0.2	0.6	1.0	1.1	1.2	1.0	0.4	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.6	40.0	47.3	51.4	61.3	67.0	64.4	63.3	61.5	56.1	43.6	42.2
		MCWB	23.9	23.7	27.3	30.3	35.9	41.3	43.9	43.4	40.1	34.6	25.4	24.2
	2%	DB	35.1	35.4	42.2	48.3	57.1	63.8	61.9	60.7	58.5	51.7	40.0	37.2
		MCWB	20.4	21.0	25.3	29.0	34.6	40.7	44.1	43.0	40.4	32.9	23.7	21.5
	5%	DB	31.3	32.7	38.6	45.5	53.6	61.1	59.8	58.5	56.2	48.2	37.5	33.8
		MCWB	18.4	19.4	23.3	27.9	33.5	40.5	43.5	43.0	39.8	31.9	22.6	19.7
	10%	DB	27.6	30.0	35.6	42.7	50.4	58.4	57.7	56.5	53.9	45.0	34.7	30.7
		MCWB	16.2	18.0	21.8	26.6	32.4	40.3	43.3	43.0	39.4	30.2	21.3	18.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	24.5	28.2	33.2	40.2	45.9	48.1	47.6	44.9	37.7	26.7	24.6
		MCDB	39.6	37.9	44.5	45.9	52.0	58.5	58.9	57.7	55.3	49.1	39.4	41.2
	2%	WB	20.8	21.4	25.9	30.7	37.8	44.7	46.8	46.4	43.6	35.6	24.7	21.7
		MCDB	34.0	34.3	40.9	43.4	49.2	57.0	57.1	55.9	53.6	46.6	37.6	36.5
	5%	WB	18.7	19.7	24.0	29.2	36.2	43.7	45.9	45.4	42.4	33.8	23.2	19.8
		MCDB	30.9	32.0	37.2	42.1	47.4	55.5	55.9	54.4	51.9	44.5	35.9	33.2
	10%	WB	16.5	18.1	22.3	27.7	34.6	42.6	45.1	44.5	41.3	31.9	21.8	18.1
		MCDB	27.3	29.4	34.4	40.4	45.8	53.6	54.7	53.0	50.5	42.5	33.7	30.1
Mean Daily Temperature Range	5% DB	MDBR	18.3	17.1	17.8	18.5	18.0	17.8	15.7	15.3	16.7	17.9	18.7	19.2
		MCDBR	21.0	19.1	20.7	22.1	22.4	21.2	19.1	19.3	18.9	20.7	20.5	20.1
		MCWBR	13.7	12.1	12.0	10.9	9.2	7.5	7.0	7.1	6.8	8.6	11.8	12.2
	5% WB	MCDBR	20.6	18.5	19.6	19.7	17.9	17.1	15.4	14.9	16.1	18.1	19.5	20.5
		MCWBR	13.6	11.9	11.8	10.1	8.3	7.0	6.8	6.8	7.1	7.9	11.7	13.0
Clear-Sky Solar Irradiance	taub	0.171	0.185	0.224	0.265	0.279	0.270	0.271	0.265	0.245	0.206	0.174	0.161	
	taud	2.647	2.595	2.482	2.390	2.416	2.541	2.589	2.605	2.631	2.687	2.700	2.739	
	Ebn at Noon	353	352	340	326	319	320	319	322	328	340	349	355	
	Edh at Noon	23	27	33	38	37	33	31	30	28	24	22	20	
All-Sky Solar Radiation	RadAvg	1221	1492	1855	2079	2233	2255	2029	1891	1827	1652	1387	1219	
	RadStd	121	127	121	111	117	115	118	117	101	114	84	76	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.95	N/A	-4.25	N/A	N/A	-446	-490	+63	N/A

Nomenclature: See separate page