

BAINGOIN, China

WMO: 552790

Lat: 31.3973N

Lon: 90.0117E

Elev: 4701

StdP: 56.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.4	-18.1	-37.1	0.2	-6.9	-35.5	0.2	-7.1	15.6	-0.4	13.5	-1.3	1.0	180	0.830

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	17.2	5.5	16.0	5.4	14.9	5.4	8.1	13.7	7.6	13.0	7.1	12.4	4.3	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.7	10.3	10.3	5.2	10.0	10.0	4.8	9.7	9.6	38.6	13.9	37.0	13.1	35.6	12.5	12.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	11.6	10.1	9.0	DB	-24.7	19.4	2.3	1.3	-26.4	20.4	-27.7	21.2	-29.0	22.0	-30.7	22.9
(5)				WB	-25.3	9.3	1.9	0.8	-26.7	9.9	-27.8	10.4	-28.9	10.8	-30.3	11.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-9.3	-7.3	-4.2	-0.2	4.0	8.7	9.7	9.0	7.1	1.0	-4.5	-7.6	(6)
(7)		DBStd	7.47	4.30	3.70	3.37	2.82	2.93	2.85	1.64	1.64	2.45	3.60	3.34	4.19	(7)
(8)		HDD10.0	3486	597	485	439	307	188	58	24	38	91	279	434	545	(8)
(9)		HDD18.3	6479	855	718	697	557	446	290	267	288	337	537	684	803	(9)
(10)		CDD10.0	48	0	0	0	0	1	18	16	8	4	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.9	5.3	5.1	4.5	3.8	3.7	3.1	2.8	3.4	3.5	4.0	4.5	(14)
(15)	Precipitation	PrecAvg	304	1	2	2	5	14	50	79	86	52	10	2	1	(15)
(16)		PrecMax	469	6	7	9	18	64	106	157	170	117	41	18	5	(16)
(17)		PrecMin	192	0	0	0	0	0	14	36	29	15	0	0	0	(17)
(18)		PrecStd	61	2	2	2	4	14	26	27	31	25	9	4	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.8	4.5	8.5	10.8	16.3	19.4	18.0	17.4	16.4	13.4	6.4	5.7	(19)
(20)		MCWB	-4.5	-4.6	-2.6	-1.0	2.2	5.1	6.6	6.3	4.5	1.4	-3.7	-4.3	(20)	
(21)		2%	DB	1.7	1.9	5.7	9.0	14.0	17.7	16.6	15.9	14.7	10.9	4.5	2.9	(21)
(22)		MCWB	-6.4	-6.1	-3.7	-1.7	1.4	4.8	6.7	6.1	4.7	0.5	-4.6	-5.8	(22)	
(23)		5%	DB	-0.4	0.4	3.7	7.5	12.0	16.2	15.4	14.7	13.4	9.0	3.1	1.0	(23)
(24)		MCWB	-7.6	-7.0	-4.8	-2.3	0.8	4.7	6.4	6.1	4.3	-0.1	-5.2	-6.8	(24)	
(25)		10%	DB	-2.5	-1.1	2.0	5.9	10.2	14.7	14.3	13.6	12.1	7.2	1.5	-0.7	(25)
(26)		MCWB	-8.8	-7.8	-5.7	-3.0	0.2	4.6	6.3	6.1	4.1	-1.0	-5.9	-7.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.4	-4.2	-2.1	0.7	4.6	7.7	8.9	8.7	7.2	3.2	-2.9	-4.1	(27)
(28)		MCDWB	4.2	3.3	6.9	7.7	11.1	14.7	14.9	14.3	12.9	9.5	4.1	5.1	(28)	
(29)		2%	WB	-6.2	-5.9	-3.4	-0.7	3.2	7.1	8.2	8.0	6.4	2.0	-4.0	-5.7	(29)
(30)		MCDWB	1.1	1.3	4.9	6.3	9.5	13.9	13.9	13.3	12.0	8.1	3.1	2.5	(30)	
(31)		5%	WB	-7.4	-6.8	-4.5	-1.5	2.3	6.5	7.7	7.4	5.8	1.0	-4.9	-6.8	(31)
(32)		MCDWB	-0.6	0.0	2.9	5.6	8.6	13.0	13.3	12.4	11.1	6.9	2.2	0.7	(32)	
(33)		10%	WB	-8.6	-7.7	-5.4	-2.4	1.5	5.9	7.3	7.0	5.2	0.0	-5.7	-7.7	(33)
(34)		MCDWB	-2.6	-1.4	1.3	4.7	7.7	12.0	12.6	11.7	10.3	5.9	1.0	-1.1	(34)	
(35)	Mean Daily Temperature Range		MDBR	10.1	9.5	9.9	10.3	10.0	9.9	8.7	8.5	9.3	10.0	10.4	10.7	(35)
(36)		5% DB	MCDBR	11.7	10.6	11.5	12.3	12.5	11.8	10.6	10.7	10.5	11.5	11.4	11.2	(36)
(37)		MCWBR	7.6	6.7	6.7	6.0	5.1	4.2	3.9	4.0	3.8	4.8	6.5	6.8	(37)	
(38)		5% WB	MCDBR	11.4	10.3	10.9	10.9	9.9	9.5	8.6	8.3	8.9	10.1	10.8	11.4	(38)
(39)		MCWBR	7.5	6.6	6.5	5.6	4.6	3.9	3.8	3.8	4.0	4.4	6.5	7.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.171	0.185	0.224	0.265	0.279	0.270	0.271	0.265	0.245	0.206	0.174	0.161	(40)	
(41)		taud	2.647	2.595	2.482	2.390	2.416	2.541	2.589	2.605	2.631	2.687	2.700	2.739	(41)	
(42)		Ebn at Noon	1114	1111	1072	1027	1006	1008	1006	1014	1034	1071	1101	1120	(42)	
(43)		Edh at Noon	72	85	104	120	118	104	98	95	89	77	68	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.85	4.71	5.85	6.55	7.04	7.11	6.40	5.96	5.76	5.21	4.37	3.84	(44)	
(45)		RadStd	0.38	0.40	0.38	0.35	0.37	0.36	0.37	0.37	0.32	0.36	0.27	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.53	N/A	-2.36	N/A	N/A	N/A	-248	-272	+35	N/A

Nomenclature: See separate page