

NAGQU, China

WMO: 552990

Lat: 31.4795N

Lon: 92.0612E

Elev: 4508

StdP: 57.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.4	(c) -20.5	(d) -35.5	(e) 0.2	(f) -11.0	(g) -33.8	(h) 0.3	(i) -9.9	(j) 14.4	(k) -0.1	(l) 12.5	(m) -2.2	(n) 0.6	(o) 20	(p) 0.772

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.3	(c) 18.2	(d) 7.0	(e) 17.0	(f) 7.0	(g) 15.9	(h) 6.8	(i) 9.1	(j) 14.9	(k) 8.6	(l) 14.3	(m) 8.2	(n) 13.6	(o) 3.4	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.9	10.9	11.3	6.4	10.5	10.9	5.9	10.2	10.5	41.2	15.1	39.6	14.5	38.2	13.8	16.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	8.5	7.2	-26.0	20.5	2.2	1.1	-27.6	21.3	-28.9	22.0	-30.1	22.6	-31.7	23.4
			-26.6	10.3	2.0	1.4	-28.1	11.3	-29.3	12.1	-30.4	12.8	-31.9	13.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.5	-10.4	-8.2	-4.5	-0.1	4.6	8.9	10.4	10.0	7.3	1.3	-5.2	-9.0
	DBStd	7.97	3.51	3.12	3.08	2.60	2.84	2.65	1.58	1.74	2.21	3.50	2.95	3.22
	HDD10.0	3547	633	509	451	303	170	49	14	21	83	269	456	588
	HDD18.3	6519	892	743	709	553	427	282	246	258	330	528	706	847
	CDD10.0	70	0	0	0	0	2	17	27	22	3	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	2.3	2.5	2.8	3.0	2.8	2.6	2.4	2.1	1.9	1.9	2.1	2.0	2.1
Precipitation	PrecAvg	424	3	2	3	10	26	83	104	97	71	18	3	2
	PrecMax	590	13	10	11	31	65	146	205	212	131	60	16	12
	PrecMin	299	0	0	0	0	0	25	37	12	27	0	0	0
	PrecStd	73	3	2	3	8	16	31	36	42	28	15	4	3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.3	10.2	12.7	18.3	20.4	19.1	19.1	17.2	14.7	7.7	6.0
		MCWB	-3.5	-3.9	-1.3	0.4	3.9	6.1	7.8	7.7	6.4	2.9	-2.5	-3.6
	2%	DB	2.3	3.2	6.9	10.7	15.6	18.1	17.6	17.7	15.5	12.0	5.4	3.3
		MCWB	-5.5	-5.0	-2.6	-0.3	3.1	6.4	7.9	7.7	6.1	2.2	-3.4	-5.0
	5%	DB	-0.4	1.5	4.7	8.8	13.3	16.5	16.3	16.4	14.1	10.0	3.7	1.1
		MCWB	-7.0	-6.0	-3.8	-1.3	2.2	6.4	7.6	7.5	5.9	1.2	-4.1	-6.0
	10%	DB	-2.5	-0.3	3.1	7.1	11.3	15.0	15.1	15.0	12.7	8.1	2.1	-0.9
		MCWB	-8.2	-7.0	-4.6	-1.9	1.6	6.3	7.6	7.2	5.6	0.3	-4.8	-7.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.3	-3.0	-0.5	1.8	6.1	9.2	10.0	9.7	8.4	4.7	-1.6	-3.0
		MCDB	4.7	4.1	8.5	9.3	13.8	15.6	15.4	15.7	14.3	10.9	5.1	4.7
	2%	WB	-5.2	-4.6	-2.2	0.5	4.7	8.4	9.2	9.0	7.5	3.7	-2.7	-4.7
		MCDB	1.6	2.3	5.8	7.9	11.1	14.8	14.8	14.9	13.3	9.6	3.7	2.7
	5%	WB	-6.7	-5.7	-3.3	-0.4	3.8	7.7	8.8	8.5	6.9	2.6	-3.6	-5.9
		MCDB	-0.7	0.9	3.7	6.9	10.2	14.0	14.3	14.1	12.4	7.9	2.6	0.7
	10%	WB	-8.1	-6.8	-4.3	-1.2	2.9	7.2	8.3	8.0	6.2	1.4	-4.5	-7.1
		MCDB	-2.9	-0.9	2.1	5.6	8.8	12.9	13.5	13.3	11.2	6.2	1.4	-1.2
Mean Daily Temperature Range	5% DB	MDBR	15.3	14.6	13.7	12.7	11.0	10.3	9.3	9.6	10.4	11.6	14.2	16.1
		MCDBR	18.9	18.0	16.6	16.1	14.8	13.1	11.4	12.2	12.4	14.4	16.8	19.2
		MCWBR	12.9	11.9	10.0	8.0	5.9	4.7	4.3	4.5	4.8	6.0	9.7	12.7
	5% WB	MCDBR	18.3	17.0	15.4	14.0	10.9	10.3	9.1	9.3	10.2	12.0	15.1	18.5
		MCWBR	12.8	11.5	9.5	7.6	5.1	4.3	3.9	3.9	4.4	5.3	9.1	12.6
Clear-Sky Solar Irradiance	taub		0.175	0.191	0.230	0.267	0.278	0.269	0.268	0.263	0.247	0.215	0.180	0.166
	taud		2.672	2.617	2.500	2.424	2.470	2.601	2.652	2.654	2.669	2.699	2.721	2.764
	Ebn at Noon		1107	1104	1065	1025	1007	1009	1009	1016	1032	1060	1092	1112
	Edh at Noon		71	83	102	116	112	98	92	91	86	76	67	61
All-Sky Solar Radiation	RadAvg		3.75	4.66	5.67	6.27	6.53	6.37	5.96	5.70	5.16	4.71	4.20	3.74
	RadStd		0.38	0.28	0.38	0.36	0.41	0.33	0.37	0.35	0.25	0.37	0.23	0.22

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.63	+0.96	-2.38	N/A	+0.27	N/A	-248	-272	+35	N/A	
(47) Regional (2 neighbors)		+0.59	N/A	-2.40	N/A	N/A	N/A	-248	-272	+35	N/A	

Nomenclature: See separate page