

XIGAZE, China

WMO: 555780

Lat: 29.2501N

Lon: 88.8887E

Elev: 12589

StdP: 9.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	9.3	-33.0	1.4	42.1	-28.9	1.8	41.5	19.1	44.7	16.3	44.1	0.5	200	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	22.0	75.5	48.7	73.3	48.6	71.3	48.4	53.9	66.0	53.1	65.2	52.4	64.4	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
50.0	86.8	57.0	49.2	84.0	56.7	48.4	81.6	56.5	28.4	66.4	27.8	65.5	27.2	64.7	57.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	12.7	10.8	DB	1.0	79.1	2.8	2.6	-1.1	81.0	-2.7	82.5	-4.3	84.0	-6.3	85.9	(4)
(5)			WB	-1.4	55.6	2.5	0.7	-3.2	56.0	-4.6	56.4	-6.0	56.8	-7.8	57.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.5	27.8	32.5	39.5	46.4	53.7	60.2	59.7	58.6	55.5	46.0	35.9	29.4		
	DBStd	12.59	6.02	5.73	5.40	4.99	4.98	3.86	3.33	2.81	3.02	5.43	4.37	5.60		
	HDD50	2873	689	491	330	131	21	0	0	0	2	146	425	638		
	HDD65	7129	1154	910	792	559	351	148	167	200	284	587	874	1103		
	CDD50	1224	0	0	3	22	135	307	301	265	168	23	0	0		
	CDD65	8	0	0	0	0	0	5	3	0	0	0	0	0		
	CDH74	142	0	0	0	0	15	82	40	4	1	0	0	0		
	CDH80	2	0	0	0	0	0	1	1	0	0	0	0	0		
	WSAvg	3.7	3.6	4.6	5.5	5.3	4.6	3.9	3.1	2.9	2.9	2.9	2.7	2.7		
	PrecAvg	17.0	0.0	0.0	0.0	0.1	0.6	2.4	5.2	6.0	2.4	0.2	0.0	0.0		
(15) Precipitation	PrecMax	29.6	0.3	0.2	0.4	0.5	2.8	8.8	11.4	15.2	7.4	1.1	0.5	0.0		
	PrecMin	8.5	0.0	0.0	0.0	0.0	0.0	0.2	1.1	1.8	0.2	0.0	0.0	0.0		
	PrecStd	4.5	0.1	0.0	0.1	0.1	0.6	1.8	2.0	3.0	1.5	0.3	0.1	0.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	59.1	65.4	69.2	75.8	79.1	78.2	74.5	72.1	68.4	60.2	56.8		
		MCWB	32.4	33.4	36.6	38.9	44.4	47.8	51.0	50.8	48.6	43.6	34.7	32.3		
	2%	DB	51.5	54.2	60.1	65.8	72.7	76.3	74.4	71.9	69.6	65.4	56.6	52.2		
		MCWB	29.7	30.8	34.0	37.7	43.4	48.2	50.7	50.8	48.2	42.1	32.7	30.1		
	5%	DB	47.0	50.6	56.3	62.7	69.9	74.1	71.7	69.8	67.5	63.0	53.9	48.8		
		MCWB	27.4	29.3	32.4	36.4	42.6	48.0	50.9	50.8	47.8	40.5	31.5	28.5		
	10%	DB	43.4	47.5	53.3	59.9	67.0	71.8	69.2	67.7	65.6	60.3	51.1	45.4		
		MCWB	25.5	27.9	31.0	35.2	41.6	47.6	50.9	50.8	47.5	39.1	30.4	26.9		
	0.4%	WB	32.5	34.0	36.6	41.1	49.3	53.9	55.0	54.9	52.7	46.5	36.2	33.4		
		MCDB	57.2	58.7	62.8	57.9	68.0	66.9	66.7	66.6	65.2	64.0	56.7	57.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	30.0	31.3	34.6	39.2	46.4	52.6	54.0	53.8	51.4	44.9	33.8	31.0		
		MCDB	51.6	53.9	57.6	62.3	63.6	66.2	66.2	65.4	64.0	61.7	53.1	53.0		
	5%	WB	28.0	29.7	32.9	37.7	44.8	51.5	53.4	52.9	50.5	43.3	32.3	29.3		
		MCDB	47.4	50.7	54.5	59.1	62.5	65.7	65.7	64.4	62.8	58.6	52.7	49.9		
	10%	WB	26.1	28.3	31.5	36.5	43.5	50.6	52.7	52.2	49.5	41.5	31.0	27.6		
		MCDB	44.0	47.6	51.8	56.9	61.3	65.2	64.8	63.5	61.6	55.9	51.0	46.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	30.7	28.1	26.2	24.9	23.8	22.0	18.7	18.6	21.1	28.6	33.1	33.4		
		MCDBR	35.3	32.6	30.2	28.5	27.4	25.2	23.2	22.0	24.0	30.3	36.1	36.7		
		MCWBR	20.0	16.9	13.2	10.2	7.4	7.1	6.0	6.0	7.1	10.4	17.8	20.0		
		MCDBR	35.6	32.2	28.2	27.0	22.1	19.8	18.0	17.7	19.1	25.1	35.4	37.9		
	5% WB	MCWBR	19.7	16.7	12.6	9.3	6.9	6.4	5.7	5.9	6.2	8.2	16.7	20.1		
(40) Clear-Sky Solar Irradiance	taub		0.183	0.201	0.241	0.291	0.297	0.297	0.297	0.291	0.271	0.228	0.190	0.176		
	taud		2.730	2.654	2.530	2.403	2.463	2.541	2.589	2.608	2.625	2.710	2.772	2.812		
	Ebn at Noon		351	348	335	318	314	312	311	314	320	333	345	351		
	Edh at Noon		22	26	32	38	36	33	31	30	29	24	21	19		
(44) All-Sky Solar Radiation	RadAvg		1390	1629	1914	2056	2163	2163	1868	1778	1780	1776	1541	1365		
	RadStd		83	125	101	126	122	143	125	81	97	83	67	57		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.61	N/A	N/A	N/A	N/A	N/A	N/A	-218	+184	+5
(47)	Regional (3 neighbors)	+0.61	N/A	-4.57	N/A	N/A	N/A	N/A	-238	+27	N/A

Nomenclature: See separate page