

XIGAZE, China

WMO: 555780

Lat: 29.2501N

Lon: 88.8887E

Elev: 3837

StdP: 62.96

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-12.6	-36.1	0.2	5.6	-33.8	0.3	5.3	8.5	7.1	7.3	6.7	0.2	200	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.2	24.2	9.3	23.0	9.2	21.8	9.1	12.2	18.9	11.7	18.5	11.3	18.0	2.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	12.4	13.9	9.6	12.0	13.7	9.1	11.7	13.6	48.2	19.1	46.7	18.6	45.4	18.2	14.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	5.7	4.9	-17.2	26.2	1.6	1.5	-18.4	27.2	-19.3	28.1	-20.2	28.9	-21.3	30.0		
(5)			-18.5	13.1	1.4	0.4	-19.5	13.4	-20.3	13.6	-21.1	13.8	-22.1	14.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-2.3	0.3	4.1	8.0	12.0	15.7	15.4	14.8	13.1	7.8	2.1	-1.4		
	DBStd	6.99	3.35	3.18	3.00	2.77	2.77	2.14	1.85	1.56	1.68	3.02	2.43	3.11		
	HDD10.0	1596	383	273	183	73	12	0	0	0	1	81	236	354		
	HDD18.3	3961	641	506	440	311	195	82	93	111	158	326	486	613		
	CDD10.0	680	0	0	2	12	75	171	167	147	93	13	0	0		
	CDD18.3	4	0	0	0	0	0	3	2	0	0	0	0	0		
	CDH23.3	79	0	0	0	0	8	46	22	2	1	0	0	0		
	CDH26.7	1	0	0	0	0	0	1	1	0	0	0	0	0		
(14) Wind	WSAvg	1.7	1.6	2.1	2.4	2.4	2.0	1.7	1.4	1.3	1.3	1.3	1.2	1.2		
(15) Precipitation	PrecAvg	432	1	0	1	2	14	62	131	153	61	6	1	0		
	PrecMax	752	8	6	10	13	72	223	290	386	189	28	12	1		
	PrecMin	217	0	0	0	0	1	4	29	45	6	0	0	0		
	PrecStd	114	2	1	2	3	14	45	52	75	38	7	2	0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	15.1	18.6	20.7	24.3	26.2	25.7	23.6	22.3	20.2	15.6	13.8		
		MCWB	0.2	0.8	2.5	3.8	6.9	8.8	10.6	10.4	9.2	6.5	1.5	0.2		
	2%	DB	10.8	12.3	15.6	18.8	22.6	24.6	23.6	22.2	20.9	18.6	13.7	11.2		
		MCWB	-1.3	-0.6	1.1	3.2	6.4	9.0	10.4	10.4	9.0	5.6	0.4	-1.1		
	5%	DB	8.4	10.4	13.5	17.1	21.1	23.4	22.1	21.0	19.7	17.2	12.2	9.3		
		MCWB	-2.6	-1.5	0.2	2.4	5.9	8.9	10.5	10.4	8.8	4.7	-0.3	-2.0		
	10%	DB	6.3	8.6	11.9	15.5	19.4	22.1	20.7	19.8	18.7	15.7	10.6	7.4		
		MCWB	-3.6	-2.3	-0.5	1.8	5.3	8.7	10.5	10.5	8.6	4.0	-0.9	-2.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.3	1.1	2.6	5.1	9.6	12.1	12.8	12.7	11.5	8.0	2.3	0.8		
		MCDB	14.0	14.8	17.1	14.4	20.0	19.4	19.3	19.2	18.5	17.8	13.7	14.2		
	2%	WB	-1.1	-0.4	1.5	4.0	8.0	11.5	12.2	12.1	10.8	7.1	1.0	-0.6		
		MCDB	10.9	12.2	14.2	16.8	17.5	19.0	19.0	18.5	17.8	16.5	11.7	11.6		
	5%	WB	-2.2	-1.3	0.5	3.2	7.1	10.9	11.9	11.6	10.3	6.3	0.2	-1.5		
		MCDB	8.5	10.4	12.5	15.0	16.9	18.7	18.7	18.0	17.1	14.8	11.5	9.9		
	10%	WB	-3.3	-2.0	-0.3	2.5	6.4	10.3	11.5	11.2	9.7	5.3	-0.6	-2.4		
		MCDB	6.6	8.7	11.0	13.8	16.3	18.4	18.2	17.5	16.4	13.3	10.5	8.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	15.6	14.6	13.8	13.2	12.2	10.4	10.3	11.7	15.9	18.4	18.5		
		MCDBR	19.6	18.1	16.8	15.9	15.2	14.0	12.9	12.2	13.4	16.8	20.0	20.4		
		MCWBR	11.1	9.4	7.3	5.7	4.1	3.9	3.3	3.3	3.9	5.8	9.9	11.1		
	5% WB	MCDBR	19.8	17.9	15.7	15.0	12.3	11.0	10.0	9.8	10.6	14.0	19.7	21.1		
		MCWBR	11.0	9.3	7.0	5.2	3.8	3.6	3.2	3.3	3.4	4.5	9.3	11.2		
(40) Clear-Sky Solar Irradiance	taub	0.183	0.201	0.241	0.291	0.297	0.297	0.297	0.297	0.291	0.271	0.228	0.190	0.176		
	taud	2.730	2.654	2.530	2.403	2.463	2.541	2.589	2.608	2.625	2.710	2.772	2.772	2.812		
	Ebn at Noon	1106	1097	1057	1002	989	983	981	989	1009	1051	1089	1107			
	Edh at Noon	69	83	101	119	113	104	99	96	91	77	66	61			
(44) All-Sky Solar Radiation	RadAvg	4.38	5.13	6.03	6.48	6.82	6.82	5.89	5.60	5.61	5.60	4.86	4.30			
	RadStd	0.26	0.39	0.32	0.40	0.39	0.45	0.39	0.26	0.31	0.26	0.21	0.18			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.34	N/A	N/A	N/A	N/A	N/A	N/A	-121	+102	+3
(47) Regional (3 neighbors)		+0.34	N/A	-2.54	N/A	N/A	N/A	N/A	-132	+15	N/A

Nomenclature: See separate page