

LHUNZE, China

WMO: 556960

Lat: 28.4135N

Lon: 92.4600E

Elev: 12667

StdP: 9.10

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	9.7	-18.7	3.2	34.1	-14.0	4.2	34.4	25.6	41.9	23.2	41.9	1.1	340	0.631

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	20.7	71.0	49.3	69.3	49.1	67.6	48.8	52.8	64.9	52.0	63.7	51.2	62.4	7.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
49.1	84.0	55.2	48.3	81.3	55.0	47.4	78.8	54.8	27.6	65.3	26.9	63.9	26.3	62.8	57.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	17.8	15.4	1.3	75.6	3.2	1.7	-1.0	76.8	-2.9	77.8	-4.7	78.8	-7.1	80.0		
(5)			-1.4	54.4	4.6	1.2	-4.7	55.3	-7.4	56.0	-10.0	56.7	-13.3	57.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	26.5	30.5	36.0	42.4	50.7	57.7	57.8	56.8	54.3	45.1	35.8	30.1		
	DBStd	11.90	4.50	4.25	4.05	3.89	4.52	3.09	2.67	2.85	2.94	5.29	3.92	4.61		
	HDD50	3201	727	547	433	229	47	1	0	1	4	167	427	618		
	HDD65	7771	1192	967	898	678	443	219	223	253	321	617	877	1083		
	CDD50	904	0	0	0	1	69	232	243	212	132	15	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	5	0	0	0	0	0	3	2	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	5.6	5.1	6.0	6.4	6.4	6.8	6.4	5.4	5.2	5.2	5.4	4.5	4.4		
	PrecAvg	10.6	0.0	0.0	0.1	0.2	0.6	1.7	3.1	3.1	1.6	0.2	0.1	0.0		
(15) Precipitation	PrecMax	16.3	0.0	0.2	0.4	0.8	1.3	4.7	6.4	5.9	3.4	0.9	0.6	0.5		
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.1	0.2	0.9	0.8	0.5	0.0	0.0	0.0		
	PrecStd	2.4	0.0	0.0	0.1	0.2	0.3	1.0	1.2	1.1	0.7	0.3	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	56.7	62.8	66.1	70.1	73.7	73.2	71.8	70.1	66.6	60.9	56.5		
		MCWB	33.3	34.5	38.0	42.9	46.1	49.2	51.0	50.8	48.9	43.7	36.7	33.9		
	2%	DB	49.4	52.1	57.0	61.1	67.4	71.3	70.1	69.3	67.5	63.7	56.6	51.7		
		MCWB	30.3	32.4	35.7	39.6	45.0	48.8	50.6	50.5	48.1	42.9	35.0	31.5		
	5%	DB	45.0	48.5	53.2	58.2	64.9	69.4	68.0	67.3	65.5	61.1	53.3	47.8		
		MCWB	28.4	30.9	34.0	38.0	43.8	48.8	50.6	50.3	47.5	41.4	33.7	30.0		
	10%	DB	41.4	45.0	50.0	55.3	62.3	67.5	65.9	65.2	63.6	58.2	50.1	44.1		
		MCWB	26.8	29.3	32.7	36.9	43.0	48.5	50.3	49.9	47.0	40.1	32.5	28.4		
	0.4%	WB	34.4	36.4	40.0	45.9	50.6	53.8	54.0	53.8	51.3	47.0	38.7	34.8		
		MCDB	51.9	52.5	58.4	60.8	65.0	67.5	65.8	66.3	64.0	60.5	54.9	53.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	31.1	33.6	37.3	41.8	47.9	52.2	52.9	52.4	50.1	45.5	36.5	32.3		
		MCDB	47.2	49.4	53.2	56.0	61.6	65.2	64.3	64.3	62.2	58.8	53.1	49.9		
	5%	WB	29.0	31.5	35.3	39.9	46.3	51.1	52.1	51.6	49.2	44.1	34.8	30.5		
		MCDB	43.7	46.6	50.1	53.7	59.8	63.6	63.3	62.9	60.9	56.5	50.6	46.5		
	10%	WB	27.1	29.7	33.5	38.3	44.8	50.2	51.3	50.8	48.4	42.7	33.3	28.8		
		MCDB	40.6	43.8	47.6	51.7	58.0	62.3	62.0	61.6	59.6	53.9	47.8	43.1		
	5% DB	MDBR	33.7	31.9	29.5	26.2	22.8	20.7	17.6	18.2	20.7	27.9	33.7	33.9		
		MCDBR	39.4	38.2	35.6	31.0	25.8	23.3	20.8	21.2	23.4	30.5	38.2	38.6		
		MCWBR	22.0	19.6	16.0	11.6	7.1	5.8	5.3	5.7	6.6	10.4	17.4	19.7		
		MCWBR	37.9	35.6	32.1	27.4	22.2	19.3	17.5	17.9	19.3	23.7	34.7	37.3		
(40) Clear-Sky Solar Irradiance	taub		0.225	0.263	0.332	0.351	0.315	0.302	0.298	0.300	0.285	0.252	0.229	0.211		
		taud	2.532	2.421	2.206	2.216	2.425	2.552	2.591	2.569	2.579	2.638	2.601	2.631		
	Ebn at Noon		331	323	303	299	308	310	311	312	316	324	328	334		
		Edh at Noon	27	34	45	46	37	33	31	32	30	27	25	23		
(44) All-Sky Solar Radiation	RadAvg		1259	1405	1551	1657	1766	1702	1557	1525	1475	1532	1383	1253		
	RadStd		71	82	101	95	89	93	93	102	82	98	104	75		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	-1.03	-6.12	+0.61	N/A	+0.79	N/A	N/A	N/A	N/A	
(47) Regional (1 neighbor)		+0.63	N/A	-6.16	N/A	N/A	N/A	-238	-457	+270	+32	

Nomenclature: See separate page