

MADOI, China

WMO: 560330

Lat: 34.9172N

Lon: 98.2158E

Elev: 14019

StdP: 8.63

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-11.4	-30.5	1.7	-0.7	-26.9	2.1	1.5	29.2	21.0	26.2	21.9	1.7	40	0.857

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	63.5	46.1	60.3	44.6	57.7	43.5	48.7	58.9	47.4	56.8	45.9	54.5	7.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
44.7	75.0	53.1	43.4	71.2	51.8	42.1	67.7	50.7	25.2	59.0	24.2	57.2	23.2	54.6	55.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.6	20.3	17.3	DB	-22.1	69.0	3.8	2.8	-24.8	71.0	-27.0	72.6	-29.1	74.2	-31.8	76.2	(4)
(5)			WB	-22.7	51.2	3.6	1.5	-25.3	52.3	-27.4	53.2	-29.4	54.0	-32.0	55.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	6.2	11.9	19.2	29.1	36.6	43.0	47.7	47.6	41.2	29.3	16.2	8.0		
	DBStd	15.83	6.64	6.54	6.50	5.58	4.75	4.61	4.59	4.93	5.50	6.24	6.32	6.43		
	HDD50	8073	1359	1066	956	628	415	215	100	108	269	642	1013	1302		
	HDD65	13476	1824	1486	1421	1078	880	660	535	540	715	1107	1463	1767		
	CDD50	72	0	0	0	0	0	5	30	33	4	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	6.8	5.6	6.8	7.6	7.8	7.9	7.6	7.4	7.1	6.4	6.2	5.5	5.2		
	PrecAvg	12.2	0.1	0.2	0.3	0.4	1.1	2.2	2.8	2.4	1.9	0.7	0.1	0.1		
(15) Precipitation	PrecMax	19.4	0.4	0.4	0.8	0.9	2.4	4.7	5.8	6.0	4.8	1.8	0.4	0.4		
	PrecMin	7.2	0.0	0.0	0.0	0.1	0.1	0.3	1.4	0.5	0.4	0.1	0.0	0.0		
	PrecStd	2.7	0.1	0.1	0.2	0.2	0.5	1.0	1.0	1.3	0.9	0.4	0.1	0.1		
	PrecStd	2.7	0.1	0.1	0.2	0.2	0.5	1.0	1.0	1.3	0.9	0.4	0.1	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.5	37.7	44.9	52.7	58.2	62.2	67.9	68.2	62.3	54.4	38.2	33.1		
		MCWB	19.5	23.2	27.2	32.3	37.8	44.8	48.8	46.8	45.4	37.8	24.4	20.8		
	2%	DB	26.9	32.4	39.3	48.2	53.7	58.4	63.5	63.7	57.7	47.1	34.8	28.2		
		MCWB	17.1	20.1	24.7	30.5	35.6	42.7	46.6	46.0	43.3	33.9	22.9	17.6		
	5%	DB	23.0	29.0	35.7	44.6	50.2	55.5	60.4	60.3	54.2	42.6	31.8	24.6		
		MCWB	14.6	18.3	22.8	28.8	34.0	40.8	45.0	45.1	42.1	31.3	21.3	15.5		
	10%	DB	19.3	25.5	32.2	41.0	47.0	52.6	57.4	57.2	50.7	39.3	28.7	21.2		
		MCWB	12.3	16.5	21.3	27.2	32.9	39.9	44.3	43.9	40.1	29.7	19.7	13.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	23.5	28.3	34.6	41.2	48.4	51.3	50.4	47.9	40.4	25.9	21.3		
		MCDB	30.6	35.8	41.4	47.3	51.9	58.1	62.9	61.3	57.4	50.7	35.9	32.1		
	2%	WB	17.3	20.7	25.6	32.0	38.5	46.0	49.2	48.5	45.5	36.0	23.8	18.0		
		MCDB	26.1	31.2	36.9	43.0	48.1	54.8	59.5	58.8	54.7	43.9	32.8	27.6		
	5%	WB	14.9	18.8	23.7	30.1	36.5	44.1	47.7	47.2	43.6	33.4	22.0	15.7		
		MCDB	22.3	28.1	33.9	41.3	45.9	51.7	57.1	56.8	52.0	39.9	30.5	23.9		
	10%	WB	12.5	16.8	21.8	28.4	34.9	42.1	46.2	45.8	41.9	30.9	20.3	13.7		
		MCDB	18.8	24.9	31.1	39.1	43.5	49.2	54.3	54.5	49.2	37.6	28.0	20.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	25.1	24.5	23.2	21.0	18.4	16.4	16.8	17.4	17.0	17.8	23.1	25.5		
		MCDBR	28.9	28.9	27.7	26.3	24.5	21.1	21.7	21.5	20.8	21.6	25.5	28.8		
		MCWBR	21.1	19.4	16.7	13.0	11.1	9.2	8.8	8.6	9.4	11.0	16.0	20.5		
		MCDBR	27.5	27.1	25.0	22.7	18.5	16.9	17.0	17.0	17.4	18.2	23.5	27.9		
	5% WB	MCWBR	20.4	18.7	15.4	12.1	9.5	8.6	8.0	7.5	8.5	10.2	15.3	20.2		
(40) Clear-Sky Solar Irradiance	taub		0.186	0.214	0.264	0.300	0.310	0.295	0.284	0.278	0.259	0.236	0.198	0.180		
	taud		2.571	2.490	2.340	2.257	2.320	2.467	2.561	2.571	2.599	2.589	2.587	2.613		
	Ebn at Noon		340	336	322	312	308	311	314	316	320	323	332	338		
	Edh at Noon		23	29	37	43	41	35	32	31	29	26	23	21		
(44) All-Sky Solar Radiation	RadAvg		1037	1289	1643	1962	2030	1991	2055	1914	1603	1371	1179	995		
	RadStd		88	84	92	82	121	136	129	146	128	72	56	54		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.74	N/A	N/A	N/A	N/A	N/A	-239	-288	N/A	N/A
(47)	Regional (2 neighbors)	+0.61	N/A	N/A	N/A	N/A	N/A	-198	-230	N/A	N/A

Nomenclature: See separate page