

DARLAG, China

WMO: 560460

Lat: 33.7577N

Lon: 99.6474E

Elev: 13018

StdP: 8.98

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-7.4	-24.7	2.3	1.6	-21.2	2.8	6.0	29.5	27.7	24.6	26.0	1.1	200	0.759

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	66.5	49.7	63.7	48.7	61.2	47.6	52.1	62.8	50.8	60.6	49.5	58.3	5.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
48.1	81.9	56.6	46.9	78.3	55.2	45.8	75.0	54.2	27.3	63.2	26.2	60.9	25.2	58.6	57.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	17.4	14.2	DB	-19.1	71.5	4.6	1.9	-22.4	72.9	-25.1	74.0	-27.7	75.1	-31.1	76.5
			WB	-19.8	54.9	4.5	1.1	-23.0	55.7	-25.6	56.4	-28.1	57.0	-31.3	57.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	12.2	17.5	24.8	34.3	41.0	47.2	51.1	50.5	45.2	34.4	22.7	13.6	(6)
(7)		DBStd	14.83	6.67	6.52	6.01	5.14	4.55	4.54	4.06	4.28	5.12	5.69	5.62	6.70	(7)
(8)		HDD50	6392	1171	910	780	471	281	108	36	48	156	484	819	1128	(8)
(9)		HDD65	11695	1636	1330	1245	921	744	535	430	450	593	949	1269	1593	(9)
(10)		CDD50	173	0	0	0	0	2	23	71	63	14	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.7	4.5	5.2	5.7	5.7	5.3	4.9	4.6	4.3	4.2	4.2	4.3	3.9	(14)
(15)	Precipitation	PrecAvg	21.5	0.2	0.2	0.5	0.9	2.2	4.1	4.4	3.9	3.5	1.3	0.2	0.1	(15)
(16)		PrecMax	27.5	0.7	0.8	1.2	1.9	3.3	5.9	9.1	7.4	7.8	2.8	0.6	0.3	(16)
(17)		PrecMin	16.4	0.0	0.0	0.1	0.3	0.9	2.0	2.0	1.6	1.7	0.5	0.0	0.0	(17)
(18)		PrecStd	2.9	0.2	0.2	0.3	0.4	0.6	1.1	1.7	1.3	1.6	0.6	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.9	43.5	49.5	57.7	62.7	65.7	69.9	70.0	66.9	59.3	45.0	40.5	(19)
(20)		0.4%	MCWB	23.8	26.7	30.5	36.0	42.7	49.5	51.7	50.8	48.2	41.7	28.7	25.4	(20)
(21)		2%	DB	33.8	38.4	44.2	52.5	57.9	62.0	66.4	66.4	61.8	51.9	41.3	35.3	(21)
(22)		2%	MCWB	21.7	24.2	28.2	34.3	40.5	47.6	50.4	49.8	47.3	38.2	27.0	22.5	(22)
(23)		5%	DB	30.2	35.0	40.7	49.1	54.7	59.2	63.5	63.4	58.3	47.8	38.2	31.5	(23)
(24)		5%	MCWB	19.5	22.7	26.8	32.9	38.9	46.2	49.3	49.0	46.0	35.8	25.8	20.4	(24)
(25)		10%	DB	26.5	31.5	37.3	45.8	51.4	56.4	60.8	60.4	54.9	44.4	35.0	27.9	(25)
(26)		10%	MCWB	17.5	21.0	25.4	31.6	38.0	45.2	48.4	47.8	44.2	34.1	24.4	18.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	27.2	31.7	38.7	46.3	52.3	54.0	54.1	50.9	44.1	30.1	26.1	(27)
(28)		0.4%	MCDWB	36.6	40.9	45.9	51.4	59.1	62.9	65.2	64.4	61.7	56.0	40.5	39.7	(28)
(29)		2%	WB	22.1	24.9	29.6	36.2	43.4	49.9	52.3	51.9	49.0	40.8	28.4	23.0	(29)
(30)		2%	MCDWB	32.8	36.4	41.3	48.0	53.6	59.3	63.0	62.8	58.5	49.2	38.6	34.3	(30)
(31)		5%	WB	19.9	23.4	27.9	34.4	41.4	48.2	51.1	50.5	47.3	38.2	26.8	20.8	(31)
(32)		5%	MCDWB	29.2	33.6	37.8	45.4	50.3	56.3	60.8	60.4	55.8	45.0	36.2	30.5	(32)
(33)		10%	WB	17.9	21.6	26.4	32.8	39.5	46.6	49.7	49.2	45.6	35.8	25.1	18.8	(33)
(34)		10%	MCDWB	26.0	30.8	35.7	43.0	47.9	54.0	58.1	58.0	53.1	41.9	33.9	27.4	(34)
(35)	Mean Daily Temperature Range		MDBR	28.0	25.7	22.5	19.5	18.3	16.5	18.1	19.3	18.8	18.8	24.6	28.4	(35)
(36)		5% DB	MCDBR	32.8	31.2	28.3	25.9	25.0	20.6	23.4	24.4	23.7	24.0	28.3	32.5	(36)
(37)			MCWBR	22.5	19.8	15.5	11.2	10.3	9.2	10.5	10.9	11.2	11.8	16.4	21.6	(37)
(38)			MCDBR	30.8	28.2	23.7	22.0	19.5	16.9	18.5	19.4	19.7	20.1	25.0	31.2	(38)
(39)		5% WB	MCWBR	21.4	18.3	13.4	10.3	9.3	8.7	9.0	9.7	10.0	10.4	14.7	21.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.203	0.231	0.286	0.314	0.314	0.296	0.288	0.283	0.262	0.242	0.210	0.191	(40)	
(41)		taud	2.568	2.483	2.311	2.269	2.366	2.531	2.596	2.595	2.640	2.614	2.610	2.630	(41)	
(42)		Ebn at Noon	334	330	315	308	307	311	313	315	320	322	328	335	(42)	
(43)		Edh at Noon	24	30	39	43	39	33	31	30	28	26	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1090	1334	1705	1981	1930	1833	1951	1816	1515	1324	1218	1045	(44)	
(45)		RadStd	92	95	96	114	102	151	116	168	125	78	61	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.95	+1.80	N/A	+1.10	N/A	N/A	-322	-394	+72	N/A
(47)	Regional (3 neighbors)	+0.86	+1.37	N/A	N/A	N/A	N/A	-290	-331	+41	N/A

Nomenclature: See separate page