

HEZUO, China

WMO: 560800

Lat: 34.9910N

Lon: 102.9048E

Elev: 2910

StdP: 70.91

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.4	-17.6	-29.3	0.4	-7.2	-27.3	0.4	-7.6	8.7	1.2	7.1	0.8	0.5	340	0.642

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	23.5	13.3	21.9	12.5	20.4	11.8	15.3	20.5	14.4	19.2	13.5	18.0	2.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	13.9	17.6	12.7	13.1	16.7	11.8	12.4	15.9	54.7	20.5	51.5	19.4	48.6	18.0	18.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 6.9	5.7	4.8		-23.2	26.8	2.1	1.2	-24.7	27.7	-25.9	28.4	-27.1	29.1	-28.5	30.0	
(5)			DB	-23.7	16.6	1.9	0.9	-25.1	17.2	-26.2	17.8	-27.3	18.3	-28.6	19.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.1	-7.8	-4.6	0.1	5.0	8.5	11.7	14.0	13.8	10.3	5.0	-1.0	-6.3
	DBStd	8.06	3.11	3.56	3.48	3.27	2.76	2.34	2.39	2.57	2.88	2.74	3.21	2.70
	HDD10.0	2514	551	410	308	154	62	9	1	2	29	155	329	504
	HDD18.3	5198	809	643	566	402	305	200	134	143	243	412	579	762
	CDD10.0	360	0	0	0	2	16	59	126	119	37	1	0	0
	CDD18.3	3	0	0	0	0	0	0	1	1	1	0	0	0
	CDH23.3	51	0	0	0	1	1	2	26	17	4	0	0	0
	CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0
	WSAvg	1.6	1.3	1.6	1.9	2.0	2.0	1.7	1.6	1.6	1.6	1.5	1.3	1.2
	PrecAvg	549	3	5	15	34	74	74	111	106	78	40	7	1
(15) Precipitation	PrecMax	800	7	12	36	63	177	158	180	214	121	89	19	7
	PrecMin	374	0	0	0	10	32	30	49	39	21	12	1	0
	PrecStd	98	2	3	8	14	34	32	36	44	29	18	5	2
	PrecStd	98	2	3	8	14	34	32	36	44	29	18	5	2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	12.4	16.5	20.5	21.8	23.0	25.6	25.2	23.2	18.1	13.2	8.6
		MCWB	-1.5	0.6	3.6	6.7	8.2	12.3	14.1	14.3	13.7	7.3	2.7	-1.0
	2%	DB	5.2	8.7	12.7	17.3	19.3	20.9	23.8	23.2	20.0	15.0	10.6	5.7
		MCWB	-3.0	-0.8	1.9	5.4	8.2	11.3	13.6	13.5	11.4	6.3	1.1	-2.5
	5%	DB	2.9	5.9	10.1	14.9	17.5	19.3	22.1	21.6	17.9	12.8	8.6	3.7
		MCWB	-4.2	-2.2	0.9	4.7	7.6	10.7	13.0	13.1	10.4	5.3	0.4	-3.5
	10%	DB	0.3	3.3	7.6	12.6	15.5	17.8	20.4	19.7	15.9	10.8	6.4	1.6
		MCWB	-5.5	-3.2	-0.1	4.0	7.1	10.0	12.6	12.6	9.8	4.7	-0.6	-4.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.1	1.1	4.7	8.8	11.3	14.8	16.3	16.6	15.5	9.4	3.5	-0.9
		MCDB	7.8	11.5	14.8	17.3	17.4	19.5	22.4	22.6	20.1	14.8	10.8	7.4
	2%	WB	-2.8	-0.6	2.7	6.8	9.9	13.3	15.2	15.3	13.4	7.7	2.1	-2.3
		MCDB	4.8	7.9	10.6	14.1	15.8	17.6	20.8	20.5	17.9	12.3	8.5	5.1
	5%	WB	-4.2	-1.8	1.4	5.7	8.7	12.2	14.4	14.4	12.0	6.6	0.9	-3.3
		MCDB	2.5	5.2	8.5	12.8	14.6	16.3	19.4	19.0	16.1	10.9	6.8	3.3
	10%	WB	-5.5	-3.1	0.2	4.7	7.8	11.2	13.5	13.5	10.7	5.5	-0.1	-4.5
		MCDB	0.1	3.0	6.6	11.2	13.8	15.8	18.2	17.9	14.3	9.4	5.5	1.3
(35) Mean Daily Temperature Range	5% DB	MDBR	16.4	15.5	13.5	12.9	11.9	10.9	11.0	11.1	10.3	11.2	14.4	16.6
		MCDBR	20.6	20.2	18.6	17.9	16.4	14.6	15.0	14.5	14.3	14.9	17.7	19.7
		MCWBR	13.6	12.0	9.2	7.6	6.6	5.9	5.8	5.8	6.1	6.8	9.2	12.5
	5% WB	MCDBR	19.7	18.7	15.8	15.0	13.3	11.1	11.5	11.4	11.3	12.0	15.2	18.7
		MCWBR	13.2	11.3	8.2	7.0	6.0	5.0	4.8	4.9	5.4	6.1	8.1	11.9
(40) Clear-Sky Solar Irradiance	taub		0.273	0.319	0.381	0.419	0.411	0.401	0.390	0.389	0.363	0.323	0.275	0.250
	taud		2.369	2.219	2.036	1.978	2.097	2.206	2.295	2.282	2.335	2.387	2.441	2.472
	Ebn at Noon		937	919	883	866	875	881	888	884	894	906	930	951
	Edh at Noon		93	122	160	179	161	144	131	130	117	102	85	78
(44) All-Sky Solar Radiation	RadAvg		3.23	3.95	4.82	5.46	5.51	5.31	5.47	5.09	4.02	3.74	3.36	3.08
	RadStd		0.21	0.22	0.28	0.28	0.26	0.39	0.58	0.43	0.34	0.35	0.20	0.11

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.40	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page