

QAMDO, China

WMO: 561370

Lat: 31.1475N

Lon: 97.1737E

Elev: 10880

StdP: 9.77

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	13.7	-16.5	3.4	32.3	-12.8	4.1	32.6	14.2	43.3	12.0	44.3	0.6	270	0.507

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	81.0	54.6	78.5	54.1	76.0	53.5	58.4	71.9	57.4	70.7	56.5	69.2	4.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.5	95.8	62.1	53.6	92.6	61.0	52.7	89.6	60.5	31.1	72.1	30.3	70.8	29.5	69.5	63.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.6	7.8	DB	5.3	86.0	1.9	1.9	3.9	87.4	2.8	88.5	1.7	89.6	0.3	90.9	(4)
(5)			WB	2.4	60.3	1.6	1.7	1.3	61.5	0.3	62.5	-0.6	63.5	-1.7	64.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	31.2	35.5	41.2	47.8	55.3	61.2	62.9	61.9	57.9	48.6	39.3	32.5	(6)
(7)		DBStd	12.23	4.76	4.67	4.50	4.33	5.22	4.85	4.09	3.87	4.26	5.35	4.20	4.23	(7)
(8)		HDD50	2327	583	406	277	91	11	1	0	0	2	92	320	544	(8)
(9)		HDD65	6261	1048	826	739	515	303	132	90	107	215	507	770	1009	(9)
(10)		CDD50	1598	0	0	2	26	175	336	400	370	239	50	0	0	(10)
(11)		CDD65	56	0	0	0	0	2	17	24	12	1	0	0	0	(11)
(12)		CDH74	983	0	0	0	2	74	282	302	242	76	5	0	0	(12)
(13)		CDH80	116	0	0	0	0	4	41	39	27	5	0	0	0	(13)
(14)	Wind	WSAvg	2.5	2.3	2.6	3.0	3.1	3.3	2.9	2.5	2.4	2.2	2.3	1.9	1.8	(14)
(15)	Precipitation	PrecAvg	18.6	0.0	0.2	0.4	0.7	1.6	3.6	4.1	3.9	3.0	1.1	0.2	0.1	(15)
(16)		PrecMax	25.7	0.3	0.8	0.9	2.4	4.1	6.4	7.8	9.5	6.2	2.7	0.9	0.7	(16)
(17)		PrecMin	12.2	0.0	0.0	0.0	0.1	0.1	1.4	1.8	1.1	0.3	0.0	0.0	0.0	(17)
(18)		PrecStd	3.6	0.1	0.2	0.3	0.5	0.9	1.3	1.4	2.1	1.1	0.7	0.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	60.1	66.0	72.0	79.8	84.3	83.9	83.2	79.9	73.7	63.5	57.3	(19)
MCWB			35.2	36.4	41.2	44.5	50.8	54.3	56.0	55.1	53.9	48.6	39.1	35.0	(20)	
2%		DB	52.2	55.8	60.9	67.8	76.0	80.4	80.5	79.8	76.0	69.6	59.3	53.0	(21)	
		MCWB	32.3	34.5	38.3	43.1	49.0	53.4	56.0	55.2	53.2	47.6	37.4	33.0	(22)	
5%		DB	48.4	52.6	57.3	64.1	72.8	77.2	77.4	76.7	73.0	65.7	56.2	49.4	(23)	
		MCWB	30.5	32.9	36.5	41.6	47.9	53.1	55.6	54.7	52.9	45.7	36.0	31.3	(24)	
10%		DB	44.8	49.2	54.2	60.9	69.1	73.9	74.2	73.4	69.6	61.7	52.9	45.9	(25)	
		MCWB	28.8	31.4	35.3	40.3	46.7	52.4	55.3	54.5	52.2	44.1	34.7	29.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.0	37.8	42.3	46.7	54.2	58.3	60.4	59.4	57.5	51.5	40.8	35.6	(27)
MDCB			56.0	56.6	62.1	66.3	73.7	73.3	74.7	72.2	70.5	67.9	57.3	55.7	(28)	
2%		WB	32.7	35.5	39.4	44.7	51.2	56.7	58.9	58.1	56.0	49.5	38.6	33.3	(29)	
		MDCB	50.8	53.2	57.4	63.4	69.5	71.4	72.6	71.2	69.2	65.3	55.0	51.9	(30)	
5%		WB	30.7	33.4	37.7	43.1	49.6	55.7	57.8	57.0	54.7	47.7	37.1	31.5	(31)	
		MDCB	47.4	50.3	53.9	59.7	67.3	69.9	70.9	70.0	67.4	61.8	52.6	48.1	(32)	
10%		WB	28.9	31.9	36.2	41.7	48.2	54.6	56.7	56.0	53.5	45.7	35.5	29.9	(33)	
		MDCB	43.9	47.7	51.2	57.0	65.2	68.0	69.1	68.3	65.2	57.6	50.6	44.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	30.0	27.8	25.5	24.4	24.0	22.0	21.2	21.8	22.9	25.1	29.3	31.0	(35)	
MCDBR			35.5	34.4	31.2	31.1	29.6	28.6	27.9	29.3	29.6	31.6	34.9	35.8	(36)	
MCWBR			19.9	18.1	14.4	12.7	9.7	8.6	8.2	8.5	10.0	12.3	16.4	19.5	(37)	
5% WB		MCDBR	34.3	31.3	27.6	26.4	25.3	22.2	20.8	21.1	23.0	26.8	31.3	34.3	(38)	
		MCWBR	19.4	16.8	12.9	10.6	9.1	7.4	7.2	7.2	8.4	10.9	15.0	18.9	(39)	
		MCWBR	19.4	16.8	12.9	10.6	9.1	7.4	7.2	7.2	8.4	10.9	15.0	18.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.233	0.271	0.331	0.347	0.324	0.306	0.307	0.307	0.283	0.256	0.231	0.217	(40)	
taud		2.536	2.436	2.245	2.251	2.416	2.580	2.609	2.587	2.634	2.645	2.622	2.622	(41)		
Ebn at Noon		324	317	301	299	305	309	308	308	315	320	323	327	(42)		
Edh at Noon		26	32	42	44	37	32	30	31	28	26	24	23	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1287	1497	1783	2009	2050	1841	1747	1667	1559	1409	1351	1223	(44)	
(45)		RadStd	92	93	122	146	137	108	104	139	93	68	73	64	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.58	+0.90	-3.24	N/A	N/A	N/A	N/A	-277	+220	+36
(47) Regional (2 neighbors)		+0.54	N/A	-3.24	N/A	N/A	N/A	N/A	-281	+144	N/A

Nomenclature: See separate page