

DAWU, China

WMO: 561670

Lat: 30.9714N

Lon: 101.1186E

Elev: 9874

StdP: 10.16

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.2	13.7	-8.6	5.0	40.6	-5.5	5.9	38.1	20.2	39.4	16.1	41.0	1.0	290	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	80.6	57.1	78.0	56.2	75.5	55.5	60.3	73.6	59.2	72.0	58.3	70.2	4.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.4	98.9	64.2	55.5	95.4	63.3	54.6	92.3	62.4	32.1	73.8	31.2	72.4	30.3	70.3	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.1	14.4	11.7	DB	6.3	86.2	2.0	2.3	4.9	87.8	3.7	89.1	2.6	90.4	1.2	92.1	
			WB	4.1	62.8	1.7	1.3	2.9	63.7	1.9	64.5	0.9	65.2	-0.4	66.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	32.3	37.4	43.2	50.0	56.7	60.9	63.4	63.1	59.0	50.1	39.8	32.3
	DBStd	12.12	4.64	4.53	4.46	4.55	4.87	4.22	3.71	3.84	4.51	5.27	4.38	4.14
	HDD50	2098	549	354	216	54	5	0	0	0	2	64	307	547
	HDD65	5877	1014	774	676	451	260	132	74	83	183	462	756	1012
	CDD50	1760	0	0	4	53	212	328	415	406	273	68	1	0
	CDD65	64	0	0	0	0	3	10	24	23	4	0	0	0
	CDH74	853	0	0	3	10	95	128	230	283	97	7	0	0
	CDH80	92	0	0	0	0	7	16	24	38	7	0	0	0
Wind	WSAvg	3.6	2.8	3.4	4.5	4.6	4.7	3.9	3.5	3.6	3.6	3.3	2.5	2.2
Precipitation	PrecAvg	23.5	0.0	0.1	0.4	0.9	2.4	5.2	4.6	3.9	4.3	1.5	0.2	0.1
	PrecMax	31.9	0.3	0.5	1.9	2.2	5.4	9.3	6.9	6.5	6.9	3.3	0.7	0.7
	PrecMin	16.0	0.0	0.0	0.0	0.3	0.6	2.6	2.0	0.8	1.3	0.1	0.0	0.0
	PrecStd	3.7	0.1	0.1	0.4	0.5	1.1	1.7	1.3	1.7	1.4	0.9	0.2	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.2	65.1	69.7	75.4	80.6	82.0	83.2	83.9	80.7	74.6	64.2	58.4
		MCWB	37.0	39.3	42.9	47.6	54.0	57.6	58.6	58.0	57.0	53.5	42.1	37.7
	2%	DB	54.5	60.1	64.4	70.5	76.5	77.6	79.5	80.5	76.8	69.9	60.1	53.4
		MCWB	34.2	37.2	40.4	45.5	51.0	56.7	58.2	57.2	55.9	51.2	40.5	34.8
	5%	DB	50.7	56.2	60.7	67.0	73.1	74.4	76.5	77.3	73.2	65.9	57.0	49.6
		MCWB	32.3	35.5	39.1	44.4	50.4	55.8	57.5	56.8	55.2	49.0	39.4	32.7
	10%	DB	46.8	52.3	57.7	63.8	69.7	71.1	73.4	73.8	69.3	61.8	53.5	46.2
		MCWB	30.5	33.7	37.9	43.3	49.5	55.4	57.0	56.1	54.3	47.2	37.6	31.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.7	40.2	44.3	50.2	57.1	61.6	61.9	61.2	59.4	55.1	44.7	38.3
		MCDB	58.5	61.0	64.0	69.8	73.4	74.5	75.2	75.2	73.8	69.9	58.4	56.7
	2%	WB	34.6	37.8	42.0	47.7	54.4	59.6	60.5	59.5	58.0	53.0	42.3	35.4
		MCDB	53.1	57.7	60.1	64.5	71.1	71.9	73.9	73.2	71.3	67.0	56.7	51.8
	5%	WB	32.6	36.0	40.4	46.2	52.7	58.2	59.4	58.4	56.7	50.8	40.2	33.3
		MCDB	49.3	53.8	57.1	62.7	68.2	69.6	71.8	71.6	68.9	62.3	54.5	48.2
	10%	WB	30.8	34.4	39.0	44.7	51.2	56.9	58.5	57.4	55.4	48.7	38.4	31.5
		MCDB	45.7	50.1	54.4	60.0	65.2	67.4	69.6	69.6	66.6	58.9	51.4	45.1
Mean Daily Temperature Range	5% DB	MDBR	32.5	31.8	28.1	25.7	23.9	20.4	20.4	21.6	21.1	23.8	29.0	31.2
		MCDBR	38.3	39.8	35.0	32.8	30.0	26.4	26.7	28.6	27.7	29.6	34.2	35.8
		MCWBR	20.5	19.9	15.3	12.5	10.0	8.8	8.4	8.9	9.8	12.4	16.9	19.2
	5% WB	MCDBR	36.9	36.5	29.8	26.0	25.0	20.9	20.8	21.9	22.3	25.0	31.9	33.8
		MCWBR	20.0	18.2	13.0	10.0	9.3	8.0	7.4	7.6	8.6	10.8	16.0	18.4
Clear-Sky Solar Irradiance	taub	0.243	0.282	0.352	0.373	0.352	0.340	0.356	0.360	0.318	0.275	0.246	0.229	
	taud	2.547	2.439	2.203	2.200	2.367	2.490	2.451	2.423	2.531	2.615	2.613	2.616	
	Ebn at Noon	320	313	294	291	297	298	293	292	303	313	317	322	
	Edh at Noon	26	32	44	46	39	35	36	36	31	27	24	23	
All-Sky Solar Radiation	RadAvg	1254	1458	1736	1932	1920	1666	1663	1608	1468	1352	1277	1199	
	RadStd	79	93	127	135	152	146	128	193	107	72	76	63	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.75	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.74	+0.99	-1.98	+1.03	N/A	N/A	-142	-270	+178	+16

Nomenclature: See separate page