

DAWU, China

WMO: 561670

Lat: 30.9714N

Lon: 101.1186E

Elev: 3010

StdP: 70.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-10.2	-22.5	0.7	4.8	-20.8	0.8	3.4	9.0	4.1	7.2	5.0	0.4	290	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	27.0	14.0	25.6	13.4	24.2	13.0	15.7	23.1	15.1	22.2	14.6	21.2	2.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.6	14.1	17.9	13.0	13.6	17.4	12.5	13.2	16.9	56.8	23.2	54.6	22.4	52.7	21.3	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.1	6.4	5.2	-14.3	30.1	1.1	1.3	-15.1	31.0	-15.7	31.7	-16.3	32.5	-17.1	33.4
			-15.5	17.1	1.0	0.7	-16.2	17.6	-16.7	18.1	-17.3	18.5	-18.0	19.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	0.2	3.0	6.2	10.0	13.7	16.1	17.4	17.3	15.0	10.1	4.3	0.2		
	DBStd	6.73	2.58	2.52	2.48	2.53	2.70	2.34	2.06	2.13	2.51	2.93	2.43	2.30		
	HDD10.0	1166	305	197	120	30	3	0	0	0	1	36	171	304		
	HDD18.3	3265	563	430	376	251	144	73	41	46	102	257	420	562		
	CDD10.0	978	0	0	2	29	118	182	231	226	152	38	1	0		
	CDD18.3	36	0	0	0	0	2	6	13	13	2	0	0	0		
	CDH23.3	474	0	0	2	6	53	71	128	157	54	4	0	0		
	CDH26.7	51	0	0	0	0	4	9	13	21	4	0	0	0		
(14) Wind	WSAvg	1.6	1.2	1.5	2.0	2.1	2.1	1.8	1.6	1.6	1.6	1.5	1.1	1.0		
(15) Precipitation	PrecAvg	596	1	3	9	24	60	131	116	99	108	37	4	2		
	PrecMax	811	8	12	48	55	138	236	175	166	176	83	17	18		
	PrecMin	407	0	0	0	0	7	15	66	52	20	32	2	0		
	PrecStd	95	2	3	9	12	28	42	34	42	36	22	4	4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.7	18.4	20.9	24.1	27.0	27.8	28.4	28.8	27.0	23.7	17.9	14.7		
		MCWB	2.8	4.1	6.1	8.7	12.2	14.2	14.8	14.5	13.9	12.0	5.6	3.2		
	2%	DB	12.5	15.6	18.0	21.4	24.7	25.3	26.4	27.0	24.9	21.1	15.6	11.9		
		MCWB	1.2	2.9	4.7	7.5	10.6	13.7	14.6	14.0	13.3	10.7	4.7	1.6		
	5%	DB	10.4	13.4	16.0	19.5	22.9	23.6	24.7	25.2	22.9	18.8	13.9	9.8		
		MCWB	0.2	1.9	4.0	6.9	10.2	13.2	14.2	13.8	12.9	9.4	4.1	0.4		
	10%	DB	8.2	11.3	14.3	17.6	20.9	21.7	23.0	23.2	20.7	16.6	11.9	7.9		
		MCWB	-0.8	1.0	3.3	6.3	9.7	13.0	13.9	13.4	12.4	8.5	3.1	-0.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.2	4.6	6.8	10.1	13.9	16.4	16.6	16.2	15.2	12.8	7.1	3.5		
		MCDB	14.7	16.1	17.8	21.0	23.0	23.6	24.0	24.0	23.2	21.1	14.7	13.7		
	2%	WB	1.4	3.2	5.5	8.7	12.4	15.3	15.8	15.3	14.5	11.7	5.7	1.9		
		MCDB	11.7	14.3	15.6	18.1	21.7	22.1	23.3	22.9	21.9	19.5	13.7	11.0		
	5%	WB	0.4	2.2	4.6	7.9	11.5	14.6	15.2	14.7	13.7	10.4	4.6	0.7		
		MCDB	9.6	12.1	13.9	17.0	20.1	20.9	22.1	22.0	20.5	16.8	12.5	9.0		
	10%	WB	-0.7	1.4	3.9	7.0	10.7	13.8	14.7	14.1	13.0	9.3	3.5	-0.3		
		MCDB	7.6	10.1	12.4	15.6	18.5	19.6	20.9	20.9	19.2	14.9	10.8	7.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.1	17.7	15.6	14.3	13.3	11.4	11.3	12.0	11.7	13.2	16.1	17.3		
		MCDBR	21.3	22.1	19.5	18.2	16.7	14.7	14.8	15.9	15.4	16.4	19.0	19.9		
	5% WB	MCWBR	11.4	11.0	8.5	6.9	5.6	4.9	4.7	5.0	5.5	6.9	9.4	10.7		
		MCWBR	20.5	20.3	16.6	14.5	13.9	11.6	11.5	12.2	12.4	13.9	17.7	18.8		
(40) Clear-Sky Solar Irradiance	taub		0.243	0.282	0.352	0.373	0.352	0.340	0.356	0.360	0.318	0.275	0.246	0.229		
	taud		2.547	2.439	2.203	2.200	2.367	2.490	2.451	2.423	2.531	2.615	2.613	2.616		
	Ebn at Noon		1010	987	928	918	935	940	923	919	954	986	1000	1015		
	Edh at Noon		82	102	139	145	124	109	113	115	99	84	77	73		
(44) All-Sky Solar Radiation	RadAvg		3.95	4.60	5.47	6.09	6.05	5.25	5.24	5.07	4.63	4.26	4.03	3.78		
	RadStd		0.25	0.29	0.40	0.42	0.48	0.46	0.41	0.61	0.34	0.23	0.24	0.20		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	-1.53	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.41	+0.55	-1.10	+0.57	N/A	N/A	-79	-150	+99	+9

Nomenclature: See separate page