

BARKAM, ChinaWMO: **561720**Lat: **31.8991N**Lon: **102.2289E**Elev: **8747**StdP: **10.61**Time Zone: **8.00 (E08)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	14.7	17.4	-5.8	5.6	37.8	-2.4	6.7	34.9	12.7	43.0	10.0	43.1	0.6	90	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	84.3	60.0	81.0	59.2	77.9	58.1	63.3	76.4	62.1	74.5	60.9	72.5	5.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.0	107.9	66.3	58.8	103.2	65.2	57.7	99.2	64.1	34.0	76.7	32.9	74.5	31.9	72.9	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	9.6	7.8	9.0	90.8	2.0	2.2	7.5	92.3	6.3	93.6	5.2	94.8	3.8	96.4		
(5)			6.9	66.2	1.7	1.7	5.6	67.5	4.6	68.5	3.7	69.5	2.4	70.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	33.9	40.4	45.8	52.0	57.4	61.5	64.4	64.3	59.9	51.3	41.5	33.6	(6)
(7)		DBStd	11.80	4.23	4.57	4.57	4.91	4.99	4.66	4.25	4.54	5.22	5.08	4.12	3.96	(7)
(8)		HDD50	1761	498	270	144	34	5	0	0	0	2	43	255	510	(8)
(9)		HDD65	5402	963	690	596	389	241	123	64	67	166	424	704	975	(9)
(10)		CDD50	1958	0	0	13	95	233	345	445	444	299	84	0	0	(10)
(11)		CDD65	125	0	0	0	0	4	18	44	46	13	0	0	0	(11)
(12)		CDH74	1667	0	0	2	40	156	214	479	540	214	22	0	0	(12)
(13)		CDH80	377	0	0	0	4	27	37	119	145	43	2	0	0	(13)
(14)	Wind	WSAvg	2.4	2.2	2.7	3.1	3.1	2.8	2.3	2.3	2.2	2.0	2.0	2.0	(14)	
(15)	Precipitation	PrecAvg	30.3	0.1	0.2	0.7	1.8	4.0	6.1	5.3	4.1	5.4	2.2	0.3	0.1	(15)
(16)		PrecMax	37.0	0.4	0.6	1.7	3.9	6.4	10.6	10.1	6.5	8.7	6.1	1.7	0.3	(16)
(17)		PrecMin	24.9	0.0	0.0	0.2	0.8	1.5	3.4	2.4	2.1	1.7	0.6	0.0	0.0	(17)
(18)		PrecStd	3.2	0.1	0.2	0.4	0.7	1.1	1.7	1.8	1.1	1.5	1.1	0.4	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	66.4	71.9	78.7	83.6	84.4	87.8	88.3	85.2	77.2	63.0	54.2	(19)
(20)			MCWB	36.4	41.0	44.6	50.4	56.2	60.4	61.3	61.2	60.0	56.5	44.1	37.1	(20)
(21)		2%	DB	53.1	61.7	66.9	73.9	78.2	79.6	83.3	84.2	80.0	70.5	59.9	50.9	(21)
(22)			MCWB	34.9	38.9	42.6	48.0	53.6	59.4	60.8	60.6	59.2	53.0	42.3	35.1	(22)
(23)		5%	DB	50.0	57.7	63.3	69.9	74.3	75.8	79.5	80.3	75.7	66.4	56.9	48.3	(23)
(24)			MCWB	33.5	37.4	41.4	46.5	52.5	58.2	60.3	59.7	57.9	50.8	40.5	33.4	(24)
(25)		10%	DB	46.8	54.1	59.7	66.0	70.2	72.2	75.5	76.1	71.2	62.4	53.7	45.6	(25)
(26)			MCWB	31.9	36.0	40.2	45.5	51.4	57.3	59.6	59.0	56.4	48.9	39.0	32.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.8	42.0	46.3	52.4	59.5	64.4	65.2	64.6	62.8	57.8	45.8	38.3	(27)
(28)			MCD B	54.3	62.2	64.5	73.3	77.8	77.2	77.8	79.0	78.6	73.7	59.9	51.7	(28)
(29)		2%	WB	35.5	39.7	44.1	50.0	56.6	62.2	63.5	62.8	60.8	54.9	43.7	35.9	(29)
(30)			MCD B	51.5	58.3	62.1	67.1	71.6	73.7	75.9	77.1	74.9	67.4	56.4	49.1	(30)
(31)		5%	WB	33.8	38.2	42.7	48.5	54.7	60.6	62.3	61.4	59.2	52.5	42.0	34.2	(31)
(32)			MCD B	48.7	55.3	59.5	64.3	68.0	71.2	73.8	74.4	71.4	62.6	53.9	46.7	(32)
(33)		10%	WB	32.1	36.6	41.2	47.1	53.0	59.0	61.1	60.2	57.6	50.4	40.2	32.5	(33)
(34)			MCD B	45.6	52.0	56.3	61.9	64.9	68.2	71.5	71.7	67.9	58.9	51.1	44.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	28.8	30.0	27.8	27.1	25.3	21.8	22.9	24.1	23.3	23.6	26.6	26.7	(35)
(36)			MCDBR	32.4	36.3	34.7	35.0	33.0	28.8	31.3	32.3	31.1	29.8	30.3	28.6	(36)
(37)			MCWBR	17.7	18.0	14.9	13.3	11.6	10.2	11.2	10.8	11.9	13.1	14.9	15.8	(37)
(38)		5% WB	MCD BR	30.8	33.9	30.5	28.8	27.2	23.8	23.4	24.9	25.6	26.1	27.5	27.1	(38)
(39)			MCWBR	17.0	16.8	13.0	11.0	10.3	9.2	9.4	9.4	10.1	11.5	13.9	15.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.275	0.316	0.397	0.421	0.415	0.401	0.414	0.421	0.375	0.319	0.277	0.256	(40)
(41)		taud		2.443	2.315	2.046	2.036	2.154	2.293	2.274	2.232	2.357	2.469	2.505	2.526	(41)
(42)		Ebn at Noon		304	298	279	276	278	280	276	273	283	294	301	307	(42)
(43)		Edh at Noon		29	36	51	54	49	42	43	44	37	31	27	25	(43)
(44)	All-Sky Solar Radiation	RadAvg		1219	1440	1702	1921	1864	1532	1633	1547	1369	1248	1219	1169	(44)
(45)		RadStd		88	82	124	129	138	163	163	187	115	81	64	63	(45)