

PINGWU, China

WMO: 561930

Lat: 32.417N

Lon: 104.517E

Elev: 2933

StdP: 13.20

Time Zone: 8.00 (E08)

Period: 86-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.1	32.0	17.7	14.9	42.4	21.1	17.6	41.1	7.8	40.5	6.8	41.3	0.3	220	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	91.1	72.0	88.5	71.4	86.0	70.6	75.3	84.9	74.1	83.1	73.0	81.3	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.8	136.0	79.4	71.7	130.8	78.2	70.7	126.3	77.3	41.2	84.8	40.0	83.4	38.9	81.5	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.9	5.5	DB	24.9	95.3	3.5	2.3	22.4	97.0	20.4	98.4	18.4	99.7	15.9	101.3	
			WB	23.9	77.5	2.9	1.1	21.8	78.3	20.1	78.9	18.5	79.5	16.4	80.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	41.4	44.7	52.0	61.7	68.6	73.7	77.2	75.5	68.8	60.7	52.2	43.3	(6)
	DBStd	13.30	3.42	4.92	6.05	6.09	4.70	4.09	3.85	4.35	4.45	4.25	5.01	3.83	(7)
	HDD50	718	267	159	46	2	0	0	0	0	0	0	35	209	(8)
	HDD65	3073	732	567	403	134	20	1	0	0	14	145	385	672	(9)
	CDD50	4395	0	12	110	354	577	712	844	790	563	331	100	2	(10)
	CDD65	1274	0	0	2	36	133	263	379	325	126	10	0	0	(11)
	CDH74	8091	0	0	18	260	772	1654	2773	2087	496	31	0	0	(12)
	CDH80	2604	0	0	1	48	193	522	1018	718	102	2	0	0	(13)
(14) Wind	WSAvg	1.2	0.8	0.9	1.3	1.6	2.0	1.8	1.6	1.3	0.9	0.7	0.8	0.7	(14)
(15) Precipitation	PrecAvg	33.0	0.1	0.2	0.7	1.9	3.2	4.3	8.1	6.9	5.2	1.7	0.5	0.1	(15)
	PrecMax	45.7	0.5	0.7	2.1	3.7	6.2	15.5	15.0	17.4	14.4	3.3	1.8	0.3	(16)
	PrecMin	18.8	0.0	0.0	0.2	0.4	0.9	1.6	2.4	2.4	2.2	0.3	0.0	0.0	(17)
	PrecStd	7.0	0.1	0.2	0.4	0.9	1.3	2.9	3.3	3.5	2.6	0.7	0.4	0.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.1	64.8	76.6	84.9	89.3	92.3	94.9	93.6	87.4	78.0	70.2	58.5	(19)
		MCWB	44.6	49.1	57.6	64.0	66.5	69.1	72.1	73.7	69.2	63.1	56.7	47.0	(20)
	2%	DB	54.2	61.0	70.1	80.6	85.0	88.5	91.5	89.9	82.7	73.3	66.4	55.6	(21)
		MCWB	42.8	47.6	54.6	61.4	64.8	69.4	73.1	72.6	69.3	62.3	55.1	45.3	(22)
	5%	DB	51.0	57.0	65.9	76.7	81.6	85.7	88.8	87.1	79.4	70.2	63.1	52.9	(23)
		MCWB	41.1	45.6	52.7	60.0	64.0	69.2	72.7	72.3	67.7	60.5	53.6	43.7	(24)
	10%	DB	48.0	53.3	62.1	72.9	78.3	82.7	86.0	84.2	76.4	67.3	60.0	50.2	(25)
		MCWB	39.6	44.2	51.2	58.6	63.2	68.3	72.3	71.4	66.9	59.6	52.3	42.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	50.3	59.3	66.6	69.2	73.6	77.3	76.7	74.6	65.4	58.3	48.2	(27)
		MCDB	55.9	62.5	72.4	79.7	81.1	84.8	87.8	86.6	79.8	73.0	66.3	56.5	(28)
	2%	WB	43.6	48.3	55.7	63.8	67.4	72.0	75.6	74.9	71.2	63.6	56.5	46.3	(29)
		MCDB	52.1	58.2	66.8	75.2	79.1	82.6	85.5	84.5	78.5	70.1	63.5	53.1	(30)
	5%	WB	42.0	46.6	53.6	61.8	66.0	70.8	74.5	73.8	69.3	62.1	55.1	45.0	(31)
		MCDB	49.1	54.9	63.8	73.2	76.7	80.9	83.9	82.6	76.1	67.6	60.9	51.3	(32)
	10%	WB	40.6	45.0	51.9	59.9	64.7	69.7	73.5	72.8	68.0	60.8	53.7	43.5	(33)
		MCDB	46.5	52.6	61.3	70.4	74.6	79.1	82.2	80.8	74.1	66.0	58.7	49.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	12.7	14.2	16.9	16.8	15.6	15.1	14.3	12.4	11.3	12.8	13.5	(35)
		MCDBR	20.3	20.9	22.2	23.9	23.4	22.0	21.0	20.2	18.6	16.7	18.2	18.8	(36)
		MCWBR	10.9	10.0	10.0	9.2	8.5	7.5	7.0	7.2	7.3	6.8	8.7	10.4	(37)
	5% WB	MCDBR	18.4	18.6	20.0	21.0	18.9	17.4	16.6	16.5	14.9	13.9	14.8	16.5	(38)
		MCWBR	10.1	9.3	9.3	8.8	7.5	7.0	6.4	6.5	6.5	6.0	7.6	9.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.579	0.655	0.715	0.714	0.679	0.644	0.667	0.709	0.676	0.642	0.594	0.543	(40)
	taud		1.605	1.505	1.446	1.490	1.608	1.715	1.697	1.598	1.635	1.633	1.644	1.694	(41)
	Ebn at Noon		188	190	192	202	212	219	213	201	199	191	183	189	(42)
	Edh at Noon		68	83	94	94	84	75	76	83	77	72	65	59	(43)
(44) All-Sky Solar Radiation	RadAvg		748	813	1023	1285	1386	1311	1317	1232	892	769	731	720	(44)
	RadStd		95	121	121	115	148	151	199	174	93	110	83	99	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	+0.50	N/A	-1.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page