

PINGWU, China

WMO: 561930

Lat: 32.417N

Lon: 104.517E

Elev: 894

StdP: 91.04

Time Zone: 8.00 (E08)

Period: 86-06

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	0.0	-8.0	2.1	5.8	-6.1	2.5	5.1	3.5	4.7	3.0	5.1	0.1	220	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	32.8	22.2	31.4	21.9	30.0	21.4	24.0	29.4	23.4	28.4	22.8	27.4	1.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	19.4	26.3	22.1	18.7	25.6	21.5	18.0	25.2	78.0	29.3	75.2	28.5	72.7	27.5	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
3.6	3.1	2.4	-3.9	35.2	1.9	1.3	-5.3	36.1	-6.5	36.9	-7.5	37.6	-8.9	38.5		
			-4.5	25.3	1.6	0.6	-5.7	25.7	-6.6	26.1	-7.5	26.4	-8.7	26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	5.2	7.1	11.1	16.5	20.3	23.2	25.1	24.2	20.4	15.9	11.2	6.3
	DBStd	7.39	1.90	2.73	3.36	3.38	2.61	2.27	2.14	2.42	2.47	2.36	2.78	2.13
	HDD10.0	399	148	88	26	1	0	0	0	0	0	19	116	
	HDD18.3	1707	407	315	224	74	11	1	0	8	81	214	373	
	CDD10.0	2442	0	7	61	197	321	396	469	439	313	184	56	1
	CDD18.3	708	0	0	1	20	74	146	211	181	70	6	0	0
	CDH23.3	4495	0	0	10	144	429	919	1541	1159	276	17	0	0
	CDH26.7	1447	0	0	1	27	107	290	566	399	57	1	0	0
Wind	WSAvg	0.5	0.3	0.4	0.6	0.7	0.9	0.8	0.7	0.6	0.4	0.3	0.3	0.3
Precipitation	PrecAvg	837	3	6	19	47	81	109	206	176	131	43	13	2
	PrecMax	1161	12	17	53	94	158	393	382	442	365	84	46	8
	PrecMin	478	0	0	5	9	22	40	61	62	55	8	1	0
	PrecStd	179	3	4	11	24	33	73	83	89	65	19	11	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.5	18.2	24.8	29.4	31.8	33.5	34.9	34.2	30.8	25.5	21.2	14.7
		MCWB	7.0	9.5	14.2	17.8	19.1	20.6	22.3	23.1	20.7	17.3	13.7	8.4
	2%	DB	12.3	16.1	21.2	27.0	29.4	31.4	33.1	32.2	28.2	22.9	19.1	13.1
		MCWB	6.0	8.7	12.6	16.3	18.2	20.8	22.8	22.5	20.7	16.8	12.8	7.4
	5%	DB	10.5	13.9	18.8	24.8	27.6	29.8	31.6	30.6	26.3	21.2	17.3	11.6
		MCWB	5.0	7.5	11.5	15.6	17.8	20.6	22.6	22.4	19.9	15.9	12.0	6.5
	10%	DB	8.9	11.9	16.7	22.7	25.7	28.2	30.0	29.0	24.6	19.6	15.5	10.1
		MCWB	4.2	6.8	10.7	14.8	17.3	20.2	22.4	21.9	19.4	15.3	11.3	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	10.2	15.2	19.2	20.7	23.1	25.2	24.8	23.7	18.6	14.6	9.0
		MCDB	13.3	17.0	22.4	26.5	27.3	29.3	31.0	30.4	26.5	22.8	19.0	13.6
	2%	WB	6.4	9.0	13.2	17.7	19.7	22.2	24.2	23.8	21.8	17.5	13.6	8.0
		MCDB	11.2	14.5	19.3	24.0	26.2	28.1	29.7	29.2	25.8	21.1	17.5	11.7
	5%	WB	5.6	8.1	12.0	16.5	18.9	21.6	23.6	23.2	20.7	16.7	12.8	7.2
		MCDB	9.5	12.7	17.7	22.9	24.8	27.2	28.8	28.1	24.5	19.8	16.0	10.7
	10%	WB	4.8	7.2	11.0	15.5	18.1	20.9	23.1	22.7	20.0	16.0	12.0	6.4
		MCDB	8.0	11.4	16.3	21.4	23.6	26.2	27.9	27.1	23.4	18.9	14.8	9.5
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.1	7.9	9.4	9.3	8.7	8.4	7.9	6.9	6.3	7.1	7.5
		MCDBR	11.3	11.6	12.3	13.3	13.0	12.2	11.6	11.2	10.3	9.3	10.1	10.4
		MCWBR	6.1	5.6	5.6	5.1	4.7	4.2	3.9	4.0	4.0	3.8	4.8	5.8
	5% WB	MCDBR	10.2	10.3	11.1	11.6	10.5	9.7	9.2	9.1	8.3	7.7	8.2	9.2
		MCWBR	5.6	5.1	5.2	4.9	4.2	3.9	3.5	3.6	3.6	3.3	4.2	5.2
Clear-Sky Solar Irradiance	taub	0.579	0.655	0.715	0.714	0.679	0.644	0.667	0.709	0.676	0.642	0.594	0.543	
	taud	1.605	1.505	1.446	1.490	1.608	1.715	1.697	1.598	1.635	1.633	1.644	1.694	
	Ebn at Noon	594	598	606	638	669	691	672	634	628	601	578	597	
	Edh at Noon	215	261	297	295	264	237	240	262	242	226	205	187	
All-Sky Solar Radiation	RadAvg	2.36	2.56	3.23	4.05	4.37	4.13	4.15	3.88	2.81	2.42	2.30	2.27	
	RadStd	0.30	0.38	0.38	0.36	0.47	0.48	0.63	0.55	0.29	0.35	0.26	0.31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.28	N/A	-0.84	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page