

NYINGCHI, China

WMO: 563120

Lat: 29.6475N

Lon: 94.3605E

Elev: 9846

StdP: 10.17

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	21.9	0.0	7.9	37.9	4.4	10.0	38.0	20.9	42.0	16.7	42.0	1.3	340	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	76.7	56.8	74.2	56.4	71.8	55.9	60.0	69.5	59.2	68.2	58.4	66.9	7.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.4	102.3	62.4	56.6	99.4	61.7	55.9	96.8	61.1	31.8	70.2	31.1	68.4	30.5	67.1	63.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.1	13.3	11.2	DB	13.9	82.4	2.7	2.1	12.0	83.9	10.4	85.1	8.9	86.2	7.0	87.7
			WB	11.5	61.8	2.3	0.8	9.9	62.3	8.5	62.8	7.2	63.3	5.5	63.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	36.0	39.7	44.7	50.5	56.0	61.0	63.0	62.4	59.2	52.1	44.3	37.8
	DBStd	10.17	4.05	4.16	4.11	3.77	3.70	3.30	3.03	3.04	2.87	4.14	3.67	3.87
	HDD50	1516	435	289	170	39	4	0	0	0	0	27	174	378
	HDD65	5284	900	709	629	436	278	126	77	91	175	399	621	843
	CDD50	1736	0	0	6	52	191	329	402	384	276	93	3	0
	CDD65	29	0	0	0	0	0	5	13	10	1	0	0	0
	CDH74	230	0	0	0	0	9	43	84	77	17	0	0	0
	CDH80	10	0	0	0	0	0	1	5	3	1	0	0	0
Wind	WSAvg	3.8	4.2	4.9	4.9	4.3	4.2	3.5	3.0	2.8	2.8	3.8	3.9	3.5
Precipitation	PrecAvg	28.0	0.1	0.2	0.9	1.9	3.2	5.2	5.3	5.1	4.4	1.5	0.2	0.0
	PrecMax	38.5	0.2	0.6	2.5	3.9	6.1	9.1	9.2	13.9	10.3	3.0	0.6	0.3
	PrecMin	20.1	0.0	0.0	0.2	0.7	1.0	2.5	1.9	0.9	1.3	0.3	0.0	0.0
	PrecStd	4.6	0.1	0.1	0.6	0.7	1.2	1.6	1.9	2.9	2.2	0.8	0.1	0.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.9	59.6	65.1	70.0	75.0	78.2	79.9	79.6	76.6	69.8	62.3	56.5
		MCWB	37.0	39.1	43.9	47.0	50.3	55.4	58.1	57.8	55.9	50.6	43.1	37.9
	2%	DB	51.5	55.4	60.5	66.1	71.1	74.7	76.2	76.1	72.0	66.0	59.3	53.0
		MCWB	34.8	37.7	41.9	46.2	50.1	55.6	58.1	57.6	54.9	50.3	41.7	36.3
	5%	DB	48.3	52.1	57.2	63.1	68.3	71.7	73.6	73.2	69.1	63.3	56.9	50.4
		MCWB	33.2	36.3	40.5	45.1	50.2	55.5	57.9	57.4	54.7	49.1	40.5	35.0
	10%	DB	45.2	49.1	54.3	60.0	65.4	68.9	70.8	70.5	66.6	61.0	54.5	47.6
		MCWB	31.8	34.9	39.4	44.4	50.0	55.2	57.8	57.2	54.5	48.1	39.5	33.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.9	41.3	46.2	50.2	55.8	60.0	61.5	60.9	59.0	54.5	45.0	39.3
		MCDB	53.6	54.7	59.8	63.1	64.8	69.2	70.8	71.4	67.6	63.8	58.7	54.0
	2%	WB	35.6	39.0	43.7	48.3	54.2	58.8	60.3	59.6	57.6	52.8	43.2	37.1
		MCDB	49.5	52.1	56.4	60.7	64.0	67.4	69.8	69.4	65.5	61.1	55.6	50.9
	5%	WB	33.8	37.2	42.1	47.0	52.7	57.9	59.4	58.9	56.7	51.5	41.9	35.7
		MCDB	46.4	50.3	53.6	58.8	62.7	66.0	68.4	68.1	64.1	59.0	53.6	48.7
	10%	WB	32.3	35.7	40.6	45.8	51.3	57.1	58.7	58.1	55.9	50.2	40.6	34.3
		MCDB	43.8	47.2	51.4	56.7	61.0	64.7	67.2	66.7	62.8	57.5	51.8	46.0
Mean Daily Temperature Range	5% DB	MDBR	21.7	20.5	20.0	20.0	19.1	16.1	15.6	16.3	16.1	18.8	22.6	22.9
		MCDBR	27.4	26.5	25.1	25.2	24.7	21.8	21.8	22.6	21.6	21.9	26.8	27.4
		MCWBR	13.5	11.5	9.5	8.4	7.5	6.3	6.6	6.6	7.0	7.9	11.5	13.1
	5% WB	MCDBR	25.3	23.9	21.0	20.7	17.9	14.7	15.7	16.4	15.0	16.4	23.1	25.1
		MCWBR	12.3	10.2	7.9	7.1	5.9	5.5	5.7	5.7	5.7	6.1	9.9	12.0
Clear-Sky Solar Irradiance	taub	0.264	0.317	0.387	0.369	0.322	0.310	0.307	0.310	0.294	0.269	0.251	0.243	
	taud	2.480	2.325	2.106	2.248	2.495	2.640	2.689	2.653	2.670	2.690	2.645	2.592	
	Ebn at Noon	313	301	284	293	306	307	308	308	312	317	318	318	
	Edh at Noon	29	37	49	44	35	30	28	29	28	25	24	24	
All-Sky Solar Radiation	RadAvg	1084	1218	1414	1505	1539	1501	1522	1491	1321	1273	1218	1114	
	RadStd	89	77	112	123	122	87	121	139	97	89	85	85	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.47	N/A	-1.53	+0.85	N/A	N/A	N/A	N/A	+146	+13
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page