

NYINGCHI, China

WMO: 563120

Lat: 29.6475N

Lon: 94.3605E

Elev: 3001

StdP: 70.10

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -5.6	(d) -17.8	(e) 1.1	(f) 3.3	(g) -15.4	(h) 1.4	(i) 3.3	(j) 9.3	(k) 5.6	(l) 7.5	(m) 5.6	(n) 0.6	(o) 340	(p) 0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.6	(c) 24.8	(d) 13.8	(e) 23.4	(f) 13.6	(g) 22.1	(h) 13.3	(i) 15.6	(j) 20.9	(k) 15.1	(l) 20.1	(m) 14.7	(n) 19.4	(o) 3.1	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.1	14.6	16.9	13.7	14.2	16.5	13.3	13.8	16.2	56.1	21.2	54.5	20.2	53.1	19.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.2	6.0	5.0	-10.1	28.0	1.5	1.1	-11.1	28.8	-12.0	29.5	-12.8	30.1	-13.9	31.0
			-11.4	16.5	1.3	0.5	-12.3	16.9	-13.0	17.1	-13.8	17.4	-14.7	17.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	2.2	4.3	7.1	10.3	13.4	16.1	17.2	16.9	15.1	11.2	6.8	3.2		
	DBStd	5.65	2.25	2.31	2.28	2.09	2.06	1.84	1.68	1.69	1.60	2.30	2.04	2.15		
	HDD10.0	842	242	161	94	22	2	0	0	0	0	15	97	210		
	HDD18.3	2936	500	394	349	242	154	70	43	51	97	222	345	468		
	CDD10.0	964	0	0	3	29	106	183	223	213	153	52	2	0		
	CDD18.3	16	0	0	0	0	0	3	7	6	1	0	0	0		
	CDH23.3	128	0	0	0	0	5	24	47	43	9	0	0	0		
	CDH26.7	6	0	0	0	0	0	1	3	2	1	0	0	0		
(14) Wind	WSAvg	1.7	1.9	2.2	2.2	1.9	1.9	1.6	1.3	1.3	1.3	1.7	1.7	1.6		
(15) Precipitation	PrecAvg	711	2	4	22	48	81	133	135	130	113	38	4	1		
	PrecMax	979	6	14	64	99	155	232	234	353	261	75	14	7		
	PrecMin	510	0	0	4	19	26	64	47	24	32	8	0	0		
	PrecStd	118	2	3	15	17	31	40	49	73	56	20	3	1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	15.3	18.4	21.1	23.9	25.7	26.6	26.5	24.8	21.0	16.8	13.6		
		MCWB	2.8	4.0	6.6	8.3	10.1	13.0	14.5	14.4	13.3	10.3	6.2	3.3		
	2%	DB	10.8	13.0	15.8	19.0	21.7	23.7	24.6	24.5	22.2	18.9	15.2	11.7		
		MCWB	1.5	3.2	5.5	7.9	10.1	13.1	14.5	14.2	12.7	10.2	5.4	2.4		
	5%	DB	9.0	11.2	14.0	17.3	20.2	22.0	23.1	22.9	20.6	17.4	13.9	10.2		
		MCWB	0.7	2.4	4.7	7.3	10.1	13.0	14.4	14.1	12.6	9.5	4.7	1.7		
	10%	DB	7.3	9.5	12.4	15.6	18.6	20.5	21.5	21.4	19.2	16.1	12.5	8.7		
		MCWB	-0.1	1.6	4.1	6.9	10.0	12.9	14.3	14.0	12.5	8.9	4.2	0.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	5.2	7.9	10.1	13.2	15.6	16.4	16.0	15.0	12.5	7.2	4.0		
		MCDB	12.0	12.6	15.5	17.3	18.2	20.7	21.5	21.9	19.8	17.7	14.8	12.2		
	2%	WB	2.0	3.9	6.5	9.1	12.3	14.9	15.7	15.4	14.2	11.6	6.2	2.8		
		MCDB	9.7	11.2	13.5	15.9	17.8	19.7	21.0	20.8	18.6	16.1	13.1	10.5		
	5%	WB	1.0	2.9	5.6	8.3	11.5	14.4	15.2	14.9	13.7	10.8	5.5	2.0		
		MCDB	8.0	10.2	12.0	14.9	17.0	18.9	20.2	20.1	17.8	15.0	12.0	9.3		
	10%	WB	0.2	2.0	4.8	7.7	10.7	13.9	14.8	14.5	13.3	10.1	4.8	1.3		
		MCDB	6.6	8.5	10.8	13.7	16.1	18.2	19.5	19.3	17.1	14.2	11.0	7.8		
(35) Mean Daily Temperature Range	MDBR		12.1	11.4	11.1	11.1	10.6	9.0	8.6	9.0	8.9	10.4	12.6	12.7		
	5% DB	MCDBR	15.2	14.7	13.9	14.0	13.7	12.1	12.1	12.5	12.0	12.2	14.9	15.2		
		MCWBR	7.5	6.4	5.3	4.7	4.2	3.5	3.7	3.7	3.9	4.4	6.4	7.3		
	5% WB	MCDBR	14.1	13.3	11.7	11.5	9.9	8.2	8.7	9.1	8.3	9.1	12.9	14.0		
		MCWBR	6.9	5.7	4.4	4.0	3.3	3.0	3.1	3.2	3.1	3.4	5.5	6.6		
(40) Clear-Sky Solar Irradiance	taub		0.264	0.317	0.387	0.369	0.322	0.310	0.307	0.310	0.294	0.269	0.251	0.243		
	taud		2.480	2.325	2.106	2.248	2.495	2.640	2.689	2.653	2.670	2.690	2.645	2.592		
	Ebn at Noon		986	948	896	923	964	969	971	971	984	999	1001	1002		
	Edh at Noon		90	116	155	139	109	94	89	92	87	79	76	77		
(44) All-Sky Solar Radiation	RadAvg		3.42	3.84	4.46	4.74	4.85	4.73	4.80	4.70	4.16	4.01	3.84	3.51		
	RadStd		0.28	0.24	0.35	0.39	0.39	0.27	0.38	0.44	0.31	0.28	0.27	0.27		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.26	N/A	-0.85	+0.47	N/A	N/A	N/A	N/A	+81	+7
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page