

KANGDING, China

WMO: 563740

Lat: 30.0548N

Lon: 101.9605E

Elev: 8586

StdP: 10.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.0	19.4	1.1	8.0	39.5	5.0	9.8	36.8	24.7	35.4	22.6	36.8	3.6	90	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	74.6	57.9	72.5	57.6	70.3	57.3	61.7	69.8	60.6	68.2	59.7	66.7	13.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.3	104.3	64.5	58.2	100.4	63.9	57.3	96.9	63.4	32.4	69.9	31.6	68.4	30.8	67.0	66.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.0	19.5	17.5	13.0	78.8	3.0	2.9	10.8	80.8	9.0	82.5	7.3	84.1	5.2	86.2		
			DB	WB	11.8	63.3	2.6	1.2	9.9	64.1	8.4	64.9	6.9	65.6	5.0	66.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	29.8	34.2	40.0	48.2	53.3	57.4	61.6	61.4	55.6	48.0	40.1	32.2
	DBStd	12.14	5.87	7.36	6.86	6.63	5.03	4.40	3.65	4.23	4.96	4.68	5.03	4.72
	HDD50	2477	627	445	316	108	26	3	0	0	9	95	297	551
	HDD65	6637	1092	863	774	504	364	228	114	124	284	527	747	1016
	CDD50	1340	0	2	8	54	128	227	358	353	177	33	0	0
	CDD65	21	0	0	0	0	0	1	8	11	1	0	0	0
	CDH74	82	0	0	1	4	7	5	22	41	2	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	6.6	6.6	7.3	7.7	7.5	7.3	6.3	5.9	6.2	6.1	6.4	5.9	5.9
	PrecAvg	31.5	0.2	0.5	1.3	2.0	4.2	6.7	4.6	3.9	5.0	2.3	0.6	0.2
Precipitation	PrecMax	40.2	0.9	1.6	5.5	4.4	8.7	11.4	7.3	7.2	9.2	5.3	1.9	0.7
	PrecMin	24.3	0.0	0.0	0.0	0.2	1.5	2.2	2.1	1.2	1.9	0.2	0.1	0.0
	PrecStd	4.1	0.2	0.4	1.0	0.9	1.8	1.9	1.3	1.7	1.9	1.3	0.4	0.2
	PrecStd	4.1	0.2	0.4	1.0	0.9	1.8	1.9	1.3	1.7	1.9	1.3	0.4	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.5	63.2	69.6	73.8	74.4	74.4	76.5	77.6	73.0	65.7	59.2	52.5	52.5
	0.4% MCWB	35.3	39.8	43.9	48.1	52.4	57.3	60.2	60.1	58.5	54.2	42.2	35.2	35.2
	2% DB	47.6	56.9	62.3	68.7	69.7	70.9	73.8	74.9	69.3	61.9	55.4	47.1	47.1
	2% MCWB	32.9	37.1	42.4	47.7	52.8	57.7	59.7	59.4	57.6	51.7	42.4	33.7	33.7
	5% DB	43.4	51.5	57.3	64.5	66.1	67.9	71.6	72.4	66.5	58.8	52.5	43.7	43.7
	5% MCWB	31.6	35.9	41.6	48.2	52.4	57.2	59.2	58.8	56.6	50.2	41.8	33.2	33.2
	10% DB	39.7	46.6	52.7	60.5	62.9	65.2	69.4	69.8	63.7	56.1	49.6	40.5	40.5
	10% MCWB	30.2	34.4	40.6	47.2	51.8	56.5	58.9	58.5	55.7	49.1	40.7	31.9	31.9
	0.4% WB	36.4	40.7	46.7	53.4	57.4	61.6	62.9	63.5	60.7	56.5	46.3	37.7	37.7
	0.4% MCDB	50.3	58.7	62.1	64.3	67.2	69.2	71.4	72.3	69.3	63.2	54.1	47.0	47.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	34.0	38.4	44.5	51.3	55.4	59.9	61.7	61.8	59.1	53.7	44.4	35.7	35.7
	2% MCDB	45.3	52.9	57.0	61.9	64.7	67.0	69.8	70.0	66.8	58.6	51.8	43.6	43.6
	5% WB	32.2	36.8	42.8	49.5	54.0	58.6	60.8	60.6	57.7	51.7	43.0	34.1	34.1
	5% MCDB	42.2	49.2	54.0	60.2	62.4	65.0	68.3	68.0	64.2	56.9	50.2	41.5	41.5
	10% WB	30.5	35.2	41.2	47.9	52.6	57.4	59.9	59.5	56.5	49.9	41.6	32.4	32.4
	10% MCDB	38.7	45.6	51.4	57.8	60.6	63.2	66.7	66.7	62.3	55.0	48.1	39.2	39.2
Mean Daily Temperature Range	MDBR	14.7	16.3	16.3	17.6	15.4	12.6	12.7	13.2	11.9	12.2	14.4	14.2	14.2
	5% DB MCDBR	22.2	26.7	27.1	26.7	22.5	17.2	17.7	18.4	16.4	16.9	20.9	19.9	19.9
	5% DB MCWBR	12.5	13.3	12.6	11.4	9.3	6.8	6.7	6.5	6.9	8.7	11.6	11.6	11.6
	5% WB MCDBR	20.2	22.6	22.6	21.2	17.5	13.2	13.7	14.0	13.7	13.9	17.6	17.2	17.2
	5% WB MCWBR	11.8	12.1	11.2	10.0	7.9	5.7	5.6	5.4	5.9	7.4	10.5	10.6	10.6
	5% WB MCWBR	11.8	12.1	11.2	10.0	7.9	5.7	5.6	5.4	5.9	7.4	10.5	10.6	10.6
Clear-Sky Solar Irradiance	taub	0.305	0.340	0.428	0.449	0.436	0.426	0.452	0.460	0.418	0.358	0.316	0.294	0.294
	taud	2.354	2.260	1.991	1.995	2.117	2.235	2.167	2.125	2.226	2.347	2.392	2.417	2.417
	Ebn at Noon	294	292	271	269	272	273	266	263	271	282	288	293	293
	Edh at Noon	32	39	55	57	50	45	48	49	43	36	31	29	29
All-Sky Solar Radiation	RadAvg	1080	1242	1405	1556	1576	1433	1443	1400	1230	1123	1067	1017	1017
	RadStd	78	89	114	122	115	148	135	186	94	93	74	64	64

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.58	N/A	-1.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.63	N/A	-1.08	+1.04	N/A	N/A	-90	-164	+295	+175

Nomenclature: See separate page