

KANGDING, China

WMO: 563740

Lat: 30.0548N

Lon: 101.9605E

Elev: 2617

StdP: 73.59

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.3	-7.0	-17.2	1.1	4.2	-15.0	1.4	2.7	11.0	1.9	10.1	2.7	1.6	90	0.609

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	23.7	14.4	22.5	14.2	21.3	14.1	16.5	21.0	15.9	20.1	15.4	19.3	6.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	14.9	18.0	14.6	14.3	17.7	14.0	13.8	17.4	57.5	21.1	55.5	20.2	53.7	19.4	18.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.7	7.8	-10.6	26.0	1.7	1.6	-11.8	27.1	-12.8	28.1	-13.7	29.0	-14.9	30.1
			-11.2	17.4	1.4	0.7	-12.3	17.9	-13.1	18.3	-13.9	18.7	-15.0	19.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-1.2	1.2	4.5	9.0	11.8	14.1	16.4	16.3	13.1	8.9	4.5	0.1
	DBStd	6.75	3.26	4.09	3.81	3.68	2.80	2.45	2.03	2.35	2.76	2.60	2.79	2.62
	HDD10.0	1376	348	247	176	60	14	2	0	0	5	53	165	306
	HDD18.3	3687	607	479	430	280	202	127	63	69	158	293	415	564
	CDD10.0	744	0	1	4	30	71	126	199	196	98	18	0	0
	CDD18.3	12	0	0	0	0	0	1	4	6	1	0	0	0
	CDH23.3	46	0	0	1	2	4	3	12	23	1	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.0	3.0	3.3	3.4	3.4	3.3	2.8	2.7	2.8	2.7	2.9	2.7	2.6
Precipitation	PrecAvg	801	6	13	32	52	106	169	118	100	128	58	14	5
	PrecMax	1022	23	41	139	112	221	289	186	184	233	135	48	17
	PrecMin	617	0	0	1	4	37	56	54	31	49	4	2	0
	PrecStd	104	5	11	25	24	45	49	34	43	49	33	11	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	17.3	20.9	23.2	23.5	23.5	24.7	25.4	22.8	18.7	15.1	11.4
		MCWB	1.8	4.3	6.6	8.9	11.4	14.1	15.6	15.6	14.7	12.4	5.7	1.8
	2%	DB	8.6	13.8	16.8	20.4	20.9	21.6	23.2	23.8	20.7	16.6	13.0	8.4
		MCWB	0.5	2.8	5.8	8.7	11.6	14.3	15.4	15.2	14.2	10.9	5.8	0.9
	5%	DB	6.3	10.8	14.1	18.1	18.9	20.0	22.0	22.4	19.2	14.9	11.4	6.5
		MCWB	-0.2	2.2	5.3	9.0	11.4	14.0	15.1	14.9	13.7	10.1	5.4	0.6
	10%	DB	4.3	8.1	11.5	15.8	17.2	18.4	20.8	21.0	17.6	13.4	9.8	4.7
		MCWB	-1.0	1.4	4.8	8.5	11.0	13.6	14.9	14.7	13.2	9.5	4.8	0.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.4	4.9	8.2	11.9	14.1	16.4	17.2	17.5	15.9	13.6	7.9	3.2
		MCDB	10.1	14.8	16.7	18.0	19.5	20.7	21.9	22.4	20.7	17.3	12.3	8.3
	2%	WB	1.1	3.6	6.9	10.7	13.0	15.5	16.5	16.6	15.1	12.1	6.9	2.0
		MCDB	7.4	11.6	13.9	16.6	18.1	19.5	21.0	21.1	19.3	14.8	11.0	6.5
	5%	WB	0.1	2.7	6.0	9.7	12.2	14.8	16.0	15.9	14.3	10.9	6.1	1.1
		MCDB	5.7	9.6	12.2	15.7	16.9	18.3	20.2	20.0	17.9	13.9	10.1	5.3
	10%	WB	-0.8	1.8	5.1	8.8	11.4	14.1	15.5	15.3	13.6	9.9	5.3	0.2
		MCDB	3.7	7.5	10.8	14.3	15.9	17.4	19.3	19.3	16.8	12.8	8.9	4.0
Mean Daily Temperature Range	5% DB	MDBR	8.1	9.0	9.0	9.8	8.6	7.0	7.0	7.3	6.6	6.8	8.0	7.9
		MCDBR	12.3	14.8	15.1	14.8	12.5	9.5	9.9	10.2	9.1	9.4	11.6	11.1
		MCWBR	6.9	7.4	7.0	6.3	5.2	3.8	3.7	3.6	3.8	4.8	6.4	6.4
	5% WB	MCDBR	11.2	12.5	12.5	11.8	9.7	7.3	7.6	7.8	7.6	7.7	9.8	9.5
		MCWBR	6.6	6.7	6.2	5.6	4.4	3.2	3.1	3.0	3.3	4.1	5.8	5.9
Clear-Sky Solar Irradiance	taub	0.305	0.340	0.428	0.449	0.436	0.426	0.452	0.460	0.418	0.358	0.316	0.294	
	taud	2.354	2.260	1.991	1.995	2.117	2.235	2.167	2.125	2.226	2.347	2.392	2.417	
	Ebn at Noon	927	919	853	849	859	862	839	829	854	890	908	925	
	Edh at Noon	102	123	173	179	159	141	150	155	135	112	98	92	
All-Sky Solar Radiation	RadAvg	3.40	3.91	4.43	4.90	4.97	4.52	4.55	4.41	3.88	3.54	3.36	3.21	
	RadStd	0.24	0.28	0.36	0.39	0.36	0.47	0.43	0.59	0.30	0.29	0.23	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.32	N/A	-0.93	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.35	N/A	-0.60	+0.58	N/A	N/A	-50	-91	+164	+97

Nomenclature: See separate page