

JIULONG, China

WMO: 564620

Lat: 29.0080N

Lon: 101.5009E

Elev: 9616

StdP: 10.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 19.9	(c) 22.0	(d) -7.1	(e) 5.4	(f) 46.2	(g) -3.2	(h) 6.6	(i) 44.2	(j) 19.7	(k) 45.7	(l) 17.0	(m) 45.4	(n) 4.3	(o) 320	(p) 0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	77.6	55.7	75.3	55.2	72.9	54.8	60.2	69.8	59.3	68.2	58.6	66.9	12.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.8	102.9	62.0	57.0	99.9	61.4	56.2	97.1	61.0	31.9	70.0	31.1	68.4	30.5	67.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.5	14.4	14.0	82.0	2.0	2.2	12.6	83.6	11.4	84.8	10.3	86.1	8.9	87.6
			10.9	62.8	1.6	2.8	9.8	64.8	8.9	66.4	8.0	68.0	6.9	70.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	36.8	41.0	45.7	51.1	56.8	60.5	61.6	61.2	58.3	52.5	43.5	37.4	(6)	(7)
	DBStd	9.88	3.42	4.19	4.23	4.45	5.19	4.45	3.36	3.62	4.36	4.57	3.69	3.38	(7)	(8)
	HDD50	1470	410	252	144	38	9	1	0	0	3	27	196	390	(8)	(9)
	HDD65	5289	875	671	600	417	256	144	114	124	202	387	644	855	(9)	(10)
	CDD50	1685	0	0	9	72	221	316	358	348	254	105	2	0	(10)	(11)
	CDD65	30	0	0	0	0	3	10	7	7	3	0	0	0	(11)	(12)
	CDH74	337	0	0	1	13	87	88	57	73	18	0	0	0	(12)	(13)
	CDH80	16	0	0	0	0	5	8	1	2	0	0	0	0	(13)	(14)
(14) Wind	WSAvg	5.6	5.3	6.0	6.3	6.5	6.4	5.6	5.1	5.1	4.8	5.1	5.3	5.3	(14)	(15)
(15) Precipitation	PrecAvg	35.7	0.1	0.2	0.5	1.7	3.6	7.8	7.3	5.4	6.3	2.5	0.3	0.1	(15)	(16)
	PrecMax	48.0	0.4	0.7	1.6	4.5	7.5	13.7	10.9	10.6	10.2	5.4	0.8	0.4	(16)	(17)
	PrecMin	26.7	0.0	0.0	0.0	0.6	0.9	3.4	4.4	1.5	3.5	0.3	0.0	0.0	(17)	(18)
	PrecStd	5.2	0.1	0.2	0.3	0.9	1.7	2.2	1.5	2.2	1.6	1.3	0.2	0.1	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.5	67.4	71.3	75.9	80.2	80.9	78.5	79.4	76.8	70.8	63.1	56.6	(19)	(20)
		MCWB	37.0	40.1	43.6	47.1	53.6	58.0	58.3	57.3	56.9	53.1	44.0	37.7	(20)	(21)
	2%	DB	55.5	62.4	66.8	71.8	76.5	76.3	75.4	76.1	72.6	67.6	59.8	53.7	(21)	(22)
		MCWB	35.2	38.6	41.8	45.9	52.3	56.9	58.0	56.8	56.3	51.5	42.3	36.4	(22)	(23)
	5%	DB	52.2	58.7	63.3	68.7	73.3	73.2	72.6	73.0	69.6	64.9	57.2	51.3	(23)	(24)
		MCWB	33.9	37.2	40.5	45.2	50.9	56.8	58.0	56.8	55.8	50.6	41.3	35.2	(24)	(25)
	10%	DB	49.1	55.1	59.9	65.6	70.1	70.1	69.7	70.0	66.8	62.4	54.4	48.7	(25)	(26)
		MCWB	32.5	35.8	39.4	44.3	50.5	56.6	57.5	56.7	55.4	49.6	40.1	34.0	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.0	41.6	45.9	50.7	56.9	61.3	61.8	60.6	59.3	55.8	47.3	39.8	(27)	(28)
		MCDB	53.9	61.3	64.4	67.1	71.4	73.4	71.9	70.7	70.3	65.2	56.6	53.3	(28)	(29)
	2%	WB	36.7	39.6	43.6	48.6	55.4	59.8	60.5	59.4	58.3	54.5	44.8	37.8	(29)	(30)
		MCDB	52.3	59.3	60.4	63.9	68.7	70.3	69.3	68.7	68.4	63.0	55.5	50.6	(30)	(31)
	5%	WB	34.7	38.0	42.1	47.4	54.2	58.8	59.6	58.6	57.4	53.2	43.1	36.2	(31)	(32)
		MCDB	49.7	56.2	58.3	62.1	66.2	67.9	67.6	67.3	66.2	60.8	53.7	48.7	(32)	(33)
	10%	WB	33.0	36.3	40.7	46.1	52.9	57.8	58.8	57.8	56.4	51.7	41.6	34.7	(33)	(34)
		MCDB	47.4	53.0	55.9	60.5	64.0	66.1	65.8	64.1	62.8	58.6	51.8	46.7	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	27.6	29.1	27.7	26.7	22.4	17.6	16.3	16.8	15.9	19.6	24.3	26.2	(35)	(36)
		MCDBR	32.2	35.5	34.6	33.4	29.8	23.2	21.8	23.1	20.9	22.9	28.5	29.0	(36)	(37)
	5% WB	MCWBR	16.2	16.6	14.7	12.6	9.3	7.0	6.9	6.7	6.9	8.4	12.5	14.1	(37)	(38)
		MCWBR	29.5	33.3	30.2	27.7	21.4	18.4	16.2	16.5	16.4	17.4	23.8	26.4	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.254	0.282	0.365	0.390	0.378	0.377	0.392	0.399	0.367	0.313	0.267	0.245	(39)	(40)
		taud	2.535	2.470	2.211	2.190	2.308	2.394	2.350	2.312	2.384	2.502	2.568	2.589	(40)	(41)
	Ebn at Noon		319	316	292	287	289	288	283	281	288	300	311	318	(41)	(42)
		Edh at Noon	27	32	44	47	42	38	40	41	37	30	26	25	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		1289	1475	1600	1661	1718	1536	1452	1431	1325	1308	1267	1223	(43)	(44)
	RadStd		83	100	144	162	118	148	115	173	97	102	115	66	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.63	N/A	N/A	+1.22	+0.50	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.63	N/A	-0.92	+1.04	N/A	N/A	N/A	-166	+342	+205

Nomenclature: See separate page