

YIBIN, China

WMO: 564920

Lat: 28.7688N

Lon: 104.6050E

Elev: 504

StdP: 95.41

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.1	-0.4	3.9	7.2	1.0	4.3	6.5	4.3	6.6	3.6	6.7	1.0	320	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	35.3	25.6	34.1	25.3	32.9	24.8	27.4	32.4	26.8	31.6	26.2	30.7	1.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	23.1	30.0	25.6	22.2	29.5	25.1	21.4	29.1	91.3	32.3	88.2	31.8	85.6	30.8	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.4	3.5	3.0	1.7	37.2	1.3	1.3	0.8	38.2	0.0	38.9	-0.7	39.6	-1.7	40.6		
			1.2	28.4	1.2	0.8	0.3	29.0	-0.3	29.5	-1.0	29.9	-1.8	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	8.1	10.6	14.9	20.0	23.2	25.2	27.8	27.7	23.7	19.1	14.7	9.6
	DBStd	7.36	2.39	3.25	3.73	3.74	2.93	2.63	2.50	2.90	3.16	2.76	3.02	2.22
	HDD10.0	136	67	29	3	0	0	0	0	0	0	0	2	34
	HDD18.3	1083	316	216	119	25	2	0	0	0	1	23	112	270
	CDD10.0	3338	9	46	156	300	411	456	552	549	411	283	144	22
	CDD18.3	1246	0	0	13	75	154	206	294	291	162	48	4	0
	CDH23.3	10683	0	1	56	464	1061	1623	3171	3098	1071	134	3	0
CDH26.7	4191	0	0	7	127	349	557	1376	1390	364	22	0	0	
Wind	WSAvg	1.0	0.8	0.9	1.1	1.2	1.3	1.2	1.2	1.2	1.1	0.9	0.8	0.9
Precipitation	PrecAvg	999	20	22	38	68	89	166	192	171	119	65	29	19
	PrecMax	1456	47	43	79	135	178	383	383	328	270	109	77	34
	PrecMin	660	4	5	12	27	31	74	87	40	35	24	4	3
	PrecStd	182	11	11	18	26	37	73	70	70	64	22	15	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	21.4	27.5	32.3	33.9	34.7	36.5	37.4	35.3	29.2	23.7	16.7
		MCWB	10.6	13.7	17.7	20.7	21.5	24.1	26.1	25.6	25.0	21.2	17.5	11.7
	2%	DB	14.5	19.1	24.8	29.8	32.0	32.9	35.1	35.7	32.6	26.6	21.8	15.0
		MCWB	9.7	12.7	16.5	19.9	21.1	23.6	25.8	25.9	24.7	20.3	16.4	11.0
	5%	DB	12.7	17.1	22.7	27.9	30.3	31.5	34.0	34.3	30.5	24.6	20.2	13.8
		MCWB	9.1	12.1	15.7	19.4	21.0	23.5	25.8	25.7	23.8	19.5	16.1	10.6
	10%	DB	11.4	15.4	20.8	26.1	28.5	29.9	32.7	32.8	28.6	23.0	18.8	12.6
MCWB		8.7	11.4	15.2	18.9	20.6	23.5	25.6	25.4	23.0	19.1	15.8	10.0	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	14.3	19.7	23.5	24.5	26.7	28.3	28.4	27.3	23.1	18.3	13.3
		MCDB	14.6	19.7	25.3	29.5	29.1	31.2	33.3	32.9	32.5	26.8	21.5	15.4
	2%	WB	10.3	13.4	17.8	21.6	23.3	25.8	27.5	27.4	25.8	21.4	17.5	12.0
		MCDB	13.0	17.8	22.0	26.9	27.9	29.9	32.5	32.4	30.2	24.5	20.3	14.0
	5%	WB	9.7	12.7	16.6	20.5	22.5	25.0	26.9	26.8	24.7	20.5	16.9	11.1
		MCDB	11.9	16.3	20.9	25.7	27.1	28.9	31.6	31.8	28.9	23.2	19.3	12.9
	10%	WB	9.1	11.8	15.6	19.6	21.7	24.3	26.4	26.2	23.7	19.6	16.2	10.5
MCDB		11.0	14.9	19.9	24.7	26.3	27.9	30.7	31.0	27.6	22.2	18.1	12.1	
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.9	6.4	7.3	7.2	6.3	7.0	7.1	5.6	4.5	4.3	3.6
		MCDBR	7.0	8.4	9.8	10.3	10.4	9.4	9.4	9.5	8.8	7.6	6.6	5.9
		MCWBR	3.2	3.4	3.3	3.1	3.0	2.7	2.9	2.6	2.6	2.4	2.4	2.6
	5% WB	MCDBR	5.9	7.8	8.7	9.0	7.9	7.1	8.0	8.3	7.6	6.2	5.5	4.5
		MCWBR	2.9	3.2	3.4	3.5	3.1	2.8	3.1	2.9	2.8	2.4	2.3	2.3
Clear-Sky Solar Irradiance	taub	0.733	0.755	0.795	0.776	0.713	0.685	0.686	0.719	0.743	0.798	0.799	0.770	
	taud	1.410	1.388	1.363	1.434	1.574	1.653	1.657	1.580	1.520	1.397	1.367	1.382	
	Ebn at Noon	506	549	569	606	650	666	663	635	596	514	459	454	
	Edh at Noon	276	304	330	316	275	253	251	269	278	297	286	273	
All-Sky Solar Radiation	RadAvg	1.62	2.23	3.05	3.85	4.08	3.75	4.73	4.40	3.07	2.12	1.86	1.46	
	RadStd	0.31	0.39	0.42	0.47	0.56	0.64	0.58	0.65	0.50	0.37	0.19	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	-0.33	N/A	N/A	N/A	N/A	N/A		
Regional (5 neighbors)	+0.29	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	+111	+53	

Nomenclature: See separate page