

LIJIANG, China

WMO: 566510

Lat: 26.8476N

Lon: 100.2180E

Elev: 7815

StdP: 10.99

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 29.2	(c) 31.5	(d) 3.5	(e) 8.8	(f) 52.9	(g) 7.2	(h) 10.6	(i) 52.4	(j) 21.4	(k) 53.7	(l) 19.6	(m) 51.9	(n) 2.6	(o) 140	(p) 0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 14.0	(c) 79.5	(d) 59.8	(e) 77.6	(f) 60.1	(g) 75.8	(h) 59.9	(i) 64.6	(j) 73.0	(k) 63.8	(l) 71.7	(m) 63.1	(n) 70.7	(o) 8.8	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.3	112.9	67.2	61.6	110.3	66.7	61.0	107.6	66.2	34.5	73.2	33.9	72.1	33.2	71.0	69.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.3	(b) 16.2	(c) 14.5	(e) 24.2	(f) 83.3	(g) 2.2	(h) 2.2	(i) 22.6	(j) 84.9	(k) 21.3	(l) 86.2	(m) 20.1	(n) 87.5	(o) 18.5	(p) 89.1		
(a) 21.5	(b) 19.0	(c) 17.9	(e) 21.5	(f) 66.4	(g) 1.9	(h) 0.8	(i) 20.1	(j) 67.0	(k) 19.0	(l) 67.4	(m) 17.9	(n) 67.9	(o) 16.5	(p) 68.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	45.6	49.1	53.4	58.9	63.5	67.0	66.0	65.3	62.7	58.2	51.1	46.1		
	DBStd	8.64	4.39	4.72	4.79	4.51	5.16	4.05	3.06	2.70	3.85	3.70	4.06	4.17		
	HDD50	408	149	66	21	2	0	0	0	0	1	0	34	135		
	HDD65	3056	601	445	361	187	88	25	24	28	83	210	417	587		
	CDD50	3070	14	41	125	270	420	509	496	476	382	256	67	14		
	CDD65	237	0	0	0	4	43	84	54	38	14	0	0	0		
	CDH74	828	0	0	3	23	207	317	124	109	41	4	0	0		
	CDH80	47	0	0	0	0	15	26	4	2	0	0	0	0		
(14) Wind	WSAvg	6.4	7.8	9.0	9.0	8.9	7.0	5.6	4.3	4.0	4.1	4.9	5.7	6.3		
(15) Precipitation	PrecAvg	38.1	0.1	0.2	0.5	0.7	2.3	7.1	9.3	8.2	6.0	2.7	0.6	0.2		
	PrecMax	47.7	0.4	0.7	1.9	2.4	7.6	16.5	14.2	19.1	12.4	8.7	2.5	1.4		
	PrecMin	25.6	0.0	0.0	0.0	0.1	0.1	2.0	3.9	4.2	2.6	0.1	0.0	0.0		
	PrecStd	5.3	0.1	0.2	0.5	0.5	1.7	3.3	2.4	3.2	2.2	2.0	0.6	0.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.5	68.9	72.7	76.9	82.1	83.1	79.8	79.2	77.8	74.3	69.4	65.6		
		MCWB	42.8	44.2	47.3	51.9	57.0	60.4	63.2	63.3	62.0	56.8	48.7	43.6		
	2%	DB	62.4	65.1	68.9	73.6	78.8	79.9	77.1	76.9	74.9	71.8	66.6	62.1		
		MCWB	41.3	42.9	46.3	50.7	56.4	60.2	62.8	62.8	61.4	55.8	47.8	42.0		
	5%	DB	59.1	62.3	66.1	71.1	76.2	77.6	75.1	74.8	72.7	69.8	64.4	59.4		
		MCWB	40.0	42.1	45.4	50.3	55.7	60.5	62.8	62.4	60.6	55.0	47.3	41.5		
	10%	DB	56.3	59.5	63.5	68.5	73.7	75.3	72.9	72.5	70.4	67.7	61.9	57.1		
		MCWB	38.7	41.0	44.8	49.4	55.0	60.4	62.5	62.1	60.3	54.3	46.4	40.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.4	46.9	50.0	55.5	61.1	64.7	65.7	65.7	63.9	60.3	53.9	46.5		
		MCDB	61.2	62.5	66.4	69.9	70.9	73.3	74.6	75.3	72.2	68.7	60.4	61.0		
	2%	WB	43.0	44.9	48.3	53.4	59.8	63.8	64.7	64.5	62.9	59.1	51.8	44.5		
		MCDB	58.0	59.8	64.0	67.9	69.9	72.4	72.8	73.1	71.1	67.2	60.2	57.5		
	5%	WB	41.2	43.4	47.1	52.0	58.7	63.0	63.9	63.6	62.1	58.0	50.0	43.1		
		MCDB	55.9	58.5	62.0	66.2	69.1	71.6	71.3	71.5	69.7	65.1	60.2	55.9		
	10%	WB	39.7	42.0	45.9	50.8	57.7	62.2	63.3	62.8	61.2	56.8	48.4	41.8		
		MCDB	53.9	56.9	60.3	65.0	67.8	70.7	70.1	69.9	68.0	63.4	58.5	54.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	20.1	18.9	17.5	16.3	14.0	12.6	13.5	13.6	17.9	21.8	23.2		
		MCDBR	26.0	24.2	22.9	21.0	20.5	17.6	16.6	18.0	18.2	21.4	24.9	25.5		
		MCWBR	12.0	10.6	9.2	7.8	6.8	5.7	5.9	6.4	6.8	8.3	10.7	11.7		
	5% WB	MCDBR	23.4	20.6	18.5	17.8	15.7	14.1	13.6	14.9	14.6	15.7	20.2	23.6		
		MCWBR	11.6	9.6	8.2	7.6	6.2	5.5	5.6	5.9	5.9	6.7	9.8	12.0		
(40) Clear-Sky Solar Irradiance	taub		0.260	0.287	0.369	0.378	0.356	0.349	0.364	0.385	0.360	0.314	0.273	0.253		
	taud		2.576	2.509	2.261	2.310	2.450	2.534	2.479	2.394	2.451	2.554	2.610	2.633		
	Ebn at Noon		319	316	292	292	296	296	291	286	292	303	312	318		
	Edh at Noon		27	31	43	42	36	33	35	38	35	30	26	24		
(44) All-Sky Solar Radiation	RadAvg		1350	1538	1620	1636	1632	1499	1356	1364	1266	1311	1357	1283		
	RadStd		103	129	174	161	156	136	96	118	97	139	133	75		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.85	-1.06	N/A	+1.44	N/A	N/A	-45	-205	+243	+86
(47) Regional (1 neighbor)		+0.79	N/A	N/A	+1.49	N/A	N/A	-45	-205	+243	+86

Nomenclature: See separate page