

HUIZE, China

WMO: 566840

Lat: 26.4020N

Lon: 103.2490E

Elev: 7183

StdP: 11.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	28.7	13.8	14.5	55.4	17.2	17.1	53.4	27.4	55.2	23.0	54.5	6.7	70	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	81.0	60.7	79.1	60.9	77.3	60.7	66.1	74.8	65.3	73.6	64.6	72.5	7.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	116.0	69.4	62.9	112.7	68.7	62.2	109.7	68.1	35.4	75.0	34.7	74.0	34.1	72.7	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.4	17.1	14.7													
			DB	22.5	84.6	3.6	2.5	19.9	86.3	17.8	87.8	15.8	89.2	13.2	91.0
			WB	20.8	67.8	3.7	1.1	18.2	68.6	16.0	69.2	14.0	69.9	11.3	70.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	43.9	48.0	54.8	60.7	64.1	66.3	67.3	66.6	62.8	56.9	50.6	44.3	(6)
(7)		DBStd	10.32	7.28	9.08	7.34	6.68	6.31	4.86	3.26	3.26	4.71	5.36	5.74	6.10	(7)
(8)		HDD50	647	209	128	41	9	1	0	0	0	1	11	58	189	(8)
(9)		HDD65	3192	653	476	318	155	93	44	16	21	92	252	431	641	(9)
(10)		CDD50	3294	21	72	191	329	440	488	536	515	386	226	77	13	(10)
(11)		CDD65	360	0	0	2	25	66	82	86	71	27	1	0	0	(11)
(12)		CDH74	1396	0	0	11	156	423	319	210	195	79	3	0	0	(12)
(13)		CDH80	106	0	0	0	5	50	35	6	8	2	0	0	0	(13)
(14)	Wind	WSAvg	6.3	7.8	8.6	8.6	7.6	6.3	5.4	4.7	4.4	4.8	5.3	5.9	6.6	(14)
(15)	Precipitation	PrecAvg	30.6	0.3	0.4	0.6	1.3	3.0	5.6	6.3	6.0	3.7	2.3	0.8	0.3	(15)
(16)		PrecMax	44.6	1.3	1.1	2.4	4.0	9.0	12.1	11.5	11.5	9.3	6.6	2.6	1.5	(16)
(17)		PrecMin	20.2	0.0	0.0	0.0	0.2	0.2	2.3	1.7	1.3	1.3	0.4	0.0	0.0	(17)
(18)		PrecStd	5.3	0.3	0.3	0.6	0.9	1.9	2.0	2.3	2.6	1.7	1.6	0.7	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.3	71.0	75.5	80.6	84.2	83.9	80.9	81.2	79.2	74.2	69.0	63.5	(19)
(20)		MCWB	44.7	46.4	49.8	54.1	59.3	62.2	64.2	63.6	63.3	59.9	52.5	45.4	(20)	
(21)		2%	DB	62.0	67.4	72.6	77.9	81.1	80.2	78.4	78.4	76.2	71.6	66.0	60.3	(21)
(22)		MCWB	43.5	45.4	48.8	53.5	58.5	62.9	64.1	63.9	62.6	58.4	51.0	45.2	(22)	
(23)		5%	DB	59.3	65.0	70.2	75.7	78.7	77.7	76.4	76.2	73.9	69.3	63.6	57.9	(23)
(24)		MCWB	42.5	44.5	48.1	53.0	58.4	63.0	63.9	63.6	61.5	57.5	50.5	44.7	(24)	
(25)		10%	DB	56.5	62.3	67.7	73.3	75.9	75.1	74.3	73.8	71.5	66.6	61.1	55.2	(25)
(26)		MCWB	41.8	43.7	47.5	52.4	57.9	62.9	63.7	63.1	60.9	56.5	49.7	43.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.7	49.2	53.2	58.5	64.8	66.9	67.1	67.1	65.6	61.9	56.7	49.2	(27)
(28)		MADB	59.9	65.1	67.6	72.9	75.1	75.5	75.1	76.4	74.2	71.0	62.3	57.9	(28)	
(29)		2%	WB	45.5	47.2	51.4	56.6	62.8	65.7	66.1	65.6	64.1	60.4	54.5	47.1	(29)
(30)		MADB	57.8	63.2	66.3	71.5	74.5	74.5	74.3	74.2	72.8	69.1	61.9	57.1	(30)	
(31)		5%	WB	43.9	45.9	50.1	55.3	61.5	64.8	65.3	64.8	63.2	59.1	52.5	45.7	(31)
(32)		MADB	56.0	61.2	65.1	69.9	72.5	73.3	73.1	72.7	71.2	66.8	60.5	55.6	(32)	
(33)		10%	WB	42.6	44.6	48.8	54.0	60.1	64.0	64.6	63.9	62.1	57.7	50.7	44.3	(33)
(34)		MADB	54.1	59.8	63.7	68.5	70.5	72.1	71.9	71.2	69.4	64.2	58.6	53.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	18.3	19.0	20.4	20.0	17.3	13.3	12.0	13.0	13.5	13.5	16.3	16.4	(35)	
(36)		5% DB	MADB	22.9	23.5	23.5	22.9	22.5	18.6	16.5	17.6	18.3	19.2	20.3	20.7	(36)
(37)		MCWBR	9.9	9.2	8.0	6.6	6.3	6.0	5.8	6.1	6.8	7.8	8.7	9.4	(37)	
(38)		5% WB	MADB	22.0	22.7	22.4	21.1	18.2	14.3	13.0	14.2	15.1	15.7	17.4	19.4	(38)
(39)		MCWBR	10.9	10.1	9.0	7.6	7.0	5.9	5.4	5.8	6.5	7.3	8.8	9.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.366	0.527	0.543	0.488	0.476	0.491	0.528	0.499	0.474	0.412	0.377	(40)	
(41)		taud	2.261	2.234	1.769	1.790	2.002	2.096	2.044	1.912	1.965	1.972	2.072	2.157	(41)	
(42)		Ebn at Noon	282	287	246	246	259	261	257	247	250	248	257	266	(42)	
(43)		Edh at Noon	37	42	70	70	57	52	54	62	57	53	45	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1177	1479	1666	1792	1663	1388	1419	1374	1194	1053	1157	1034	(44)	
(45)		RadStd	133	209	147	190	181	183	121	134	139	120	150	124	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.72	N/A	N/A	+1.66	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.77	N/A	N/A	+1.55	N/A	N/A	N/A	-130	+216	+79

Nomenclature: See separate page