

HUIZE, China

WMO: 566840

Lat: 26.4020N

Lon: 103.2490E

Elev: 2189

StdP: 77.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.8	-10.1	2.1	13.0	-8.2	2.4	11.9	12.3	12.9	10.3	12.5	3.0	70	0.424

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	27.2	15.9	26.2	16.0	25.2	15.9	18.9	23.8	18.5	23.1	18.1	22.5	3.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.6	16.6	20.8	17.2	16.1	20.4	16.8	15.7	20.1	64.5	23.9	62.9	23.3	61.4	22.6	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.1	(b) 7.6	(c) 6.6	(e) -5.3	(f) 29.2	(g) 2.0	(h) 1.4	(i) -6.7	(j) 30.2	(k) -7.9	(l) 31.0	(m) -9.0	(n) 31.8	(o) -10.5	(p) 32.8		
(a) 9.1	(b) 7.6	(c) 6.6	(e) -6.2	(f) 19.9	(g) 2.0	(h) 0.6	(i) -7.7	(j) 20.3	(k) -8.9	(l) 20.7	(m) -10.0	(n) 21.0	(o) -11.5	(p) 21.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	6.6	8.9	12.7	15.9	17.9	19.0	19.6	19.2	17.1	13.8	10.3	6.9
	DBStd	5.73	4.05	5.05	4.08	3.71	3.50	2.70	1.81	1.81	2.62	2.98	3.19	3.39
	HDD10.0	359	116	71	23	5	1	0	0	0	1	6	32	105
	HDD18.3	1773	363	264	177	86	52	24	9	12	51	140	239	356
	CDD10.0	1830	12	40	106	183	244	271	298	286	214	126	43	7
	CDD18.3	200	0	0	1	14	37	46	48	39	15	1	0	0
	CDH23.3	776	0	0	6	87	235	177	117	108	44	2	0	0
	CDH26.7	59	0	0	0	3	28	19	3	4	1	0	0	0
Wind	WSAvg	2.8	3.5	3.8	3.9	3.4	2.8	2.4	2.1	2.0	2.1	2.4	2.7	3.0
Precipitation	PrecAvg	776	7	9	15	33	77	143	160	152	93	59	20	7
	PrecMax	1132	34	27	60	102	229	307	291	293	236	168	67	37
	PrecMin	514	0	0	0	4	4	59	44	33	33	10	1	0
	PrecStd	134	8	8	14	23	49	52	59	67	44	40	19	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	21.6	24.2	27.0	29.0	28.8	27.2	27.3	26.2	23.5	20.5	17.5
		MCWB	7.1	8.0	9.9	12.3	15.2	16.8	17.9	17.5	17.4	15.5	11.4	7.4
	2%	DB	16.7	19.7	22.5	25.5	27.3	26.8	25.8	25.8	24.6	22.0	18.9	15.7
		MCWB	6.4	7.4	9.3	11.9	14.7	17.2	17.8	17.7	17.0	14.7	10.5	7.4
	5%	DB	15.2	18.3	21.2	24.3	25.9	25.4	24.7	24.5	23.3	20.7	17.6	14.4
		MCWB	5.8	6.9	8.9	11.7	14.7	17.2	17.7	17.5	16.4	14.2	10.3	7.0
	10%	DB	13.6	16.8	19.8	22.9	24.4	24.0	23.5	23.2	21.9	19.2	16.2	12.9
		MCWB	5.4	6.5	8.6	11.4	14.4	17.2	17.6	17.3	16.1	13.6	9.8	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	9.5	11.8	14.7	18.2	19.4	19.5	19.5	18.6	16.6	13.7	9.5
		MCDB	15.5	18.4	19.8	22.7	23.9	24.2	23.9	24.7	23.4	21.7	16.9	14.4
	2%	WB	7.5	8.5	10.8	13.6	17.1	18.7	18.9	18.7	17.9	15.8	12.5	8.4
		MCDB	14.3	17.3	19.1	22.0	23.6	23.6	23.5	23.5	22.7	20.6	16.6	13.9
	5%	WB	6.6	7.7	10.1	12.9	16.4	18.2	18.5	18.2	17.3	15.1	11.4	7.6
		MCDB	13.4	16.2	18.4	21.1	22.5	22.9	22.8	22.6	21.8	19.4	15.8	13.1
	10%	WB	5.9	7.0	9.4	12.2	15.6	17.8	18.1	17.7	16.7	14.3	10.4	6.9
		MCDB	12.3	15.4	17.6	20.3	21.4	22.3	22.1	21.8	20.8	17.9	14.8	12.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.6	11.3	11.1	9.6	7.4	6.7	7.2	7.5	7.5	9.1	9.1
		MCDBR	12.7	13.1	13.1	12.7	12.5	10.3	9.1	9.8	10.2	10.6	11.3	11.5
		MCWBR	5.5	5.1	4.5	3.6	3.5	3.3	3.2	3.4	3.8	4.3	4.8	5.2
	5% WB	MCDBR	12.2	12.6	12.5	11.7	10.1	7.9	7.2	7.9	8.4	8.7	9.7	10.8
		MCWBR	6.0	5.6	5.0	4.2	3.9	3.3	3.0	3.2	3.6	4.1	4.9	5.4
Clear-Sky Solar Irradiance	taub	0.351	0.366	0.527	0.543	0.488	0.476	0.491	0.528	0.499	0.474	0.412	0.377	
	taud	2.261	2.234	1.769	1.790	2.002	2.096	2.044	1.912	1.965	1.972	2.072	2.157	
	Ebn at Noon	890	906	775	776	818	822	809	778	789	782	810	838	
	Edh at Noon	118	131	221	222	180	163	171	194	179	168	142	126	
All-Sky Solar Radiation	RadAvg	3.71	4.66	5.25	5.65	5.24	4.38	4.47	4.33	3.76	3.32	3.65	3.26	
	RadStd	0.42	0.66	0.46	0.60	0.57	0.58	0.38	0.42	0.44	0.38	0.47	0.39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.43	N/A	N/A	+0.86	N/A	N/A	N/A	-72	+120	+44

Nomenclature: See separate page