

TENGCHONG, China

WMO: 567390

Lat: 24.9844N

Lon: 98.5056E

Elev: 5567

StdP: 11.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.1	36.7	26.0	24.5	55.5	28.3	27.4	51.4	15.3	59.7	13.9	60.0	2.4	0	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	80.9	65.1	79.2	64.7	77.6	64.3	69.1	76.1	68.3	74.7	67.7	73.5	7.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	123.2	71.6	66.5	120.4	70.6	66.0	118.4	70.0	37.1	76.7	36.3	75.1	35.8	73.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.2	11.5	9.9	32.0	84.4	1.0	1.6	31.2	85.5	30.7	86.4	30.1	87.3	29.4	88.4		
			30.0	70.8	1.1	0.9	29.1	71.4	28.5	72.0	27.8	72.5	27.0	73.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	49.3	52.2	57.6	62.5	66.5	68.9	68.9	70.0	68.7	64.4	57.1	51.3
	DBStd	7.88	2.48	3.18	3.38	3.14	3.13	2.38	2.63	2.54	2.70	3.35	3.41	2.90
	HDD50	76	43	13	1	0	0	0	0	0	0	0	0	19
	HDD65	1902	487	358	228	84	21	1	2	0	5	53	238	425
	CDD50	4267	20	75	238	376	510	566	586	619	560	445	213	59
	CDD65	618	0	0	0	10	66	117	123	154	115	33	0	0
	CDH74	1587	0	1	30	168	297	205	196	360	247	82	1	0
	CDH80	86	0	0	0	3	20	14	11	28	9	1	0	0
Wind	WSAvg	4.0	4.0	4.3	4.5	4.3	4.1	4.3	4.3	3.8	3.5	3.5	3.6	3.6
Precipitation	PrecAvg	57.0	0.8	1.1	1.5	3.1	5.6	10.0	11.3	10.0	6.8	5.5	1.7	0.7
	PrecMax	74.0	3.5	4.4	5.6	7.0	12.7	19.7	18.2	18.8	11.1	17.3	11.1	5.5
	PrecMin	44.4	0.0	0.0	0.0	0.3	0.4	2.8	4.5	2.3	2.0	0.8	0.0	0.0
	PrecStd	8.5	0.9	1.1	1.2	1.5	3.3	3.9	2.7	3.1	2.4	3.1	2.0	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.4	72.1	77.2	80.1	82.4	82.2	81.5	82.9	81.1	78.7	73.4	67.1
		MCWB	48.5	50.9	53.3	57.4	61.7	65.3	68.3	67.9	65.2	63.4	58.2	51.6
	2%	DB	64.3	68.7	74.3	77.9	79.6	78.9	78.6	80.3	78.9	76.3	70.9	65.0
		MCWB	48.3	50.1	53.2	57.1	62.2	66.0	68.1	68.0	65.8	62.9	56.8	50.9
	5%	DB	62.3	66.3	72.2	76.0	77.4	76.3	76.1	78.0	77.0	74.3	68.8	63.4
		MCWB	47.6	49.7	53.0	57.1	62.2	66.4	67.7	67.7	65.7	62.1	55.8	50.1
	10%	DB	60.3	64.1	69.8	73.7	75.1	73.9	73.7	75.7	74.8	72.2	66.7	61.6
		MCWB	47.1	49.1	52.5	57.1	62.3	66.1	67.2	67.4	65.8	61.4	54.7	49.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.2	54.6	58.2	62.6	66.7	68.8	70.0	70.4	69.0	66.5	62.2	55.7
		MCDB	60.8	63.6	68.0	71.2	75.1	75.5	77.5	78.1	76.2	74.5	67.1	60.5
	2%	WB	50.6	52.9	56.4	61.1	65.7	67.9	69.0	69.2	67.9	65.3	60.4	53.8
		MCDB	59.4	63.1	67.7	70.7	73.4	74.1	75.5	76.4	74.8	72.2	65.4	60.6
	5%	WB	49.3	51.6	55.2	60.0	64.9	67.3	68.2	68.4	67.1	64.4	58.8	52.1
		MCDB	58.6	62.3	66.8	69.9	71.6	72.7	73.9	74.9	73.5	70.3	64.3	60.2
	10%	WB	48.1	50.3	54.0	58.8	64.1	66.6	67.4	67.8	66.4	63.5	57.2	50.7
		MCDB	57.8	61.2	65.8	69.0	70.2	71.4	72.2	73.7	72.2	68.7	63.7	59.1
Mean Daily Temperature Range	5% DB	MDBR	23.0	23.5	22.9	20.1	15.0	9.2	8.3	10.7	11.9	15.1	19.6	21.5
		MCDBR	26.1	27.1	27.4	25.0	20.6	14.3	13.2	15.1	15.8	18.4	21.7	23.1
		MCWBR	12.7	12.1	10.9	9.3	7.1	4.4	4.8	5.1	5.3	7.0	9.6	11.2
	5% WB	MCDBR	21.5	22.5	21.9	19.2	13.8	10.4	11.0	12.7	12.6	13.2	15.7	19.4
		MCWBR	11.3	11.0	9.9	8.6	5.4	4.0	4.5	4.9	4.9	5.1	7.6	10.1
Clear-Sky Solar Irradiance	taub	0.312	0.357	0.521	0.533	0.450	0.404	0.392	0.419	0.409	0.369	0.319	0.306	
	taud	2.438	2.317	1.831	1.870	2.198	2.416	2.445	2.341	2.340	2.416	2.481	2.490	
	Ebn at Noon	301	292	249	249	270	280	284	277	278	285	296	299	
	Edh at Noon	32	39	66	65	47	37	36	40	39	35	30	29	
All-Sky Solar Radiation	RadAvg	1338	1538	1588	1561	1448	1221	1167	1294	1279	1273	1347	1244	
	RadStd	105	142	165	151	169	117	90	113	104	132	106	93	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+65
(47)	Regional (5 neighbors)	+0.45	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	+65

Nomenclature: See separate page