

TENGCHONG, China

WMO: 567390

Lat: 24.9844N

Lon: 98.5056E

Elev: 1697

StdP: 82.53

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	2.6	-3.3	3.5	13.1	-2.1	3.9	10.8	6.8	15.4	6.2	15.6	1.1	0	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	27.1	18.4	26.2	18.2	25.3	17.9	20.6	24.5	20.2	23.7	19.8	23.1	3.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	17.6	22.0	19.2	17.2	21.5	18.9	16.9	21.1	68.3	24.8	66.7	23.9	65.4	23.3	22.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.9	5.1	4.4	0.0	29.1	0.6	0.9	-0.4	29.7	-0.7	30.2	-1.0	30.7	-1.4	31.3		
			-1.1	21.5	0.6	0.5	-1.6	21.9	-2.0	22.2	-2.3	22.5	-2.8	22.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	9.6	11.2	14.2	17.0	19.1	20.5	20.5	21.1	20.4	18.0	13.9	10.7
	DBStd	4.38	1.38	1.77	1.88	1.75	1.74	1.32	1.46	1.41	1.50	1.86	1.89	1.61
	HDD10.0	42	24	7	1	0	0	0	0	0	0	0	0	11
	HDD18.3	1057	271	199	127	47	12	1	1	0	3	29	132	236
	CDD10.0	2371	11	42	132	209	283	314	326	344	311	247	118	33
	CDD18.3	343	0	0	0	6	37	65	68	86	64	18	0	0
	CDH23.3	882	0	1	17	93	165	114	109	200	137	46	1	0
	CDH26.7	48	0	0	0	2	11	8	6	16	5	1	0	0
Wind	WSAvg	1.8	1.8	1.9	2.0	1.9	1.8	1.9	1.9	1.7	1.6	1.5	1.6	1.6
Precipitation	PrecAvg	1447	21	29	39	79	141	255	287	255	173	140	42	19
	PrecMax	1879	90	113	142	177	323	501	463	477	283	439	283	139
	PrecMin	1127	0	0	0	7	9	70	114	59	51	20	0	0
	PrecStd	216	22	27	30	39	83	98	68	78	61	80	50	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	22.3	25.1	26.7	28.0	27.9	27.5	28.3	27.3	25.9	23.0	19.5
		MCWB	9.2	10.5	11.8	14.1	16.5	18.5	20.2	20.0	18.5	17.5	14.5	10.9
	2%	DB	18.0	20.4	23.5	25.5	26.4	26.0	25.9	26.8	26.1	24.6	21.6	18.4
		MCWB	9.0	10.1	11.8	14.0	16.8	18.9	20.0	20.0	18.8	17.2	13.8	10.5
	5%	DB	16.8	19.1	22.3	24.5	25.2	24.6	24.5	25.6	25.0	23.5	20.5	17.4
		MCWB	8.6	9.8	11.7	13.9	16.8	19.1	19.8	19.9	18.7	16.7	13.2	10.1
	10%	DB	15.7	17.8	21.0	23.2	23.9	23.3	23.2	24.3	23.8	22.3	19.3	16.4
		MCWB	8.4	9.5	11.4	14.0	16.8	18.9	19.5	19.7	18.8	16.3	12.6	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	12.6	14.5	17.0	19.3	20.5	21.1	21.3	20.5	19.2	16.8	13.2
		MCDB	16.0	17.5	20.0	21.8	23.9	24.2	25.3	25.6	24.6	23.6	19.5	15.8
	2%	WB	10.4	11.6	13.6	16.2	18.7	20.0	20.5	20.7	19.9	18.5	15.8	12.1
		MCDB	15.2	17.3	19.8	21.5	23.0	23.4	24.2	24.7	23.8	22.3	18.6	15.9
	5%	WB	9.6	10.9	12.9	15.5	18.3	19.6	20.1	20.2	19.5	18.0	14.9	11.2
		MCDB	14.8	16.8	19.4	21.1	22.0	22.6	23.3	23.8	23.0	21.3	18.0	15.7
	10%	WB	9.0	10.2	12.2	14.9	17.9	19.2	19.7	19.9	19.1	17.5	14.0	10.4
		MCDB	14.3	16.2	18.8	20.5	21.2	21.9	22.4	23.2	22.3	20.4	17.6	15.1
Mean Daily Temperature Range	5% DB	MDBR	12.8	13.0	12.7	11.2	8.4	5.1	4.6	5.9	6.6	8.4	10.9	12.0
		MCDBR	14.5	15.1	15.2	13.9	11.5	8.0	7.4	8.4	8.8	10.2	12.1	12.8
		MCWBR	7.1	6.7	6.1	5.2	4.0	2.5	2.7	2.8	2.9	3.9	5.3	6.2
	5% WB	MCDBR	12.0	12.5	12.2	10.6	7.7	5.8	6.1	7.1	7.0	7.3	8.7	10.8
MCWBR		6.3	6.1	5.5	4.8	3.0	2.2	2.5	2.7	2.7	2.9	4.2	5.6	
Clear-Sky Solar Irradiance	taub	0.312	0.357	0.521	0.533	0.450	0.404	0.392	0.419	0.409	0.369	0.319	0.306	
	taud	2.438	2.317	1.831	1.870	2.198	2.416	2.445	2.341	2.340	2.416	2.481	2.490	
	Ebn at Noon	948	922	785	786	850	884	894	872	876	899	933	943	
	Edh at Noon	100	122	209	206	148	118	115	127	124	109	96	92	
All-Sky Solar Radiation	RadAvg	4.22	4.85	5.01	4.92	4.57	3.85	3.68	4.08	4.03	4.01	4.25	3.92	
	RadStd	0.33	0.45	0.52	0.48	0.53	0.37	0.28	0.35	0.33	0.41	0.33	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+36
(47)	Regional (5 neighbors)	+0.25	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	N/A	+36

Nomenclature: See separate page