

BAOSHAN, China

WMO: 567480

Lat: 25.1234N

Lon: 99.1825E

Elev: 1649

StdP: 83.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.3	(c) 3.3	(d) -3.7	(e) 3.4	(f) 17.0	(g) -2.1	(h) 3.9	(i) 14.6	(j) 7.4	(k) 15.7	(l) 6.5	(m) 16.1	(n) 0.3	(o) 160	(p) 0.289

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 6.5	(c) 28.5	(d) 18.7	(e) 27.6	(f) 18.7	(g) 26.8	(h) 18.5	(i) 21.0	(j) 25.5	(k) 20.6	(l) 25.0	(m) 20.2	(n) 24.4	(o) 2.9	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	17.6	22.8	19.2	17.2	22.4	19.0	16.9	22.1	69.4	25.7	67.8	25.1	66.4	24.6	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.3	5.4	4.8	0.3	30.4	1.3	1.0	-0.6	31.2	-1.3	31.8	-2.1	32.4	-3.0	33.1	
			DB												
			WB	-0.4	21.6	0.8	0.5	-1.0	22.0	-1.4	22.3	-1.9	22.6	-2.5	23.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	10.4	12.2	15.3	18.0	20.7	22.3	22.1	22.3	21.2	18.9	14.6	11.3
	DBStd	4.65	1.46	1.87	1.96	1.78	2.07	1.37	1.39	1.29	1.69	1.92	1.97	1.66
	HDD10.0	21	12	3	1	0	0	0	0	0	0	0	0	6
	HDD18.3	896	245	171	97	26	5	0	0	0	3	17	114	219
	CDD10.0	2747	25	66	163	242	331	371	376	380	337	276	137	45
	CDD18.3	581	0	0	1	17	77	121	117	122	90	34	1	0
	CDH23.3	2198	0	1	37	179	422	424	332	411	284	106	2	0
CDH26.7	206	0	0	1	9	61	49	26	41	17	3	0	0	
Wind	WSAvg	1.5	1.4	1.7	1.8	1.7	1.7	1.7	1.5	1.3	1.3	1.3	1.2	1.2
Precipitation	PrecAvg	961	13	27	33	44	65	146	162	175	125	117	36	17
	PrecMax	1243	76	73	105	96	171	320	250	289	275	347	136	104
	PrecMin	731	0	0	0	8	1	17	74	96	37	29	0	0
	PrecStd	134	16	19	24	22	45	81	48	53	58	75	39	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	23.2	25.6	27.7	29.9	29.7	28.7	29.1	28.2	26.9	23.4	20.2
		MCWB	9.9	10.6	12.2	14.8	17.1	18.4	20.3	20.2	19.3	17.9	14.6	11.0
	2%	DB	18.8	21.4	24.3	26.5	28.3	28.1	27.4	27.8	27.1	25.6	22.2	19.1
		MCWB	9.3	10.3	12.1	14.4	17.1	19.0	20.3	20.1	19.1	17.3	13.9	10.5
	5%	DB	17.7	20.1	23.2	25.4	27.0	26.8	26.3	26.7	26.1	24.6	21.1	18.1
		MCWB	8.9	10.2	11.8	14.1	17.0	19.2	20.0	20.0	19.1	16.9	13.3	10.1
	10%	DB	16.6	18.9	21.9	24.2	25.8	25.7	25.2	25.7	25.1	23.4	19.9	17.1
		MCWB	8.6	9.7	11.5	13.9	16.7	19.1	19.8	19.9	18.9	16.5	12.6	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	12.6	14.4	16.9	19.5	20.7	21.6	21.6	20.9	19.4	16.8	13.3
		MCDB	17.2	19.3	21.7	23.8	25.0	25.7	25.9	26.4	25.7	23.7	20.2	16.7
	2%	WB	10.6	11.7	13.6	16.1	18.9	20.2	21.0	21.0	20.2	18.6	15.9	12.1
		MCDB	16.5	18.5	21.1	22.8	24.0	25.1	25.4	25.5	24.8	23.0	19.4	16.9
	5%	WB	9.8	11.0	13.0	15.5	18.4	19.8	20.5	20.6	19.7	18.1	15.0	11.2
		MCDB	15.6	18.1	20.6	22.2	23.4	24.6	24.7	24.9	24.2	22.4	18.5	16.2
	10%	WB	9.2	10.3	12.4	15.0	17.9	19.5	20.1	20.2	19.4	17.6	14.0	10.5
		MCDB	15.0	17.5	19.8	21.6	22.8	24.0	24.1	24.4	23.7	21.6	18.2	15.6
Mean Daily Temperature Range	5% DB	MDBR	13.1	13.3	12.8	11.4	8.9	6.5	5.8	6.7	7.3	8.6	11.0	12.4
		MCDBR	15.0	15.5	15.3	13.8	11.4	8.7	7.8	8.8	9.1	10.3	11.9	13.4
		MCWBR	6.7	6.4	5.7	4.6	3.2	2.4	2.4	2.6	2.8	3.3	4.6	5.9
	5% WB	MCDBR	12.9	12.9	12.3	11.2	8.1	6.6	6.8	7.5	7.7	7.9	8.7	11.2
		MCWBR	6.3	5.9	5.1	4.4	2.7	2.3	2.4	2.7	2.7	2.7	3.7	5.4
Clear-Sky Solar Irradiance	taub	0.316	0.357	0.518	0.526	0.445	0.401	0.400	0.430	0.415	0.372	0.324	0.312	
	taud	2.433	2.319	1.835	1.890	2.220	2.425	2.418	2.307	2.326	2.409	2.471	2.477	
	Ebn at Noon	943	921	786	791	855	886	886	862	871	895	927	934	
	Edh at Noon	101	122	208	202	145	117	118	131	126	110	96	93	
All-Sky Solar Radiation	RadAvg	4.23	4.87	5.01	4.92	4.72	4.17	3.88	4.23	4.10	4.00	4.25	3.93	
	RadStd	0.34	0.46	0.56	0.50	0.52	0.39	0.28	0.35	0.33	0.44	0.36	0.30	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.40	N/A	N/A	+0.48	N/A	-0.13	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.24	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	+70	+44

Nomenclature: See separate page