

DALI, China

WMO: 567510

Lat: 25.7075N

Lon: 100.1767E

Elev: 6535

StdP: 11.54

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 34.7	(c) 36.7	(d) 18.0	(e) 17.3	(f) 58.1	(g) 21.4	(h) 20.4	(i) 56.6	(j) 31.7	(k) 55.0	(l) 26.4	(m) 57.6	(n) 2.8	(o) 250	(p) 0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 13.5	(c) 81.7	(d) 64.2	(e) 80.0	(f) 64.0	(g) 78.5	(h) 63.7	(i) 68.1	(j) 76.9	(k) 67.4	(l) 75.8	(m) 66.6	(n) 74.7	(o) 6.3	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	120.5	72.3	64.7	117.3	71.4	64.1	114.9	70.7	36.9	77.2	36.2	76.2	35.5	75.2	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.9	(b) 16.9	(c) 14.1	(e) 30.8	(f) 84.8	(g) 2.4	(h) 2.1	(i) 29.1	(j) 86.2	(k) 27.7	(l) 87.4	(m) 26.4	(n) 88.6	(o) 24.6	(p) 90.1		
(a) 20.9	(b) 16.9	(c) 14.1	(e) 28.4	(f) 69.5	(g) 1.9	(h) 0.9	(i) 27.1	(j) 70.2	(k) 26.0	(l) 70.8	(m) 24.9	(n) 71.3	(o) 23.6	(p) 72.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.1	49.4	52.7	57.7	62.9	66.9	69.8	69.2	68.9	66.8	62.5	55.3	50.0
	DBStd	8.23	3.63	4.06	4.29	4.00	4.40	3.30	2.96	2.72	3.71	3.62	3.55	3.52
	HDD50	118	54	17	3	0	0	0	0	0	0	0	2	42
	HDD65	2056	484	344	228	82	31	5	5	5	24	94	290	464
	CDD50	4156	36	92	242	388	525	595	597	586	503	386	163	43
	CDD65	616	0	0	1	19	92	149	137	126	77	15	0	0
	CDH74	2138	1	0	8	129	470	570	384	340	211	25	0	0
	CDH80	154	0	0	0	3	45	64	22	16	4	0	0	0
Wind	WSAvg	5.3	7.0	7.8	7.8	6.9	5.5	4.3	3.7	3.5	3.6	3.8	4.4	5.1
Precipitation	PrecAvg	41.5	0.6	1.0	1.3	0.9	2.4	7.4	7.1	8.6	6.3	3.9	1.3	0.6
	PrecMax	55.7	2.2	2.7	3.3	2.1	6.5	14.2	13.8	14.2	12.0	11.1	7.0	4.6
	PrecMin	25.6	0.0	0.0	0.0	0.1	0.0	2.2	2.8	4.2	1.7	0.2	0.0	0.0
	PrecStd	7.8	0.6	0.8	1.1	0.6	1.8	3.3	2.7	2.8	2.6	2.8	1.5	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.0	70.6	75.0	80.0	83.7	84.8	82.5	82.0	80.6	76.8	70.8	66.7
		MCWB	47.1	48.0	51.8	56.0	61.4	65.1	67.3	66.4	65.9	61.7	54.7	48.9
	2%	DB	63.6	67.7	72.4	77.4	81.1	81.7	79.9	79.7	78.4	74.4	68.4	63.6
		MCWB	45.6	47.8	50.9	54.7	60.6	64.9	66.8	66.5	65.1	60.7	53.4	47.6
	5%	DB	61.2	65.4	70.2	75.3	78.8	79.5	78.1	77.7	76.6	72.6	66.5	61.5
		MCWB	44.8	46.9	50.3	54.0	60.0	64.8	66.7	66.2	64.4	59.7	52.7	47.0
	10%	DB	59.0	63.0	67.9	72.9	76.6	77.3	76.1	75.8	74.6	70.6	64.4	59.5
		MCWB	44.0	46.0	49.4	53.5	59.2	64.9	66.3	65.8	63.9	58.7	51.6	46.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.7	51.4	54.8	58.8	65.2	68.4	69.3	68.9	67.4	64.1	58.5	52.6
		MCDB	61.7	65.4	69.4	72.6	76.8	77.2	78.2	77.8	77.0	73.6	64.7	60.9
	2%	WB	47.7	49.5	53.1	57.3	63.7	67.5	68.3	67.9	66.3	62.7	57.1	50.0
		MCDB	59.7	63.4	67.6	70.8	74.4	76.4	76.9	76.5	75.5	70.9	63.1	60.2
	5%	WB	46.2	48.3	51.9	56.2	62.7	66.6	67.4	67.1	65.5	61.7	55.4	48.5
		MCDB	57.9	62.4	66.0	69.8	73.0	75.5	75.6	75.2	74.0	69.0	62.7	58.8
	10%	WB	44.9	47.0	50.7	55.1	61.7	65.9	66.6	66.3	64.7	60.7	53.7	47.3
		MCDB	56.5	60.7	64.6	68.7	71.4	74.4	74.2	73.9	72.4	67.2	61.8	57.3
Mean Daily Temperature Range	5% DB	MDBR	20.3	20.0	19.3	18.3	16.0	13.5	12.4	13.2	13.8	14.7	18.4	20.3
		MCDBR	23.7	24.3	23.3	22.7	20.6	17.7	16.6	17.1	17.6	17.8	20.7	22.0
		MCWBR	10.6	10.3	9.1	7.3	6.0	5.6	6.2	6.2	6.2	6.4	8.6	9.8
	5% WB	MCDBR	21.8	21.7	19.9	18.9	15.7	14.2	14.2	14.8	15.1	13.9	16.5	20.5
		MCWBR	10.9	10.1	8.5	6.9	5.4	5.5	5.9	6.1	5.7	5.3	7.7	10.3
Clear-Sky Solar Irradiance	taub	0.287	0.317	0.433	0.440	0.396	0.372	0.385	0.410	0.387	0.345	0.302	0.286	
	taud	2.510	2.435	2.060	2.119	2.351	2.482	2.430	2.335	2.382	2.477	2.529	2.543	
	Ebn at Noon	310	306	273	274	285	289	285	279	284	293	302	306	
	Edh at Noon	29	34	53	51	40	35	37	40	38	32	29	27	
All-Sky Solar Radiation	RadAvg	1360	1582	1663	1663	1625	1495	1335	1367	1299	1269	1351	1258	
	RadStd	101	141	185	166	180	131	79	103	108	149	134	91	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.74	N/A	N/A	+1.55	N/A	-0.61	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.58	N/A	N/A	+1.15	N/A	-0.23	N/A	-95	+164

Nomenclature: See separate page