

CHUXIONG, China

WMO: 567680

Lat: 25.0346N

Lon: 101.5541E

Elev: 5971

StdP: 11.79

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	38.0	21.1	19.7	64.4	24.1	22.8	62.4	19.4	61.3	17.4	62.5	1.7	320	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.9	84.3	62.3	82.5	62.2	80.8	62.6	68.1	76.9	67.4	75.8	66.9	75.0	8.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	118.7	70.9	65.1	116.4	70.6	64.6	114.2	70.3	36.4	77.2	35.8	76.3	35.3	75.4	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	14.5	12.2		31.7	87.7	1.7	1.8	30.4	89.0	29.4	90.1	28.5	91.1	27.2	92.4
			DB	30.4	69.3	1.9	0.8	29.0	69.9	27.9	70.4	26.9	70.9	25.5	71.5
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.2	50.7	54.9	60.8	66.6	70.2	72.1	71.2	70.6	68.2	64.1	57.0	51.2
	DBStd	8.60	3.44	4.67	4.74	4.66	5.12	3.72	2.84	2.58	3.71	3.90	3.84	3.80
	HDD50	78	31	12	3	0	0	0	0	0	0	0	2	30
	HDD65	1675	445	282	140	37	18	3	1	1	16	63	242	427
	CDD50	4880	51	150	339	497	625	662	656	639	546	437	211	67
	CDD65	1001	0	0	11	83	178	215	192	175	112	35	0	0
	CDH74	4274	0	8	110	584	1091	990	610	528	282	69	2	0
	CDH80	546	0	0	2	65	214	162	51	41	11	0	0	0
Wind	WSAvg	4.6	4.6	5.7	6.3	6.3	5.4	4.8	3.8	3.3	3.6	3.9	3.8	4.0
Precipitation	PrecAvg	34.1	0.6	0.4	0.6	0.8	3.3	5.4	7.6	6.7	4.6	2.7	1.1	0.4
	PrecMax	49.7	4.8	1.8	2.3	4.4	12.0	10.1	13.9	13.2	9.1	6.5	4.6	0.9
	PrecMin	23.6	0.0	0.0	0.0	0.0	0.2	1.7	2.9	3.6	1.4	0.2	0.0	0.0
	PrecStd	7.0	0.9	0.4	0.6	0.9	2.6	2.2	2.8	2.4	2.0	1.7	1.1	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.4	75.2	79.2	84.4	87.2	86.9	83.7	83.4	81.5	78.0	73.5	68.9
		MCWB	48.1	50.2	52.7	56.7	61.8	64.5	66.2	66.4	65.3	62.5	55.9	51.4
	2%	DB	66.8	71.9	76.9	82.0	84.5	83.9	81.3	80.9	79.2	76.0	70.8	65.9
		MCWB	47.8	49.8	52.2	56.1	60.8	64.6	66.2	66.3	65.1	61.6	55.5	50.0
	5%	DB	64.5	69.7	74.8	79.8	82.4	81.6	79.6	79.0	77.3	74.2	68.6	63.7
		MCWB	47.3	49.1	51.9	55.6	60.2	64.8	66.3	66.1	64.7	61.1	54.8	49.6
	10%	DB	62.1	67.4	72.7	77.6	80.1	79.5	77.6	77.1	75.3	72.2	66.5	61.5
		MCWB	46.8	48.4	51.3	55.3	60.1	64.9	66.1	65.9	64.4	60.6	54.3	49.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	53.8	56.7	61.0	66.1	68.3	69.0	68.7	67.5	65.1	61.2	54.9
		MCDB	62.3	68.1	70.3	75.7	76.8	77.5	77.6	77.9	76.5	74.1	66.7	63.3
	2%	WB	50.5	52.1	55.3	59.1	64.9	67.4	68.1	67.9	66.6	63.9	59.2	53.1
		MCDB	61.2	66.9	69.4	74.4	75.4	76.6	76.6	76.8	75.1	72.2	66.2	61.3
	5%	WB	49.3	50.8	54.0	58.0	63.9	66.7	67.5	67.3	66.0	63.0	57.6	51.6
		MCDB	60.0	65.6	68.7	73.2	74.2	75.9	75.5	75.4	74.1	70.6	64.4	60.2
	10%	WB	48.1	49.6	52.9	57.0	63.0	66.2	66.9	66.6	65.3	62.1	56.1	50.3
		MCDB	58.6	64.2	68.0	72.0	73.1	75.4	74.4	74.1	72.9	69.0	63.4	58.6
Mean Daily Temperature Range	5% DB	MDBR	21.7	22.1	20.9	19.0	15.6	12.9	11.4	12.3	12.5	13.6	17.6	19.1
		MCDBR	26.8	26.2	24.4	22.1	19.0	16.5	15.2	16.0	15.8	17.3	20.8	23.7
		MCWBR	10.9	9.7	7.7	6.0	4.5	4.0	4.1	4.3	4.5	5.5	8.2	10.2
	5% WB	MCDBR	22.1	23.2	20.4	18.7	15.1	12.6	12.2	13.1	13.1	13.5	15.2	18.7
		MCWBR	10.5	9.4	7.5	6.2	4.6	4.0	4.1	4.3	4.4	4.7	6.8	9.1
Clear-Sky Solar Irradiance	taub	0.314	0.335	0.481	0.472	0.415	0.389	0.407	0.443	0.422	0.390	0.342	0.330	
	taud	2.447	2.391	1.927	2.028	2.306	2.429	2.360	2.233	2.274	2.335	2.412	2.411	
	Ebn at Noon	300	300	260	265	279	285	279	270	274	278	287	289	
	Edh at Noon	32	36	60	56	42	37	40	45	42	37	33	32	
All-Sky Solar Radiation	RadAvg	1302	1601	1698	1767	1686	1524	1393	1413	1282	1186	1272	1144	
	RadStd	113	156	160	161	205	149	94	108	95	150	136	114	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.59	N/A	N/A	+1.44	-0.20	-0.41	N/A	N/A	+126	N/A

Nomenclature: See separate page