

LUXI, China

WMO: 568860

Lat: 24.533N

Lon: 103.767E

Elev: 5604

StdP: 11.95

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.6	33.8	25.4	23.9	53.9	28.4	27.5	49.6	26.7	64.7	23.3	64.2	3.2	180	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.4	84.3	61.7	82.2	62.9	80.3	63.7	69.5	77.6	68.8	76.6	68.1	75.5	13.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.3	123.8	72.8	66.5	120.7	72.0	65.9	118.0	71.4	37.5	77.9	36.8	77.0	36.2	75.8	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	19.0	16.6	27.2	87.6	3.0	1.9	25.0	88.9	23.2	90.1	21.5	91.2	19.3	92.6		
(5)			26.2	71.0	3.1	0.9	24.0	71.7	22.2	72.2	20.4	72.8	18.2	73.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	48.3	52.1	59.0	65.6	69.0	70.4	70.3	69.6	67.0	62.5	55.5	49.3		
	DBStd	9.54	6.53	7.71	6.15	5.65	5.05	3.53	2.28	2.36	3.64	4.57	5.14	5.62		
	HDD50	282	107	65	13	0	0	0	0	0	0	0	15	82		
	HDD65	2059	518	361	195	60	23	5	1	2	22	99	286	487		
	CDD50	4513	54	124	290	469	589	612	629	608	509	389	180	60		
	CDD65	811	0	0	7	78	147	167	165	144	81	22	0	0		
	CDH74	3501	0	19	187	718	926	572	413	390	219	52	5	0		
	CDH80	472	0	0	8	135	210	66	21	24	8	0	0	0		
	WSAvg	6.4	7.0	7.9	8.5	8.8	7.8	6.2	5.1	4.4	4.6	5.1	5.8	6.0		
	PrecAvg	37.7	0.6	0.7	0.9	1.5	3.8	7.0	7.2	6.8	4.4	2.7	1.5	0.6		
(15) Precipitation	PrecMax	53.6	1.4	2.6	2.6	3.6	11.1	11.5	16.3	13.3	8.4	6.5	4.1	3.7		
	PrecMin	28.6	0.0	0.0	0.0	0.0	0.3	3.3	2.8	0.7	0.7	0.0	0.2	0.0		
	PrecStd	6.1	0.4	0.7	0.7	0.9	2.5	2.5	3.1	3.1	1.8	1.5	1.1	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	76.5	81.0	86.0	88.0	84.9	82.4	82.5	81.2	77.7	74.4	69.4		
		MCWB	50.8	52.5	54.8	58.0	61.7	67.4	68.1	68.2	67.0	64.1	58.2	52.9		
	2%	DB	67.4	73.4	78.4	83.7	84.9	81.9	80.1	80.0	78.7	75.4	71.1	66.5		
		MCWB	50.3	51.9	54.4	57.7	61.9	67.6	68.2	68.0	66.6	62.7	57.1	52.5		
	5%	DB	64.7	70.6	75.9	81.3	82.2	79.6	78.3	78.2	76.6	73.4	68.6	63.7		
		MCWB	50.0	51.0	54.0	57.9	62.4	67.3	67.9	67.4	65.3	62.2	56.4	51.8		
	10%	DB	61.7	67.5	73.1	78.6	79.4	77.4	76.4	76.1	74.5	71.0	65.9	60.5		
		MCWB	49.5	50.6	53.9	57.7	62.6	67.0	67.6	66.8	64.7	61.4	55.5	51.0		
	0.4%	WB	54.7	56.3	59.3	63.2	68.2	70.2	70.7	70.2	69.0	66.0	61.9	56.7		
		MCDB	64.1	68.6	71.3	75.2	78.0	79.4	78.9	78.9	76.9	74.3	69.6	64.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	52.9	54.5	57.6	61.9	66.9	69.2	69.5	69.2	67.8	64.6	60.1	54.4		
		MCDB	62.6	67.0	70.2	74.6	76.4	77.6	77.0	77.3	75.7	72.1	66.7	62.5		
	5%	WB	51.4	53.1	56.4	60.8	65.9	68.4	68.7	68.3	66.8	63.6	58.4	52.8		
		MCDB	61.2	65.6	69.3	73.3	75.0	76.3	75.9	75.8	74.0	70.4	64.8	60.9		
	10%	WB	50.0	51.6	55.2	59.7	64.9	67.7	68.0	67.5	65.9	62.6	56.7	51.4		
		MCDB	59.8	64.4	68.2	72.2	73.5	74.9	74.7	74.1	72.4	68.7	63.2	59.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	21.9	23.0	21.4	17.0	12.4	12.0	13.0	13.8	13.6	16.9	16.9		
		MCDBR	26.9	29.0	28.7	25.7	22.0	16.1	15.7	16.9	17.5	17.8	21.7	23.3		
		MCWBR	12.3	11.1	9.6	6.5	5.5	5.2	5.8	6.3	6.4	6.9	9.7	11.0		
		MCDBR	23.2	25.0	24.3	21.5	15.7	13.3	13.4	14.6	14.5	14.6	17.4	19.7		
	5% WB	MCWBR	12.1	11.5	9.7	7.3	5.5	5.1	5.5	6.0	5.8	6.2	8.5	10.3		
(40) Clear-Sky Solar Irradiance	taub		0.375	0.384	0.536	0.518	0.428	0.420	0.418	0.453	0.441	0.447	0.404	0.403		
	taud		2.236	2.232	1.791	1.907	2.266	2.319	2.314	2.191	2.202	2.132	2.179	2.127		
	Ebn at Noon		277	284	245	253	276	276	276	267	268	260	265	260		
	Edh at Noon		39	42	69	63	44	41	42	47	45	46	41	43		
(44) All-Sky Solar Radiation	RadAvg		1038	1367	1506	1697	1661	1425	1431	1405	1266	1030	1104	909		
	RadStd		147	234	131	159	173	152	90	83	105	117	132	131		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.83	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		+0.74	N/A	N/A	+1.13	N/A	N/A	N/A	N/A	+196	+110

Nomenclature: See separate page