

LUXI, China

WMO: 568860

Lat: 24.533N

Lon: 103.767E

Elev: 1708

StdP: 82.42

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	1.0	-3.7	3.4	12.2	-2.0	3.9	9.8	11.9	18.2	10.4	17.9	1.4	180	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.9	29.1	16.5	27.9	17.2	26.8	17.6	20.8	25.4	20.5	24.8	20.1	24.2	6.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	17.7	22.7	19.2	17.2	22.2	18.8	16.9	21.9	69.4	25.5	67.8	25.0	66.3	24.4	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4)	10.0	8.5	7.4	DB	-2.7	30.9	1.7	1.1	-3.9	31.6	-4.9	32.3	-5.8	32.9	-7.1	33.6
(5)				WB	-3.2	21.7	1.7	0.5	-4.5	22.1	-5.5	22.4	-6.4	22.6	-7.7	23.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	9.1	11.2	15.0	18.7	20.6	21.3	21.3	20.9	19.4	17.0	13.1	9.6
	DBStd	5.30	3.63	4.28	3.42	3.14	2.80	1.96	1.27	1.31	2.02	2.54	2.86	3.12
	HDD10.0	157	59	36	7	0	0	0	0	0	0	0	8	46
	HDD18.3	1144	288	201	108	33	13	3	1	1	12	55	159	271
	CDD10.0	2507	30	69	161	261	327	340	349	338	283	216	100	33
	CDD18.3	451	0	0	4	43	82	93	92	80	45	12	0	0
	CDH23.3	1945	0	11	104	399	514	318	229	217	122	29	3	0
CDH26.7	262	0	0	4	75	117	37	12	13	4	0	0	0	
Wind	WSAvg	2.9	3.1	3.5	3.8	3.9	3.5	2.8	2.3	2.0	2.1	2.3	2.6	2.7
Precipitation	PrecAvg	957	15	19	22	39	96	177	182	173	111	69	39	15
	PrecMax	1362	35	66	67	92	281	291	414	339	214	164	104	93
	PrecMin	727	1	1	0	0	8	85	70	18	18	1	6	0
	PrecStd	154	9	18	19	24	63	64	79	78	46	39	27	21
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	24.7	27.2	30.0	31.1	29.4	28.0	28.1	27.4	25.4	23.6	20.8
		MCWB	10.4	11.4	12.6	14.4	16.5	19.7	20.1	20.1	19.4	17.8	14.5	11.6
	2%	DB	19.7	23.0	25.8	28.7	29.4	27.7	26.7	26.7	25.9	24.1	21.7	19.2
		MCWB	10.2	11.0	12.4	14.3	16.6	19.8	20.1	20.0	19.2	17.0	13.9	11.4
	5%	DB	18.2	21.5	24.4	27.4	27.9	26.4	25.7	25.6	24.8	23.0	20.3	17.6
		MCWB	10.0	10.6	12.2	14.4	16.9	19.6	19.9	19.7	18.5	16.8	13.6	11.0
	10%	DB	16.5	19.7	22.9	25.9	26.3	25.2	24.7	24.5	23.6	21.7	18.8	15.8
		MCWB	9.7	10.3	12.2	14.3	17.0	19.4	19.8	19.3	18.2	16.3	13.1	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	13.5	15.2	17.4	20.1	21.2	21.5	21.2	20.6	18.9	16.6	13.7
		MCDB	17.9	20.3	21.8	24.0	25.6	26.3	26.1	26.1	24.9	23.5	20.9	18.0
	2%	WB	11.6	12.5	14.2	16.6	19.4	20.7	20.8	20.7	19.9	18.1	15.6	12.4
		MCDB	17.0	19.4	21.2	23.7	24.7	25.4	25.0	25.1	24.3	22.3	19.3	16.9
	5%	WB	10.8	11.7	13.5	16.0	18.9	20.2	20.4	20.2	19.3	17.6	14.7	11.5
		MCDB	16.2	18.7	20.7	22.9	23.9	24.6	24.4	24.3	23.3	21.3	18.2	16.0
	10%	WB	10.0	10.9	12.9	15.4	18.3	19.8	20.0	19.7	18.8	17.0	13.7	10.8
		MCDB	15.4	18.0	20.1	22.4	23.0	23.8	23.7	23.4	22.4	20.4	17.3	15.0
Mean Daily Temperature Range	5% DB	MDBR	10.7	12.2	12.8	11.9	9.4	6.9	6.7	7.2	7.6	7.6	9.4	9.4
		MCDBR	14.9	16.1	15.9	14.3	12.2	9.0	8.7	9.4	9.7	9.9	12.1	12.9
		MCWBR	6.8	6.2	5.3	3.6	3.1	2.9	3.2	3.5	3.5	3.8	5.4	6.1
	5% WB	MCDBR	12.9	13.9	13.5	11.9	8.7	7.4	7.4	8.1	8.0	8.1	9.6	10.9
		MCWBR	6.7	6.4	5.4	4.0	3.0	2.8	3.1	3.3	3.2	3.5	4.7	5.7
Clear-Sky Solar Irradiance	taub	0.375	0.384	0.536	0.518	0.428	0.420	0.418	0.453	0.441	0.447	0.404	0.403	
	taud	2.236	2.232	1.791	1.907	2.266	2.319	2.314	2.191	2.202	2.132	2.179	2.127	
	Ebn at Noon	874	895	773	798	869	869	871	843	846	819	834	821	
	Edh at Noon	124	133	218	199	138	130	131	147	143	146	130	134	
All-Sky Solar Radiation	RadAvg	3.27	4.31	4.75	5.35	5.24	4.49	4.51	4.43	3.99	3.25	3.48	2.87	
	RadStd	0.46	0.74	0.41	0.50	0.55	0.48	0.28	0.26	0.33	0.37	0.42	0.41	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.46	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.41	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	+109	+61

Nomenclature: See separate page