

LINCANG, China

WMO: 569510

Lat: 23.8814N

Lon: 100.0898E

Elev: 4931

StdP: 12.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.4	41.2	27.3	25.5	67.4	30.0	28.9	65.8	15.0	68.1	12.8	67.8	1.2	140	0.256

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.9	85.6	64.2	83.8	64.3	82.2	64.3	70.3	78.1	69.8	77.5	69.3	76.3	6.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	125.0	72.9	67.7	122.6	72.5	67.3	120.9	72.2	37.8	78.9	37.3	77.9	36.8	76.9	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	9.8	8.0	DB	35.4	89.5	2.3	3.4	33.7	91.9	32.4	94.0	31.1	95.9	29.5	98.4	(4)
(5)			WB	33.2	71.6	1.9	0.8	31.8	72.2	30.7	72.7	29.6	73.1	28.2	73.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	55.2	58.8	63.9	68.4	71.3	73.1	72.6	72.9	71.3	67.7	61.2	55.9	(6)
(7)		DBStd	7.14	2.54	3.21	3.40	3.31	3.53	2.35	2.38	2.29	2.80	3.05	3.28	3.17	(7)
(8)		HDD50	5	1	1	0	0	0	0	0	0	0	0	0	3	(8)
(9)		HDD65	970	305	175	59	10	4	0	0	0	3	12	120	282	(9)
(10)		CDD50	5864	162	246	431	551	661	692	702	711	639	547	336	186	(10)
(11)		CDD65	1354	0	0	24	112	200	242	237	246	192	94	7	0	(11)
(12)		CDH74	6173	2	64	450	1000	1212	904	703	876	623	297	41	1	(12)
(13)		CDH80	939	0	1	31	198	292	143	78	127	61	8	0	0	(13)
(14)	Wind	WSAvg	2.6	2.5	3.0	3.4	3.3	2.9	2.5	2.3	2.5	2.3	2.3	2.2	(14)	
(15)	Precipitation	PrecAvg	45.7	0.4	0.6	0.6	1.3	3.4	7.9	9.5	8.9	5.9	4.3	2.2	0.7	(15)
(16)		PrecMax	59.3	1.9	3.6	2.2	3.3	8.5	15.2	14.3	16.9	10.4	8.5	6.3	4.8	(16)
(17)		PrecMin	35.9	0.0	0.0	0.0	0.1	0.4	4.3	5.2	3.3	3.6	1.1	0.0	0.0	(17)
(18)		PrecStd	5.6	0.5	0.7	0.6	0.7	2.2	2.4	2.5	2.8	1.7	2.0	1.9	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.5	78.7	82.8	86.8	88.4	87.6	84.8	85.8	84.1	81.0	77.5	73.0	(19)
(20)			MCWB	52.3	53.4	55.9	59.2	63.5	66.5	69.0	69.0	67.6	64.7	59.9	55.1	(20)
(21)		2%	DB	71.1	76.0	80.7	84.4	85.6	83.6	82.1	83.2	81.8	79.0	75.1	70.6	(21)
(22)			MCWB	51.7	52.8	55.5	59.0	63.5	67.3	69.1	68.6	66.9	64.0	58.9	53.8	(22)
(23)		5%	DB	69.4	73.8	78.9	82.4	83.4	81.2	80.0	81.1	79.8	77.3	73.1	68.8	(23)
(24)			MCWB	51.1	52.3	55.0	58.7	63.5	67.7	68.9	68.6	66.8	63.5	58.1	53.4	(24)
(25)		10%	DB	67.1	71.5	76.6	80.1	80.9	79.0	78.0	78.9	77.7	75.4	71.0	66.7	(25)
(26)			MCWB	50.5	51.6	54.6	58.5	63.5	67.7	68.8	68.4	66.9	63.5	57.3	52.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	56.5	59.8	63.8	68.7	70.7	71.1	71.1	70.1	68.0	64.5	59.5	(27)
(28)			MCDWB	66.0	70.4	74.0	74.5	76.9	78.6	79.0	79.9	78.6	76.9	70.6	64.8	(28)
(29)		2%	WB	54.1	54.8	58.1	62.5	67.6	69.9	70.4	70.2	69.2	66.8	62.7	57.1	(29)
(30)			MCDWB	65.7	70.2	73.2	75.1	75.8	77.3	77.8	78.6	77.1	74.7	69.1	65.6	(30)
(31)		5%	WB	52.8	53.6	56.9	61.4	66.9	69.2	69.8	69.6	68.5	66.0	61.3	55.5	(31)
(32)			MCDWB	65.0	69.5	72.2	74.7	74.9	76.3	77.0	77.5	76.0	73.4	67.8	64.7	(32)
(33)		10%	WB	51.5	52.5	55.9	60.4	66.1	68.7	69.2	69.0	67.9	65.2	59.8	54.0	(33)
(34)			MCDWB	63.7	68.0	71.4	74.1	74.0	75.4	75.6	76.2	74.9	72.0	66.9	63.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	25.7	26.0	24.6	22.2	16.8	11.9	10.5	12.1	13.1	15.2	20.4	22.9	(35)
(36)			MCDBR	29.6	29.6	28.5	26.0	22.4	16.5	14.5	16.3	16.9	19.1	23.3	26.0	(36)
(37)			MCWBR	12.4	10.5	9.0	7.4	6.1	4.5	4.4	4.9	5.4	6.8	9.3	11.5	(37)
(38)		5% WB	MCDBR	25.0	25.9	23.1	20.4	14.1	11.6	11.4	13.0	13.3	13.8	16.0	20.6	(38)
(39)			MCWBR	11.8	10.0	8.3	6.9	4.9	4.1	4.1	4.5	4.8	5.3	7.1	9.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.357	0.542	0.533	0.433	0.394	0.398	0.430	0.417	0.393	0.341	0.326	(40)	
(41)		taud	2.444	2.340	1.786	1.887	2.276	2.447	2.425	2.306	2.319	2.354	2.433	2.446	(41)	
(42)		Ebn at Noon	300	294	244	250	274	283	282	274	276	279	289	292	(42)	
(43)		Edh at Noon	32	38	70	64	43	36	37	42	40	37	32	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1350	1630	1663	1683	1564	1367	1267	1366	1320	1238	1301	1191	(44)	
(45)		RadStd	112	136	141	134	167	129	89	102	94	145	109	110	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.36	N/A	N/A	+1.10	N/A	N/A	N/A	N/A	+173	+106
(47) Regional (7 neighbors)		+0.59	N/A	N/A	+0.95	N/A	N/A	N/A	-79	+259	+189

Nomenclature: See separate page