

JINGHONG, China

WMO: 569590

Lat: 22.0127N

Lon: 100.7822E

Elev: 1900

StdP: 13.71

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.8	52.0	41.9	42.0	75.9	44.9	47.1	74.1	10.7	77.8	8.6	79.0	1.2	250	0.247

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.8	96.2	72.0	93.9	72.4	91.8	72.9	78.1	87.6	77.4	86.5	77.0	85.8	5.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.7	144.6	80.9	75.3	142.4	80.3	74.7	139.6	79.8	43.3	88.2	42.6	87.3	42.1	86.1	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	7.5	6.5	45.4	100.9	3.3	2.2	43.0	102.5	41.1	103.8	39.2	105.0	36.8	106.6		
			45.0	79.6	2.7	1.5	43.0	80.6	41.5	81.5	39.9	82.3	37.9	83.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	75.4	66.5	69.7	73.8	78.5	80.4	81.3	80.2	80.4	79.6	76.7	71.3	66.6	(6)
(7)		DBStd	6.26	3.18	3.55	3.43	3.55	3.89	2.42	2.65	2.31	2.56	3.00	3.54	3.99	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	63	20	8	2	0	0	0	0	0	0	0	3	30	(9)
(10)		CDD50	9286	512	553	738	855	944	939	937	941	887	827	640	513	(10)
(11)		CDD65	3874	67	141	275	405	479	489	472	476	437	362	193	78	(11)
(12)		CDH74	31779	508	1465	2591	3913	4492	4518	3802	3764	3273	2204	919	330	(12)
(13)		CDH80	11989	62	505	1147	1954	2081	1692	1241	1266	1153	693	171	24	(13)
(14)	Wind	WSAvg	2.2	1.9	2.2	2.1	2.4	2.6	2.9	2.6	2.3	1.9	1.8	1.6	1.7	(14)
(15)	Precipitation	PrecAvg	46.1	0.7	0.5	0.8	1.9	5.1	6.5	8.6	9.0	5.4	3.9	2.6	0.9	(15)
(16)		PrecMax	59.7	3.5	2.4	4.0	5.4	12.4	11.4	14.0	14.7	11.4	8.8	8.4	7.2	(16)
(17)		PrecMin	34.5	0.0	0.0	0.0	0.0	1.3	1.7	4.4	1.9	2.0	1.3	0.1	0.0	(17)
(18)		PrecStd	6.4	0.8	0.6	0.9	1.3	3.0	2.7	2.6	3.0	2.4	2.0	2.5	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.4	91.1	94.9	99.2	100.3	95.8	94.0	93.3	92.7	90.2	86.5	82.8	(19)
(20)			MCWB	64.0	63.6	65.8	68.5	70.5	75.7	76.4	76.8	75.6	74.5	71.1	68.2	(20)
(21)		2%	DB	81.7	88.2	92.1	96.1	96.7	92.5	91.3	90.8	90.5	88.2	84.1	80.0	(21)
(22)			MCWB	64.0	63.6	66.1	70.2	73.2	76.2	76.4	76.6	75.7	73.9	70.1	67.1	(22)
(23)		5%	DB	79.5	85.9	89.8	93.6	93.6	90.2	89.0	88.8	88.6	86.4	82.0	77.9	(23)
(24)			MCWB	63.8	63.5	66.4	70.7	73.5	76.0	76.3	76.4	75.3	73.3	69.7	65.9	(24)
(25)		10%	DB	77.0	83.3	87.1	90.8	90.2	88.1	86.5	86.7	86.6	84.3	79.7	75.4	(25)
(26)			MCWB	63.3	63.3	66.5	70.8	73.6	75.9	76.1	76.2	75.1	72.8	68.5	64.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	69.5	72.8	76.0	77.8	78.7	78.9	79.0	78.2	77.0	73.9	71.3	(27)
(28)			MCD B	78.4	83.8	85.4	89.4	89.4	89.0	88.6	88.6	87.5	86.2	81.7	79.5	(28)
(29)		2%	WB	66.9	67.5	71.1	74.4	76.6	77.8	77.9	77.9	77.2	75.6	72.6	69.3	(29)
(30)			MCD B	76.6	81.0	83.6	88.1	87.8	87.6	86.7	86.8	86.3	84.3	80.0	76.4	(30)
(31)		5%	WB	65.5	66.0	69.6	73.2	75.7	77.2	77.2	77.1	76.5	74.7	71.4	67.6	(31)
(32)			MCD B	75.1	79.7	82.5	86.9	85.9	86.5	85.4	85.6	84.9	82.7	78.4	74.3	(32)
(33)		10%	WB	64.3	64.6	68.3	72.2	74.9	76.5	76.5	76.5	75.9	73.9	70.1	66.2	(33)
(34)			MCD B	73.7	78.2	80.7	85.3	84.3	85.0	83.7	84.1	83.5	81.0	76.5	72.4	(34)
(35)	Mean Daily Temperature Range	MDBR	23.6	29.1	27.9	24.5	18.1	13.8	12.2	13.3	14.9	15.5	17.9	19.0	(35)	
(36)		5% DB	MCD BR	28.0	33.9	33.6	30.2	25.0	17.5	16.9	17.0	18.1	18.7	20.4	21.5	(36)
(37)			MCWBR	11.3	11.2	10.2	8.3	6.3	4.5	4.4	4.7	5.0	5.8	7.4	8.8	(37)
(38)		5% WB	MCD BR	23.0	28.1	25.6	23.8	17.6	14.6	13.6	14.5	15.3	15.7	16.7	18.3	(38)
(39)			MCWBR	10.1	10.7	9.6	8.3	5.5	4.5	4.4	4.7	4.8	5.4	6.6	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.467	0.727	0.698	0.484	0.435	0.432	0.467	0.474	0.487	0.416	0.406	(40)	
(41)		taud	2.278	2.072	1.494	1.608	2.211	2.386	2.376	2.258	2.215	2.137	2.290	2.275	(41)	
(42)		Ebn at Noon	274	260	202	212	261	272	272	265	261	251	266	266	(42)	
(43)		Edh at Noon	39	51	94	85	46	39	39	44	45	47	38	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1297	1624	1673	1799	1651	1436	1303	1377	1393	1274	1283	1147	(44)	
(45)		RadStd	93	134	104	133	153	116	105	101	80	106	94	102	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	N/A	-1.80	+0.95	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.58	N/A	N/A	+0.94	N/A	N/A	N/A	-83	+302	+232

Nomenclature: See separate page