

PU'ER SIMAO, China

WMO: 569640

Lat: 22.795N

Lon: 100.959E

Elev: 1303

StdP: 86.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	7.6	0.2	4.5	21.3	1.9	5.1	21.8	4.4	21.0	4.1	20.9	0.3	340	0.227

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.5	30.8	17.8	29.8	18.1	28.9	18.6	22.3	26.3	22.0	26.0	21.7	25.4	2.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	18.6	23.8	20.9	18.2	23.5	20.6	18.0	23.3	73.0	26.7	71.6	26.1	70.4	25.7	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.2	3.4	3.0	DB	4.3	32.6	1.5	1.1	3.2	33.4	2.3	34.0	1.4	34.6	0.3	35.4	
			WB	3.7	23.4	1.5	0.9	2.6	24.1	1.7	24.6	0.9	25.1	-0.2	25.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	14.8	16.5	19.2	21.9	23.1	23.7	23.2	23.2	22.5	20.9	17.8	15.1	(6)
		DBStd	3.67	1.72	2.05	2.04	1.91	2.00	1.28	1.29	1.23	1.54	1.70	1.98	2.25	
		HDD10.0	2	1	0	0	0	0	0	0	0	0	0	0	1	
		HDD18.3	320	109	56	14	2	1	0	0	1	3	33	102		
		CDD10.0	3717	150	181	287	358	407	411	408	409	376	337	233	159	
		CDD18.3	996	0	4	42	111	151	161	150	151	127	82	17	2	
		CDH23.3	4988	3	108	505	963	958	692	502	539	441	230	45	2	
(13)		CDH26.7	987	0	4	85	293	292	119	66	72	48	9	0	0	(13)
(14)	Wind	WSAvg	1.0	0.9	1.1	1.2	1.2	1.2	1.1	0.9	0.9	0.9	0.9	0.9	0.8	(14)
(15)	Precipitation	PrecAvg	1513	19	15	21	47	152	225	325	326	153	135	77	21	(15)
(16)		PrecMax	1888	94	49	94	104	281	578	629	621	254	313	304	91	(16)
(17)		PrecMin	1117	0	0	0	0	48	93	132	127	67	24	4	0	(17)
(18)		PrecStd	214	22	13	21	28	65	93	126	110	48	72	76	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	23.6	27.3	29.8	31.8	32.6	30.8	29.7	29.8	29.2	27.7	25.8	23.5		(19)
(20)		0.4% MCWB	13.1	13.7	14.5	16.2	17.7	20.5	21.8	21.4	20.8	19.6	17.6	15.8		(20)
(21)		2% DB	22.6	25.9	28.7	30.7	31.1	29.2	28.4	28.5	28.0	26.6	24.6	22.3		(21)
(22)		2% MCWB	13.1	13.4	14.4	16.3	18.1	20.8	21.6	21.4	20.8	19.2	17.1	15.1		(22)
(23)		5% DB	21.6	24.7	27.6	29.7	29.8	28.0	27.2	27.3	27.0	25.7	23.5	21.2		(23)
(24)		5% MCWB	13.0	13.2	14.3	16.4	18.5	21.0	21.5	21.4	20.5	19.1	16.6	14.6		(24)
(25)		10% DB	20.6	23.4	26.4	28.5	28.3	26.9	26.1	26.2	25.9	24.7	22.4	20.1		(25)
(26)		10% MCWB	13.0	13.0	14.3	16.5	18.9	21.0	21.3	21.2	20.4	18.9	16.2	14.3		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	16.1	16.9	18.4	20.0	21.7	22.5	22.8	22.7	22.2	21.2	19.5	17.7		(27)
(28)		0.4% MCDB	19.8	22.3	23.6	25.3	26.4	26.8	27.0	27.1	26.6	25.4	23.0	21.2		(28)
(29)		2% WB	15.2	15.7	17.4	19.2	21.1	22.0	22.2	22.2	21.7	20.6	18.7	16.8		(29)
(30)		2% MCDB	19.1	21.1	22.6	24.6	25.6	26.3	26.1	26.3	25.8	24.5	21.9	20.1		(30)
(31)		5% WB	14.5	14.8	16.6	18.7	20.7	21.7	21.9	21.9	21.3	20.1	18.1	15.9		(31)
(32)		5% MCDB	18.8	20.6	21.9	24.4	24.9	25.6	25.6	25.7	25.1	23.7	21.3	19.2		(32)
(33)		10% WB	13.9	14.0	15.8	18.1	20.3	21.4	21.6	21.5	21.0	19.7	17.5	15.1		(33)
(34)		10% MCDB	18.4	20.2	21.8	24.2	24.3	25.1	24.9	25.0	24.5	23.0	20.6	18.5		(34)
(35)	Mean Daily Temperature Range	MDBR	11.7	13.5	13.4	12.1	9.0	6.5	5.7	6.3	6.8	7.2	9.0	9.6		(35)
(36)		5% DB MCDBR	13.8	15.9	16.0	14.5	12.2	8.6	7.8	8.2	8.6	9.0	10.5	11.0		(36)
(37)		5% WB MCWBR	5.3	5.0	4.4	3.4	2.7	2.3	2.5	2.5	2.6	2.8	3.7	4.3		(37)
(38)		5% DB MCDBR	10.6	12.2	11.4	10.9	8.0	6.6	6.5	6.9	7.1	7.2	7.8	8.6		(38)
(39)		5% WB MCWBR	4.7	4.6	4.2	3.6	2.5	2.2	2.4	2.5	2.5	2.6	3.1	3.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.390	0.590	0.566	0.426	0.394	0.395	0.425	0.424	0.423	0.365	0.359		(40)
(41)		taud	2.380	2.258	1.708	1.831	2.326	2.462	2.443	2.329	2.308	2.272	2.382	2.362		(41)
(42)		Ebn at Noon	916	895	734	762	871	892	892	869	866	851	890	888		(42)
(43)		Edh at Noon	109	132	239	215	130	113	115	129	129	128	108	108		(43)
(44)	All-Sky Solar Radiation	RadAvg	4.03	5.08	5.22	5.56	5.15	4.50	4.18	4.41	4.30	3.87	3.95	3.52		(44)
(45)		RadStd	0.34	0.46	0.37	0.42	0.49	0.36	0.30	0.31	0.27	0.40	0.30	0.34		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.48	N/A	N/A	+0.46	+0.19	N/A	N/A	-51	+175	+130
(47)	Regional (7 neighbors)	+0.31	N/A	N/A	+0.58	N/A	N/A	N/A	-44	+144	+105

Nomenclature: See separate page